


**Investigation on Environmental
AWARENESS
ADDENDUM N°2
CENTRAL EÓLICA ENERGÉTICA I
PARTIDO DE TORNQUIST
PROVINCIA DE BUENOS AIRES
REPÚBLICA ARGENTINA**



August 2018

General Index

Chapter 01 General information

1. Company that requests the environmental document
2. Company that elaborated the environmental document
3. Technical Manager
4. Technical Department that elaborated the environmental document
5. Accreditation document

Chapter 02 Descriptive Memory

1. Introduction
2. Geographic Location
3. Access roads to the Project- Logistics from Ing White Port
4. Node of bridging to the National Interconnected System
5. Technical Description of the Project
6. Overview table of the Project
7. Preparatory Stage of the site and construction
8. Operative Stage and Maintenance
9. Work Schedule
10. Estimated total funding cost
11. Annex C.02
 1. Study of Evaluation Tool for the Wind Resource and Power Generation
 2. Building Plans
 3. Technical Specifications of the Wind Turbines
 4. Schedule of the Planned Preparations for Project Development

Chapter 03 Environmental Baseline

1. Introduction
2. Update Reports and Environmental Baseline Amplification

Chapter 04 Specific Studies

1. Introduction
2. Annex C.04
 1. Analysis of the Surface affected by the Wind Power Plant
 2. Analysis of Noise Effects produced by wind turbines
 3. Analysis of Shadow Effects produced by wind turbines
 4. Analysis of Low Frequency Fields and the Corona Effect
 5. Analysis of the Production Intake of "Clean" Electric Energy into the Regional System
 6. Analysis of the Possible Contribution in Reduction of Emission Factors
 7. Analysis of Energy Production Effect on the saving of Methane Tankers.

Chapter 05 Addendum Report N° 2

1. Presentation
2. Antecedents
3. Introduction
4. Public Enquiry Documents
5. Descriptive Memory of the updated Project
6. Evaluation Methodology on environmental impact
7. Information research
8. Environmental Baseline
9. Identification and Evaluation on environmental impact
10. Analysis of environmental impact related to the updated Project
11. Mitigation Actions and Environmental Management Plan
12. Conclusion
13. Annex C.05
 1. Documents/Notes and Affidavits related to the Project
 2. Dangerous and/or Chemical Substances, fuel, other substances that will be deposit in the site - HDS

Chapter 01

General information

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness N° 2 Wind Energy Centre 1</p>	
<p>Doc. N°: CEEN-IA-2655-08/18</p>		<p>Date 15/08/2018 Rev: A Page 2 of 6</p>

Chapter 01

General information

Index

1.	COMPANY THAT REQUESTS THE ENVIRONMENTAL DOCUMENT	3
2.	COMPANY THAT ELABORATED THE ENVIRONMENTAL DOCUMENT	3
3.	TECHNICAL MANAGER.....	3
4.	TECHNICAL DEPARTMENT THAT ELABORATED THE ENVIRONMENTAL DOCUMENT	4
5.	ACCREDITATION DOCUMENTS	5

1. COMPANY THAT REQUESTS THE ENVIRONMENTAL DOCUMENT

Company Name	Energética Argentina S.A.
Address	1023 Carlos Pellegrini, 9° Floor. Autonomous City of Buenos Aires
Representative of the Company	Rubén Zaia Business Development Manager
Tel/Fax	+54 11 48722959.
Electronic mail	Ruben.zaia@aes.com
Web Page	https://www.aesargentina.com.ar/
Company Main Activity	Electric Power Generation

2. COMPANY THAT ELABORATED THE ENVIRONMENTAL DOCUMENT

Full Name	ICONO SRL.
Address	53 Villarino. (B8000JIA) Bahía Blanca - Buenos Aires - Argentina
Tel/Fax	Tel (+ 54291) 4556484 / Fax (+ 54291) 4521352.
Electrónico mail	Ruben.zaia@aes.com
Web Page	https://www.aesargentina.com.ar/

3. TECHNICAL MANAGER

Nombre completo	Mario Rubén Tami.
Address	Humberto Primo 560 - (8000) Bahía Blanca - Buenos Aires.
Tel/Fax	+54 291 4637306.
Electrónico mail	Ruben.zaia@aes.com
Job	Electrical Engineer Mg in Environmental Impact Evaluation Mg in Renewable Energies
Registration Number	N° 53098 College of Engineers, Buenos Aires Province.
Professional Registry N°	4156 Provincial Agency for Sustainable Development (OPDS), Buenos Aires Province

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N° 2	 ENERGÉTICA ARGENTINA
Doc. N°: CEEN-IA-2655-08/18		Date 15/08/2018 Rev: A Page 4 of 6

4. TECHNICAL DEPARTMENT THAT ELABORATED THE ENVIRONMENTAL DOCUMENT

Full Name	Professional Degree - Specialty
Tami, Mario Rubén	Electrical Engineer - Ms. in Environmental Impact Evaluation.
Alonso, Guillermo	Electrical Engineer.
Corvatta, Vivian	Licenciate in Geology.
Long, María Andrea	Licenciate in Biology - Dr. in Botany. Carrizo, Martín
Andrés	Licenciate in Biology.


5. ACCREDITATION DOCUMENTS

Organismo Provincial para el Desarrollo Sostenible ORIGINAL **Liquidación 515093**
Arancelamiento Fecha de Emisión 22/05/2018
 Gastos por Cuenta de Terceros - / -
 Gobernación I.P.M.A. Dirección Provincial de Saneamiento y control del Medio Código de Barras Mesa de Entradas OPDS N° 275518
 Decreto 4677/97 Tel. 0291-453-1352/455-
 Nombre ICONO SRL Cuit 30-66416214/4
 Domicilio VILLARINO Nro 53
 Localidad BAHIA BLANCA


Cód.	Descripción	Serie	Desde	Hasta	Cantidad	Unitario	Subtotal
2.2	INSCRIP. DE CONSULTORAS Y ORGANISMOS PR				1	3,540.0000	3,540.0000
Total							3,540.00

Recibí el importe correspondiente según el siguiente detalle:
 la suma de pesos tres mil quinientos cuarenta


Corresponde a los siguientes periodos:







Departamento de Tesorería, La Plata 22/05/2018 Responsable por opds

Recibí conforme el detalle de la presente liquidación  Responsable por Firma

Organismo Provincial para el Desarrollo Sostenible

ORIGINAL

Liquidación 515092
Fecha de Emisión 22/05/2018

Arancelamiento

Gastos por Cuenta de Terceros
Gobernación I.P.M.A. Dirección Provincial de Saneamiento y control del Medio
Decreto 4677/97

Código de Barras Mesa de Entradas OPDS N° 275515

Nombre TAMI MARIO RUBEN
Domicilio HUMBERTO 1° Nro 560
Localidad BAHIA BLANCA

Tel. 0291-15-4637306
Cuit 27-17140110/4

Cód.	Descripción	Serie	Desde	Hasta	Cantidad	Unitario	Subtotal
2.1.	INSCRIP. DE PROFESIONAL POR AÑO - EVAL I				1	700.0000	700.0000
Total							700.00

Recibi el importe correspondiente según el siguiente detalle:
la suma de pesos setecientos

Corresponde a los siguientes periodos:

ORGANISMO PROVINCIAL PARA EL
DESARROLLO SOSTENIBLE
DEPARTAMENTO
TESORERIA
PAGADO

Departamento de Tesorería, La Plata 22/05/2018

Responsable por opds

Responsable por Firma

CHAPTER 02

DESCRIPTIVE MEMORY

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	Study on Environmental Awareness Addendum N°	
<p>Doc. N°: CEEN-IA-2655-08/18</p>	2 Wind Power Centre 1	<p>Date 15/08/2018 Rev: A Page 2 of 36</p>

CHAPTER 02

DESCRIPTIVE MEMORY

Index

1.	INTRODUCTION	4
2.	Geographic Location	6
3.	Access roads to the Project- Logistics from Ing White Port	7
4.	Node of bridging to the National Interconnected System	9
4.1.	Single line Schematic of the Electric System	11
5.	Technical Description of the Project	12
5.1.	Electric Energy Transport System	12
5.1.1.	Transformer Station (MT/AT)	12
5.1.2.	Opening of LAT (132 KV) and bonding to the ET (MT/AT)	15
5.2.	Wind Farm	16
5.2.1.	Poles of Meteorological Stations	16
5.2.2.	Technical Specifications of the Wind Turbines	16
5.2.3.	Distribution of wind turbines in the plant	19
5.2.4.	Wind resources and energetic production	21
5.2.5.	Infrastructure Facilities	21
6.	Overview table of the Project	28
7.	Preparatory Stage of the site and construction	30
7.1.	Workroom	30
7.2.	Services	32
7.3.	Machinery and equipment required for the construction	33
7.4.	Staff involved in the Project	34
8.	Operative Stage and Maintenance	35
8.1.	Electric Energy Transport System	35
8.2.	Wind Farm	35

 Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	
Doc. N°: CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date 15/08/2018 Rev: A Page 3 of 36

- 8.2.1. Staff involved in the Project (O&M) 35
- 9. Work Schedule 35
- 10. Estimated total funding cost 35
- 11. Annex C.02 36

 Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	
Doc. N°: CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date 15/08/2018 Rev: A Page 4 of 36

CHAPTER 02

DESCRIPTIVE MEMORY

1. INTRODUCTION

The current document constitutes the updated Descriptive Memory of the Energetic Wind Power Plant 1, to be developed approximately at 26km South of the city of Tornquist, near the Paraje García del Río, Tornquist District, Buenos Aires Province, Argentine Republic.

The Energetic Wind Power Plant 1 is a private venture, property of the company Energética Argentina S.A. which will be built in the same site of the rural property indicated in the Study of Environmental Impact (EIA- 09/02/2012) and Addendum at EIA (13/06/2016).

The update of the Descriptive Memory arises as a consequence of the venture promoting company's decision to make some modifications to the Project, mainly based on the change of the wind turbines. The machines will have similar power per unit (of 3.2 MW and 3.325 MW) and the Wind Farm will maintain the similar total power already installed (from 99.2MW to 99.75MW); consequently, there will be a reduction of one unit in the machines to be installed.

The projection of the Wind Centre has been designed through the installation of 30 wind turbines Nordex-Acciona, model AW132/3300TH120, class IEC IIB.

As it was indicated in previous environmental studies, the electric energy produced by the Wind Farm will be evacuated into the Argentine System of Electrical Interconnection (SADI) through a new Transformer Station of 132/33/13.2KV 1x110/110/40 MVA; the site will have another similar transformer in cold generation reserve. For bridging the Wind Power Plant, it will be opened the LAT of 132KV between EE.TT Bahía Blanca (500/132 KV) and ET Tornquist (132/33/13,2 KV)

The collector electricity network will be built in the level 33 KV and it will be constituted by underground cables that will directly undertake the ET (MT/AT) Each wind turbine will provide with a step-up transformer 12/33 KV of 3,400 KVA and the corresponding cells in the 33 kV level for the bonding of the collector network circuits (located at the bottom of the simple concrete tower).

 Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	
Doc. N°: CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date 15/08/2018 Rev: A Page 5 of 36

Down below there is a summary chart with the general description of the Project, drawn by Energética Argentina S.A.

General Description of the Project - Energetic Wind Power Plant 1	
Electrical Energy Transportation System and its Vinculation to SADI	<p>1- Transformer Station (MT/AT)</p> <p>Level of Tension: 132/33/13,2 KV.</p> <p>Total Power Installed: 1x110/110/40 MVA.</p> <p>Length of access way to the ET: 1,585 Km (from neighborhood street).</p> <p>2- Opening of Overhead Power Line in High Voltage and bonding to ET (MT/AT)</p> <p>Level of Tension: 132 KV.</p> <p>Place of bonding to SADI: Between pickets N°151 and N°152 of the LAT in 132 KV (existing) between EE.TT Bahía Blanca and ET Tornquist.</p> <p>Configuration of the LAT opening: "U". Configuration of the structures: Overhear, double ternary.</p> <p>Length of the installation hollow: 50 meters</p>
Wind Farm	<p>3- Total Power Installed: 99.75 MW.</p> <p>It will be composed of 30 wind turbines Nordex-Acciona, model AW132/3300TH120 class IEC JIB and their complementary.</p> <p>Complementary:</p> <ul style="list-style-type: none"> ▪ 2 Poles with meteorological stations; of 48 meters and 82 meters (existing). ▪ 30 foundations for wind turbines. ▪ 30 set-up platforms for wind turbines. ▪ 18,0 Km of internal ways to be constructed and 5,0 Km of access ways to realign. ▪ 22.0 Km of underground tubes for: <ul style="list-style-type: none"> - Collector of Electrical Energy Network in 33 KV- - Earthing System. <p>System of Communication Network.</p>

2. Geographic Location

As mentioned before the Wind Energy Plant will be developed in the same Rural Site.

The property is private and covers a total area of 950 hectares. It is conformed of 3(three) portions of countryside with the following cadastral identification:

Table N° 1 Identification fo Rural Property and cadastral information.

Name of the Rural Property	Cadastral Information					
	Province	Department	District	Circ	Lot	Surface area
A) Guanaco Chico.	Buenos Aires	Tornquist	3533	III	39. F	311 hectares
B) Reyrolles.	Buenos Aires	Tornquist	45.	VIII	569.	333 hectares
C) San Bautista Sur.	Buenos Aires	Tornquist	14852.	VIII	566	306 hectares

In Figure N°1 there is a picture taken from Google Images, the geographical location of the Wind Energy Plant projected, related to the cities of Tornquist, Tres Picos and Paraje García del Río. And in Figure N° 2 , the distribution of the three rural sites.




Figure N° 1 Google Image with the geographical location of the Wind Energy Centre

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N°: CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date 15/08/2018 Rev: A Page 7 of 36</p>



Figure N° 2 Google Image with the distribution of the three rural sites.

3. ACCESS ROADS TO THE PROJECT- LOGISTICS FROM ING WHITE PORT

The ways of access to the project area are the same indicated in previous environmental studies.

The rural sites (A, B and C) can be reached from the National Route N° 33 and public neighboring streets of firm land (approximate width 20 meters), which are in good condition. These are the accesses:

- The main access to the area of the Project will be from the National Route N°33 in the kilometer 40 that joins the city of Bahía Blanca with the city of Tornquist. Heading from Bahía Blanca, it is 40 km North, and then the progression indicated, approximately 4.7 Km. along a neighboring land street, in the Northeastern direction.
- From the progressing km. 47, the site can be reached as well travelling approximately 5 km. along a neighboring land street, in the Southeastern direction.
- One can reach the area of the Project, through a neighboring land road, that joins the town of Tres Picos with the Paraje García del Río.

 Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N° 2 Wind Power Centre 1	 Date 15/08/2018 Rev: A Page 8 of 36
Doc. N°: CEEN-IA-2655-08/18		

The most important components (in relation to quantities, dimensions and weights) are the 30 wind turbines that will be transported by sea from their country to the multipurpose quay of Engineer White Port.

The transportation of the components from Engineer White Port to the setting-up site will be done through land travel. The zone that will be affected by transportation truck circulation involves approximately 60 Km. The itinerary will be the following:

- Engineer White Port.
- 18 de Julio Avenue
- Section of the National Route N° 3
- Hundred and Fiftieth Road.
- Sections of the National Route N° 33 up the progressing Km40 (site of access to the Wind Energy Plant).

In Figure N°3 there is a Google Image of the general description of the land logistics for the transportation of the components (wind turbines) up to the mounting site.



Figure N° 3 Google Image with the land logistics up to the mounting site.

4. Node of Bridging to the National Interconnected System

It is important to highlight that the node of Bridging to the National Interconnected System by which the electric energy will be evacuated from the Wind Energy Plant is the same indicated in previous studies.

- Connecting Point: PDI 1140.

Line in 132 KV between ET Bahía Blanca (500/132 KV) and ET Tornquist (132/33/13.2 KV).

In Figure N°4 the Geographical Single line Schematic location of the Wind Energy Plant and its connection to SADI is shown.




Figure N° 4 Geographical Single Line Schematic location of the Wind Energy Plant and its connection to SADI. Source: CAMMESA. With modification made by ICONO SRL

In Figure N°5 the Geographical Single line Schematic location of the Wind Energy Plant and its connection to SADI is shown.




Figure N° 5 Geographical Single Line Schematic location of the Wind Energy Plant and its connection to SADI. Source: CAMMESA. With modification made by ICONO SRL

4.1. Single line Schematic of the Electric System

In Figure N° 6 it is shown the Electrical Single line Schematic simplified of the Transformer Station in Bahía Blanca of 500/132 KV 2x300 MVA , the facilities of 132 KV of the Wind Energy Plant and the cross-company limit.




Figure N° 6 Simplified Electrical Single line Schematic of Bahía Blanca with the Wind Energy Plant and the cross-company limit (Energética Argentina S.A.- Transport)

 Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	
Doc. N°: CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date 15/08/2018 Rev: A Page 12 of 36

5. Technical Description of the Project

5.1. Electric Energy Transport System

The electric energy produced by the Wind Plant will be evacuated through the Transportation System made up by the following facilities:

- Transformer Station (MT/AT)
- Opening of Overhead Power Line in High Voltage and bonding to ET .

The corresponding facilities to the Transportation System will not manifest significant modifications of the technical-building type, not even in the geographical location with respect to the Original Project.

5.1.1. Transformer Station (MT/AT)

The function of the Transformer Station (MT/AT) is that of increasing the level of tension from 33 KV, that corresponds to the internal network of connection of the Wind Plant, to the level of 132 KV.

The surface area of the site will be approximately 1.10 hectares (100m x 110 m) with the obligatory perimeter fencing. The access to the Transformer Station (for Transport Transba S.A) is anticipated to be done through a neighboring street located to the south of the Rural Property of "Reyrolles", by an internal path of the Wind Energy Plant, with an approximate extension of 1.585 Km (see Fig N°7).

In the Annex C.02.2 updated plans are presented, for the Plant and electrical installation of the Transformer Station projected.

Document N°	Description
PEEN-EM-001-H1	General Plant.
PEEN-EE-001-H1	Single Line Schematic 132 KV.
PEEN-EE-001-H2	Single Line Schematic 33 KV. - Transba.
PEEN-EE-001-H3	Single Line Schematic 33 KV. - Wind Energy Plant

The design of the ET (MT/AT) will comply with the TECHNICAL SPECIFICATIONS DETERMINED FOR EXECUTION OF CIVIL WORK PROVIDED IN THE GUIDE FOR TRANSFORMER STATION DESIGN OF TRANSBA S.A. It includes mainly:

- Cleaning and preparation of the area.

 Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	
Doc. N°: CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date 15/08/2018 Rev: A Page 13 of 36

- Construction of Civil Work.

General

Sewers.

Perimeter Fencing

Access Gates

Rain drainage

Concrete paving, for internal, principal and secondary roads.

Boxes for the installation of power transformers with their respective flame-retardant walls.

Foundations.

- For the power transformers and lanes. It's been anticipated the construction of oil containment systems, and a tank with enough capacity to store the possible oil leak of the machines of 110/110/40 MA (one in a cold generation reserve).
- For the neuter reactor, limiting reactance and transformer of auxiliary services.
- Light signal towers, guard cable, plant appliances and gantries. Electric conduits.

Installation services (electric light, water supply, drainage system - including the building of a septic tank and cesspit. -)

Safety signaling.

Parking according to the characteristics of the area.

Control facilities

Control room.

Cell room for 33 KV.

Battery room.

Restrooms.

Office.

Services

Electric energy.

Cold and hot water.

Fire alarm. Anti-theft alarm.

 Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	
Doc. N°: CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date 15/08/2018 Rev: A Page 14 of 36

Thermal control with air conditioner (hot-cold)

Telephone and signals.

Sewage.

- Electromechanical set-up - electrical connections and communication links.

Electromechanical Work in the open air.

Double bus bar in 132 KV.

Two output-field-lines in 132 KV.

One transformer field of 132 KV.

Buswork and cables.

Connections in 132 KV. Protection cable.

Earthen meshes.

Insulators of 132 KV.

Support insulators.

Two transformers of 132/34.5/13.8 KV, 110/110/40MVA (*).

One shortcut reactance for the neuter of 33 KV.

One transformer of auxiliary services 33/0.400 KV 250 KVA.

Connections in 33 KV.

Lightning, sockets and driving force.

Maneuvering platforms.

Fittings and ironworks.

(* Note: The energy generated by the Wind Energy Plant will be evacuated by a transformer of 110 MVA; but other of equal characteristics is provided as a cold generation reserve to meet the demands in case of indisposition of the installed unit.

Electromechanical works in the inside

Five cells of 33 KV for the collector network of the Wind Energy Plant (5 collector circuits of underground aluminum cables insulated in XLPE).

One cell of 33 KV for the installation of the power transformer.

One cell of 33 KV for the installation of the extra services transformer.

One cell of 33 KV for the bank of reactive compensation capacitors.

Auxiliary services of CC and CA.

Commercial Measurement System (SMEC)

Measurement System of power quality.

Automatism DAG (incorporated to DAG COMAHUE).

Protections, control and communications for the network of 132 KV as well as for the Wind Energy Plant. In particular, the communication system and control will meet the requirements of CAMMESA and the Transportation regarding the Operating and Deliverance System -SOD (and its components SORT, SCOM, SMEC).

- Site Cleaning and final control.

In Annex C.05.1, the Affidavits are attached expressing that the equipment (power transformers 110/110/40MVA, and others) neither contain biphenyl polychlorides (PCBs), nor that they will store such products in the site.

5.1.2. Opening of LAT (132 KV) and bonding to the ET (MT/AT)

As said before the LAT (132 KV) that interconnects the ET Bahía Blanca with the ET Tornquist goes along the Rural Site "Reyrolles", in which eight structures of simple concrete are installed. The bonding with the ET (MT/AT) is anticipated to be done between pickets N° 151 and N° 152 (see Figure N° 7 and Figure N° 8).




Figure N° 7 Opening of LAT Site and bonding to the ET (MT/AT)
Access way to ET for the Transportation

 Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N° 2 Wind Power Centre 1	
Doc. N°: CEEN-IA-2655-08/18		Date 15/08/2018 Rev: A Page 16 of 36

The aerial path between the Opening of LAT and the Installation to the Gate of the ET will be of approximately 50 meters. It will be constructed in a "U" form with double ternary bearings, with one conductor per phase and a guard cable. The bearings in the line will be poles of pre-stressed reinforced concrete and the phase conductor will be of the Al/Alc type 300/50 mm² of the nominal section.




Figure N° 8 Photomontage of opening of LAAT (132 KV) and bonding to the ET (MT/AT)

5.2. Wind Farm

The update of the Project consists primarily on the change of the wind turbines for units of similar unitary power (of 3.2 MW and 3.325 MW) So, maintaining similar total power installed (from 99.2 MW to 99.75 MW), the number of wind turbines is reduced in one unit (from 31 units to 30). One important aspect is that the new wind turbines will be constructed with concrete towers.

5.2.1. Poles of Meteorological Stations

In Annex N° C.02.1 and previous environmental studies, it is specified the location of the poles and the main technical characteristics of the meteorological stations (data logger, sensors, etc.) With the new configuration of the Wind Plant the furthest wind turbine (N° 12) will be located approximately 5.2 km from the meteorological station (Tres Picos 2).

The meteorological stations provide information over eight years (installed in February and August 2010) with which it was possible to perform an analysis of the energetic production with a representative period of time.

5.2.2. Technical Specifications of the Wind Turbines

The 30 wind turbines selected for the Project are Nordex- Acciona, model AW 132/330o TH120, class IEC IIB of the type of three-blade propeller upwind rotor and they will have a nominal power of 3.325 MW.

 Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	
Doc. N°: CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date 15/08/2018 Rev: A Page 17 of 36

They are regulated by a changing system of independent steps in each blade and they count with an active system of orientation. The control system enables the operation of the wind turbine to a variable speed maximizing the produced power in every moment, and minimizing the charges and the noise.

The towers will be or concrete, 118 meters long. They will be conformed by six parts united between them. Each part will be composed of united precast units, perfectly sealed with a mortar of high resistance between their upright joints. The joint between the parts is produced introducing steel bars of the superior part in the sheath of the inferior one and the subsequent sealing with mortar of high density of the horizontal joint.co

The concrete towers will be manufactured locally, in the Industrial plant in Bahía Blanca. In the following Figure N° 9 the main characteristics of the towers are shown, with images of stockpiling and the transportation of the precast units to the installation site.



Figure N° 9 Main characteristics of the concrete towers with images of the stockpiling and transportation.

The wind turbines will be a hundred and twenty meters hub (h: 120 m) and the diameter of the rotor will be of one hundred and two meters (d: 132 m); see Figure N° 10.




Figure N° 10 Dimensions of the wind turbine complete (1: 120m – 2: 132m).

In Figure N° 11 the wind turbine is shown identifying the main components in the hub and in the nacelle.




Figure N° 11 Image of the wind turbine with identification of the main component in the hub and the nacelle. Source: Energética Argentina S.A.

 Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	
Doc. N°: CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date 15/08/2018 Rev: A Page 19 of 36

The wind turbine contains a multiplier box which is in charge of converting the low rpm that the rotor transmits into high rpm which are the ones that the generator needs to produce electricity. The multiplier box and all the lubrication system require approximately 1000 liters of oil.

In Annex C.02.3 these specific documents of the wind turbines are included:

- Technical specifications of the wind turbine.
- Power curve.
- Acoustic emission of the wind turbine.
- Beacons system of the wind turbine.
- Plans Main Components disposition in the nacelle.
- General Plan of the wind turbine.

5.2.3. Distribution of wind turbines in the plant

In Annex C.02.2 the Layout with the new distribution of the wind turbines is shown. The Wind Energy Plant will be constructed in a flat site with some gentle hills; the height above sea level varies between 210 and 265 meters. The wind turbines will be disposed perpendicularly to the predominant wind direction, sufficiently separated between them in a way to reach the optimization of the wind resource development.

With reference to the update location of the turbines, in Annex C.05.1 there is a Note on permission in surroundings of neighboring roads, emitted by the Town Hall of Tornquist (September 14th, 2018)

The structure of the opening of LAT (132 KV), the Transformer Station (MT/AT) and the 30 wind energy turbines will all be distributed within the three Rural Properties in the following way:

- Rural Property "Guanaco Chico".
Wind Turbines N°: 3, 4, 12, 13, 14, 15, 16, 17,18, 26 y 27.
- Rural Property "Reyrolles".
Opening of LAT in 132 KV.
Transformer Station (MT/AT)
Wind Turbines N°: 5, 6, 7, 19, 20, 21, 22, 28, 29 y 30.

 Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	
Doc. N°: CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date 15/08/2018 Rev: A Page 20 of 36

- Rural Property "San Bautista Sur" Wind Turbines

N°: 1, 2, 8, 9, 10, 11, 23, 24 y 25.

In Table N° 2 there is an account of the new location, dimensions of the place and the maximum height (a.s.n.m.) of the 30 wind turbines.

Table N° 2 Location, dimensions of the site and maximum height of the turbines.

N° of Wind Turbine	South Latit ude	West Longit ud	Dimensi on of the site	Max height of the wind turbine	a.s.n.m. (metres)
1.	38° 20' 35.68"	62° 12' 35.87"	240	186.	426.
2.	38° 20' 31.61"	62° 12' 20.22"	250	186.	436.
3.	38° 21' 26.05"	62° 15' 32.06"	211.5.	186.	397.5.
4.	38° 21' 26.05"	62° 15' 12.39"	240	186.	426.
5.	38° 21' 09.92"	62° 14' 20.73"	225.7.	186.	411.7.
6.	38° 21' 09.55"	62° 14' 04.17"	230	186.	416.
7.	38° 21' 08.21"	62° 13' 47.66"	258.7.	186.	444.7.
8.	38° 21' 08.32"	62° 13' 20.34"	244.1.	186.	430.1.
9.	38° 20' 53.77"	62° 12' 59.03"	260	186.	446.
10.	38° 21' 02.49"	62° 12' 37.47"	247.1.	186.	433.1.
11.	38° 21' 00.93"	62° 12' 18.87"	240	186.	426.
12.	38° 21' 53.51"	62° 16' 06.09"	214	186.	400.
13.	38° 21' 47.13"	62° 15' 51.73"	220	186.	406.
14.	38° 21' 47.93"	62° 15' 35.28"	235.2.	186.	421.2.
15.	38° 21' 46.59"	62° 15' 18.86"	210.6.	186.	396.6.
16.	38° 21' 45.29"	62° 15' 02.47"	206.5.	186.	392.5.
17.	38° 21' 43.32"	62° 14' 38.22"	217	186.	403.
18.	38° 21' 27.23"	62° 14' 53.67"	235.7.	186.	421.7.
19.	38° 21' 39.65"	62° 14' 13.66"	240	186.	426.
20.	38° 21' 38.31"	62° 13' 57.02"	240	186.	426.
21.	38° 21' 36.90"	62° 13' 39.61"	255.5.	186.	441.5.
22.	38° 21' 35.31"	62° 13' 20.01"	253.9.	186.	439.9.
23.	38° 21' 33.86"	62° 13' 02.06"	250	186.	436.
24.	38° 21' 32.45"	62° 12' 44.73"	250	186.	436.
25.	38° 21' 30.84"	62° 12' 27.65"	247	186.	433.
26.	38° 22' 15.33"	62° 15' 37.81"	220	186.	406.
27.	38° 22' 07.20"	62° 15' 08.75"	210	186.	396.
28.	38° 22' 06.19"	62° 13' 38.89"	250	186.	436.
29.	38° 22' 04.09"	62° 13' 15.05"	250	186.	436.
30.	38° 21' 55.80"	62° 12' 58.28"	255.9.	186.	441.9.

Geographic coordinates System of horizontal reference, WGS-84
 Elevation: System of upright reference, Above sea level MSL

Source: Energética Argentina S.A.

 Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	
Doc. N°: CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date 15/08/2018 Rev: A Page 21 of 36

5.2.4. Wind resource and energetic production

In Annex C.02.1, there is an updated document with the results of the measurement campaign and the estimated energetic production. It includes mainly:

- Measurement of wind resource Campaign.
- Evaluation of the wind resource.
- Evaluation of the energetic production.

5.2.5. Civil works and Infrastructure Facilities

Civil works and infrastructure facilities necessary for the materialization of the Wind Energy Park are:

- Roads and access routes.
- Mounting Platforms for the wind turbines.
- Foundations for the wind turbines.
- Collector Network (electric network, earthing system and communication links).

– Roads and access routes.

As indicated to EIA in the Addendum, the neighboring street corresponding to the Progressive km 40 of the National Route N° 33 will be the main access to the Project area; it is well preserved with firm land. It is approximately 20 meters' width, between wirings. A readjustment of approximately 5 km. is anticipated.

The adjustment will be re-compacted and outlined to receive the structural packet that ensures the bearing capacity and the geographical characteristics demanded by the provider and the assembly team.

The new configuration of the internal roads (between the wind turbines) will be an estimate 18.0Km long; 6,0 meters is the minimum width in order to permit the circulation of the main crane between them, without dismounting it. For its construction they must follow the guidelines indicated by the turbine manufacturer (see Annex N° C.02.2, "Document "Profile of internal roads").

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N°: CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date 15/08/2018 Rev: A Page 22 of 36</p>

– **Mounting Platforms**

In the wind turbine mounting platforms there will be distinguished the operative zones on one side and on the other the zones defined as stockpiling ones.

In the crane operative zones, the most important thing is to get the correct support for the main crane. Gravel will be used in case the area assigned to the platform were not able to balance the land profile to get the maxim slopes required.

Several turbine components will be located in the stockpiling zones to be raised by the cranes (main and auxiliary ones) from the platform.

The dimensions of the crane operative zone and the stockpiling zone of components for each turbine will be of approximately 3,680 m (including the foundation area); which shows a total surface area of approximately 11.0 hectares for the 30 machines.

For its construction they must follow the guidelines indicated by the turbine manufacturer (see Annex N° C.02.2, "Document "Mounting Platforms AW 132 TH 120").

– **Foundations for the wind turbines.**

The most important civil works for the Wind Energy Park correspond to the foundations of the turbines, whose concrete volume will be of 436 m³ for each foundation. This shows a total volume of approximately 13.080 m³ of structural concrete for the 30 machines. Although the dimensions are not major ones in relation to the area occupied by the park, the soil is a key element that will be much affected because of the significant movement of earth needed.

According to the supplier's specifications they contain approximately 33.2 tons of steel (per unit), which shows a total amount of 996 tons of steel.

Quantities will be adjusted when the calculation report is done according to requirements of soil studies and current applicable regulations.

Geometrical characteristics of the foundations:

- Base diameter: 18,80m.
- Shaft diameter: 8,16m.

- Total height of the base: 2,25m.
- Heel height: 0,50m.

Typical Plan of turbine bases with conductor stockpiling, Figure N° 12.




Figure N° 12 Typical Plan of wind turbine foundation.

For its construction they must follow the guidelines indicated by the turbine manufacturer (see Annex N° C.02.2, "Document "Foundations. Foundation type AW3000 TH120")

– **Collector Network (electric network, earthing system and communication links).**

The power generator is a three-phase asynchronous double-fed type, with reeling rotor and slip ring excitation. It contains 3 pairs of poles and a synchronous speed of 1000 rpm (50Hz) Turning speed of the rotor is variable and it adapts to wind speed. This is possible adapting rotor excitation to the angular speed of the rotor, so the power generates constant tension and frequency.

The generator is supported by a rear frame with four damper elements (Silent-Blocks), whose function is that of reducing the vibration extent and the noise.

The wind turbines will be connected to the collector network of the Wind Park at 33 KV level. For this it is necessary to include in each machine, a 12/33 KV -3400 KVA power transformer and protection cells and maneuver in half tension (33 KV). The power transformer will be that of the type submerged under biodegradable liquid, as a dielectric medium.

In Figure N° 13 there is a scheme to connect the power generator to the network. And in Figure N° 14, the configuration of the components in the base of the wind turbine.




Figure N° 13. Scheme to connect the generator to the network.




Figure N° 14 Configuration of the components in the base of the wind turbine.

Source: Energética Argentina S.A.

Accordingly, each generator contains an individual substation which includes:

- A 12/33 KV set-up transformer of 3.400 KVA nominal power.
- A set of 33 KV bars (see Figure N° 15) with transformer input cell and output cells to the collector network. The output to the collector network depend on the cell position in the wind farm (end of line, intermediate wind turbine, others).




Figure N° 15. Typical set-up of the cells in 33 KV.

The electric network of the Wind Energy Park will be underground type; it is in charge of collecting the energy produced by each wind turbine in the 33 KV level and take it to the Transformer Station (MT/AT), where it will be set up to a 132 KV level and delivered to the SADI. It will count with the corresponding systems of Control, Remote control, Measurement and Communication, etc., located in the building of the Operative Centre and Control of the Wind Energy Centre (see Figure N°16)




Figure N° 16 General Control System of the Wind Energy Plant.

Source: Energética Argentina S.A.

 Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	
Doc. N°: CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date 15/08/2018 Rev: A Page 26 of 36

It is anticipated the installation of five (5) collector circuits implemented through underground aluminum single-pole wires type XLPE in 33 KV (with nominal sections between the parts of: 120 mm², 150 mm², 185 mm², 240 mm², 300 mm², 400 mm², 500 mm² and 630 mm²), independently related to the Transformer Station (MT/AT). The circuits will be conformed in the following way:

- 1 circuit of 5 wind turbines.
5 units x 3.325 MW = 16.625 MW.
- 3 circuits of 6 wind turbines.
6 units x 3.325 MW = 19.95 MW.
- 1 circuit of 7 wind turbines.
7 units x 3.325 MW = 23.275 MW.
- Total Power: 1 x 16,625 MW + 3 x 19,95 MW + 1 x 23,275 MW = 99,75 MW.

The underground ducts cover a total of 22.0 Km long. The conductors will be installed in trenches of approximately 1.10 meters depth and a sufficient width to enable the adequate laying according to the typical underground mounting schemes of the collector network.




Figure N° 17 Google Image with the collector circuits implemented with underground wiring.

 Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	
Doc. N° CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date 15/08/2018 Rev: A Page 27 of 36

In Annex C.02.2, there is a single line diagram of the collector system in 33 KV and the detail of trenches and medium power typical ducts.

On the same sandy mantle and at the same level of the power wiring, also the earthing cable will be installed in bare copper wire of 50 mm², which will be bounded to the earthing system of each wind turbine and to the Transformer Station; and the optic fiber cables for the communication and control of the wind turbines.

On the sand filling there will be installed a mechanical protection (bricks, plastic plates, others). Then, the filling is completed and the rest of the trench is compressed with 30 centimeter depth of the signaling tape, warning about the presence of electrical wiring. Finally, endurance and insulation tests take place, along with continuity and sequence of phases, as well as dielectric rigidity.

 Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	
Doc. N° CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date 15/08/2018 Rev: A Page 28 of 36

6. Overview table of the Project

Summary Chart with technical data of the Project.

Overview of the Wind Energy Park.	
Affected countryside - total surface.	Three (3) portions of countryside -950 hectares.
Poles of Meteorological Stations	Two (2) 48m and 82m poles. Installed on February 9th and August 24th, 2012.
Total Power Installed:	99.75 MW.
Quantity of wind power turbines	30 units
Net energy production.	436.905 MW-h/Year.
Capacity Factor.	50,0%.
Internal Electricity Network of the P.E and connection to ET	12 KV a 33 KV.
- Transformation level of each wind energy turbine	33 KV.
- Tension level of the service network.	Radial.
- Configuration.	Underground
- Line type.	d.
- Transformers MT.	Relation: 12/33 KV. Nominal Power: 3.400 KVA.
Type.	Three-faced, submerged in biodegradable liquid.
Nominal Frequency.	50 Hz.
Connection Group.	Dyn11
Quantity	30 units
Location.	In the bottom part of the tower (concrete)
- Number of cells in MT (33 KV).	30 units with transformer inlet and output/s to the network. In the bottom part of the tower (concrete)
Location.	
- Number of circuits.	5(five) circuits in all.
Configuration of circuits	<ul style="list-style-type: none"> - 1 circuit of 5 wind turbines. 5 units x 3.325 MW = 16.625 MW. - 3 circuits of 6 wind turbines. 6 units x 3.325 MW = 19.95 MW. - 1 circuit of 7 wind turbines. 7 units x 3.325 MW = 23.275 MW. - Total Power: 99.75
Approximate length of access road (to readapt).	5.0 Km.
Approximate length of internal roads (to construct).	18,0 Km, of 6,0 meters useful width
Foundation Platforms (including the foundation of the wind turbine).	
- Approximate Individual Surface.	3.680 m ² .
- Approximate Total Surface.	110.400 m ² (11,0 hectares).

Technical Specifications of the Wind	
Trademark- Model	Nordex-Acciona -AW132/3300 TH120, class IEC IIB.
Wind Turbine Power.	3.325 MW.
Hub Height	120 meters
Lowest Speed Limit of Operation.	3,0 m/sec
Highest Speed Limit of Operation.	25 m/sec
Power Generator.	
Type.	Asynchronous, 6 poles, double-fed.
Nominal Power:	3,390 KW.
Nominal Frequency.	50 Hz.
Speed System.	680 -1,365 rpm
Nominal Power.	12,000 V.
Power Factor.	0.93.
Protection System.	PDI 54.
Gearbox.	It is composed of 3 combined stages, two planetary and a parallel one.
Pitch system.	It enables to vary the holding torque of each blade, when turning in its longitudinal axis. The system has two objectives: <ul style="list-style-type: none"> – Regulate the power generated by high winds. – Aerodynamic Brake in case of controlled or emergency shutdown.
Tower.	
Type.	Tubular, of concrete (six sections). 118
Length.	meters
Tower Access.	Gate, with lock.
Superficial treatment - Color.	Painted - RAL 7035 (light grey).
Nacelle.	
Approximate dimensions. Material	4,089 (width) x 4,270 (height) x 15,973 (long) meters.
/ liquid containment.	The cover protection of the nacelle will be of glass-fiber reinforced polyester. The bottom part has the form of a bath tub, so any liquid substance that is spilt in the interior, will pass to a retention system.
Color.	RAL 7035 (light grey).
Rotor	
Number of blades.	3 units
Diameter.	132 meters
Rotation speed of operation.	Variable. 7.0/14.0 rpm 13.720 m ² .

 Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	
Doc. N° CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date 15/08/2018 Rev: A Page 30 of 36

Hub Material / protection	Cast iron /Epoxy. The nose cone protects the hub from adverse weather conditions. It's manufactured with glass-fiber reinforced polyester.
Blades Material. Length. Approx. weight Color.	Glass-fiber reinforced polyester, with a soft outer plate to protect the materials from UV radiation. 64.7 meters 16,400 tones+/- 3% (unit). RAL 7035 (light grey).
Foundations. Main Characteristics. <ul style="list-style-type: none"> - Volume of concrete (per unit) - Volume of concrete (total) - Quantity of steal (per unit) - Quantity of steal (total) 	Round-section pads of 18.8 meters of diameter. The preparatory level suggested by soil studies will be 2.250 meters under the natural level of the ground. The bottom part will have a cylindrical section, then tapered to finish in a cylindrical pedestal of approximately 8.16 meters diameter over which the turbine tower base will be anchored. 436 m ³ . 13.080 m ³ . 33,2 tones. 996 tones.
Noise level.	108,5 dB(A).
Service life (indicated by manufacturers).	20 years.

7. Preparatory Stage of the site and construction

7.1. Workroom

So stated in the Original Project there will be a workroom which will be located in the same building. That is to say, in the access way to the Rural Property of "Reyrolles" (see Figure N° 18), in the geographical coordinates: 38°21'41.09" South, 62°14'22.50" West.

At present the site already counts with electric energy coming from an air Transformer Station 13,2/0,4-0,231 KV of 63 KVA; in case or need it is anticipated the installation of an additional generating set catered by diesel fuel. Besides, the site has one drilling and a submersible pump for water withdrawal.




Figure N° 18 Google Image with the location of the general workroom and prep Layout.

Source: Energética Argentina S.A.

 Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	
Doc. N° CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date 15/08/2018 Rev: A Page 32 of 36

The workroom will have a total surface of approximately 1.10 hectares and will provide the following areas:

- A guard's hut.
- Trailer for office Energética Argentina S.A.
- Trailer for office Civil Work Contractor.
- Trailer for office Electromechanical Work Contractor.
- Trailer for office Founding Work Contractor.
- Trailer for infirmary and first aids.
- Restrooms (chemical toilets) and changing room.
- Distribution and storage of water.
- Infirmary.
- Laboratory.
- Canteen.
- Warehouses, storehouses and lockers.
- Specific storehouse for dangerous and/or chemical substances, and others.
- Open stockpiling Zone.
- Waste Management Area
- Decanting pool, to wash the elements that have been in contact with the concrete.
- Parking space for vehicles.
- Perimeter fencing, safety fencing, work safety posters and signals, others.

7.2. Services

So said by Energética Argentina S.A., the Contractor will dispose of the following services in the work:

- Surveillance.
- Employee transport.
- Catering.
- Infirmary and first aids.

 Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	
Doc. N° CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date 15/08/2018 Rev: A Page 33 of 36

7.3. Machinery and equipment required for the construction

The machinery and equipment required for the construction site will be similar to those indicated in previous environmental studies. According to the promoter of the Project they will need:

Heavy equipment /transport:

- Caterpillars or crawler excavators.
- Bulldozer.
- Articulated off-road dump truck
- Packer roller.
- Motor grader.
- Trencher.
- Backhoe loader.
- Loader.
- Bobcat.
- Main and secondary cranes.
- Transport trucks.
- Dump truck.
- Hydro crane truck.
- Tanker.
- Mixer truck.
- Concrete pump truck.
- Employee transport.
- Auxiliary pickups.

Light equipment and/or tools:

- Diesel fuel or gasoline generators
- Compressor.
- Lightning Tower.
- Extraction pumps.
- Gasoline and electrical vibrator.

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date 15/08/2018 Rev: A Page 34 of 36</p>

- Gasoline and electrical concrete mixers.
- Concrete pump.
- Vibratory plates.
- Welding equipment.
- Electric welder.
- Angle grinder.
- Electric circular saw.
- Electrical tables and extensions.
- Ceramic cutting machine.
- Vibratory Rule.
- Electric or jackhammer.
- Ladders.
- Hand tools.
- Slings and hoisting elements.
- Wiring and tightening wire machines.
- Multiple tools.

Observation: So said by Energética Argentina S.A. there is no anticipation of installing a concrete plant in the Wind Energy Center site. The concrete elaborated will be bought to third parties and transported to the site through mixer trucks of 6/8 m³ of capacity.

7.4. Staff involved in the Project

The staff required for different works will be approximately 172 people, employed directly, with different professional knowledge and skills needed for these types of activities.

In this respect it is important to emphasize that Nordex-Acciona, providers of the wind turbines, has anticipated the installation of a Plant for manufacturing concrete towers, in the industrial area of the city of Bahía Blanca. This will benefit the providers of products and services already in the area, as well as the hiring of local manpower.

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date 15/08/2018 Rev: A Page 35 of 36</p>

8. Operative Stage and Maintenance

8.1. Electric Energy Transport System

The operation and maintenance of the Transport System will be under the charge of the Network Transport and the Operator in the Wind Energy Centre according to the boundary limits already established. Particular conditions of operation will be set up in due course, prior to the entering of the energetic venture service.

8.2. Wind Farm

The operation will meet the requirements established by CAMMESA for the deliverance of Centers, and the proper characteristics of the operation in the Wind Energy Park, classified as type A according to a Study of Access for Transport Capacity. The study was performed by Energética Argentina S.A. in total agreement with Annex 40 of the Procedures by CAMMESA.

For the operation the Wind Energy Center will dispose of a Control Center which will meet all the requirements specified in Annexes 24 and 25 of the Procedures by CAMMESA, so it will provide a System of Operation in real time or SOTR and System of Communication or SCOM, in answer to the requirements of the operation in real time by SADI.

According to the data informed by the wind turbine manufacturer, there will be seven (different) types of maintenance in each wind energy unit with the following regularity: a) every six months; b) annual; c) biennial; d) triennial; e) every four years; f) every five years and g) every ten years.

8.2.1. Staff involved in the Project (O&M)

During the operation and maintenance stage of the Wind Energy Park, it is anticipated the direct contracting of 10 people.

9. Work Schedule

In Annex C.002.4, the Work Schedule is provided for the work development and other activities associated to the preparation stage and construction.

10. Estimated total funding cost

The estimated total cost of the work will be of U\$S 119.000.000 (VAT not included)

 Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	
Doc. N° CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date 15/08/2018 Rev: A Page 36 of 36

Bridging the Energetic Wind Center to the SADI: It includes supply and mounting of: - Transformer Station (MT/AT) - Opening of Aerial Power Line in 132 KV and bond to ET.	US\$ 17.500.000 (VAT not included)
Supply and mounting of: - 30 wind energy turbines (complete). - Roads, platforms, foundations and drainage works. - Underground Collector Network in 33 KV, earthing system and communication links.	US\$ 101.500.000 (VAT not included)

11. Annex C.02

- C.2.1 Study of Evaluation Tool for the Wind Resource and Power Generation
- C.2.2 Building Plans
- C.2.3 Technical Specifications of the Wind Turbines
- C.2.4 Schedule of the Planned Preparations for Project Development

Annex C.02.1

Study of Evaluation Tool for the Wind Resource and Power Generation

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date 15/08/2018 Rev: A Page 2 of 7</p>

Study of Evaluation Tool for the Wind Resource and Power Generation

Index

1.	INTRODUCTION	3
2.	Evaluation of the wind resource.	3
2.1.	Characteristics of the Poles and Meteorological Stations.....	3
2.2.	Measurement of wind resource Campaign.....	4
2.3.	Characteristics of the wind resource.....	5
3.	Evaluation of the energetic production.	5

Study of Evaluation Tool for the Wind Resource and Power Generation

1. INTRODUCTION

The present document provides a brief evaluation of the wind resource and the estimation of the energetic production of the Wind Energy Center 1, targeted to obtain results on the application in the Addendum N° 2 to the Environmental Impact Study of the Project.

2. Evaluation of the wind resource.

2.1. Characteristics of the Poles and Meteorological Stations.

The energetic venture provides two pole with their correspondent meteorological stations. The location of these devices is shown in the following figure (see sites with Tres Picos 1 and 2)




Figure N° 1 Image with the location of two poles and meteorological stations.

Source: EIA Original, Icono srl (09/02/2012).

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date 15/08/2018 Rev: A Page 4 of 7</p>

2.2. Measurement of wind resource Campaign.

The Project provides a data report over eight years of "in situ" measurements, which represents a very significant period to cover the analysis of energetic production of the Wind Energy Center. Down below the characteristic data of the poles and sensors installed in the site are shown.

- Pole N° 1, called "Tres Picos 1": It is located in the coordinates Lat: - 38.356567°, Long: - 62.227633°; size 48m and its approximate elevation is of 263 meters above sea level. There are data reports since 09/02/2010.

There is a wind speed at two levels (48 m and 30 m), the direction at one level (46.5 m) and the pressure and temperature at 2.5 m.

- Pole N° 2, called "Tres Picos 2": It is located in the coordinates Lat: 38.3487°, Long: -62.212133°; size 82m and its approximate elevation is of 244 meters above sea level. There are data reports since 24/08/2010.

There is a wind speed at five levels (82 m. 80 m. 60 m, 48 m and 40m), the direction at three levels (80m, 58.5 m and 38.5 m) and temperature at 7.0 m.



Figure N° 2 Photographs of the two poles and equipment installed in the site.

Source: Own.

2.3. Characteristics of the wind resource.

Through continuous report of the meteorological variables "in situ" and its subsequent processing, the following results were registered in respect to the prevailing direction of the wind, its frequency, energy and speed distribution at the top of pole N° 2 (see Figure N° 3)




Figure N° 3 Compass cards (frequency, energy, speed) and distribution of frequencies.

Source: Energética Argentina S.A.

3. Evaluation of the energetic production.

From the point of view strictly energetic the production of electric energy from the wind only produces positive environmental impact. The objective followed in this report is to prepare an estimation of the electric generation of the Wind Energy Park in order to evaluate the environmental aspects, leaving behind the thorough determination of energy production.

In Figure N° 4 there is a Layout of the Wind Energy Center with the location of the pole and the wind energy turbines, with the new configuration of the Wind Energy Park. With the new configuration of the Wind Plant the furthest wind turbine (N° 12) will be located approximately 5.2 km from the meteorological station (Tres Picos 2).




Figure N° 4 Wind Energy Center Layout

Source: Energética Argentina S.A.

The Wind Energy Center will be conformed of 30 wind energy turbines Nordex-Acciona AW 132/3300 TH 120, class JEC2B. In Figure N° 5 there is the generator power curve, from which the estimated annual production of the electric energy in the Wind Energy Center is determined.

Wind Speed (m/s)	Dynamic Power (kW)	Wind Speed (m/s)	Dynamic Power (kW)
3.0	31	14.0	3325
3.5	89	14.5	3325
4.0	177	15.0	3325
4.5	280	15.5	3325
5.0	405	16.0	3325
5.5	560	16.5	3325
6.0	743	17.0	3325
6.5	963	17.5	3325
7.0	1219	18.0	3325
7.5	1515	18.5	3325
8.0	1844	19.0	3325
8.5	2202	19.5	3325
9.0	2571	20.0	3325
9.5	2903	20.5	3325
10.0	3159	21.0	3325
10.5	3280	21.5	3325
11.0	3310	22.0	3325
11.5	3325	22.5	3325
12.0	3325	23.0	3325
12.5	3325	23.5	3325
13.0	3325	24.0	3325
13.5	3325	24.5	3325
		25.0	3325



Figure N° 5 Power Curve of the Wind Energy Turbine Nordex-Acciona, model AW132/3300 TH120 IEC2B.

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	Study on Environmental Awareness Addendum N°	
<p>Doc. N° CEEN-IA-2655-08/18</p>	2 Wind Power Centre 1	<p>Date 15/08/2018 Rev: A Page 7 of 7</p>

Down below in Table N° 1 there are the data provided by Energética Argentina S.A. with reference to the estimated productions of the Wind Energy Center, the resultative capacity factor and equivalent hours.

Table N° 1

Wind Power Centre 1		
Net Energetic Production (MW-h/YEAR)	Capacity Factor (%).	Equivalent hours (Hs/Year)
436,905	50.0.	4,369.0.

Annex C.02.2

Plans

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	Study on Environmental Awareness Addendum N°	
Doc. N° CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date 15/08/2018 Rev: A

Plans

1. INTRODUCTION

This Annex contains the plans corresponding to the Addendum N° 2 at the Environmental Impact Study of the Wind Energy Center.

Document N° Description

----- Wind Energy Center Layout (13/09/2018)

PEEN-EM-001-H1 Transformer Station General Plant

PEEN-EE-001-H1 Transformer Station Single line Schematic 132 KV.

PEEN-EE-001-H2 Transformer Station Single line Schematic 33 KV. - TRANSBA

PEEN-EE-001-H3 Transformer Station Single line Schematic 33 KV. - Wind

Energy Plant


----- Single line Diagram in 33 KV

DG200522 Foundations Foundation type AW3000 TH120

----- Trenches - Plan of cable type sections

----- Profile type of internal roads.

-----Mounting Platforms AW 132 TH120.



Legend

-  AW 3300 TH120.
-  Access Road
-  Internal Access Road to SET
-  Site
-  Compound

Substation


Coordinate system.

UTM, WGS84 DATUM, ZONE 20 SOUTH

R. No.	Description
1.	Emission

Company  	Project Title 3 Picos Wind Farm	Author Raquel Cabeza	Created 13/09/2018	Range	Designation AW132 3.3 MW TH120	Nº of Plan	Revisión
				Format A3		Page	

No se permite la explotación económica ni el uso de este documento, Copia, uso o distribución sin el consentimiento escrito de NordeX, queda expresamente prohibido.



ESIN CONSULTORA S.A.

Obra:
 PROYECTO: PARQUE EÓLICO ENERGÉTICA I

TÍTULO: PLANTA GENERAL

HOJA 1 DE 1

DOCUMENTO: PEEN-EM-001

ESC: S/E

REV. 0

DOCUMENTO N°:

D

C

B

A

CAMPO 00
ACOPLAMIENTO + MEDICIÓN DE TENSIÓN Y P.A.T. DE BARRAS

CAMPO 01
TRAFO T1 132/33 kV

CAMPO 02
LAT 132 kV A ET BAHIA BLANCA

CAMPO 03
LAT 132 kV A ET TORNUQUIST


CAMPO 04
TRANSFORMADOR SS.AA.

CAMPO 05
TRANSFORMADOR T2 132 kV/BT
(FUTURO)

2

2

1



NOTA:

- 1 - EL SISTEMA DE PROTECCIONES Y CONTROL SE DEBE FUNDAMENTAR EN UN SISTEMA SAS (SUBSTATION AUTOMATION SYSTEM), BASADO EN LA NORMA IEC 61850.
- 2 - EN EL CAMPO DEL TRANSFORMADOR DE POTENCIA SE INSTALARÁN 2 TABLEROS DE PROTECCIÓN:
 - PARA CONTROL Y PROTECCIÓN DEL CAMPO
 - PARA CONTROL DE LA MAQUINA INCLUYENDO EL RAT, INDICADORES DE IMAGEN TÉRMICA, BOTONERAS SUBE Y BAJA DEL TAP, INDICADOR DE POSICIÓN DEL TAP, COMANDO VENTILADORES, ETC.

ESIN CONSULTORA S.A.

Obra:
PROYECTO: PARQUE EÓLICO ENERGÉTICA I

TITULO: ESQUEMA UNIFILAR 132 kV

HOJA 1 DE 3


DOCUMENTO: PEEN-EE-001

ESC: S/E


REV. 0

DOCUMENTO N°:

(CELDAS 33 kV LADO PLAYA – TRANSBA)



CELLS33 kV - ENERGETIC I




ESIN CONSULTORA S.A.

Obra:
PROYECTO: PARQUE EÓLICO ENERGÉTICA I

TITULO: ESQUEMA UNIFILAR 33 kV - PARQUE EÓLICO
HOJA 3 DE 3 DOCUMENTO: PEEN-EE-001 ESC: S/E REV. 0

DOCUMENTO N°:



Todos los derechos reservados.
 Este documento, sus datos, su contenido,
 o el contenido total o parcial, no
 debe ser reproducido, almacenado en un sistema de recuperación,
 ni transmitido en ninguna forma o por cualquier medio, electrónico o mecánico, incluyendo fotocopias, grabaciones o cualquier otro método de información.



Título del proyecto
 23456789:56;=<= 8>?6@A3B

Autor
 7C

Creado
 DEFGHE


Escala
 Formato
 A3

Designación
 JJKL6M:~90:36734N8B>A3P

N° de Plano
 Hoja

R. No.	Descripción
0	Emisión
Revisión	

AW3000 300 Kpa









NOT VALID
FOR CONSTRUCTION

LAS CANTIDADES Y TIPOS DE COMPONENTES DE LAS IMÁGENES MOSTRADAS PUEDEN VARIAR EN FUNCIÓN DEL MODELO DE AEROGENERADOR
 QUANTITY AND TYPE OF COMPONENTS MAY CHANGE DEPENDING ON WIND TURBINE MODEL

B	01-06-15	MGB	NUEVA DISTRIBUCIÓN SOLERAS DE PREMONTAJE CAMBIO DENOMINACIÓN PLANO NEW DISTRIBUTION PRE-ASSEMBLY SLABS. CHANGE DRAWING NAME
A	23-12-14	MGB	CREACIÓN DEL PLANO / DRAWING CREATE
REV / REV	FECHA / DATE	REALIZADO / CREATED	MODIFICACION / MODIFICATION
MATERIAL / MATERIAL		TOLERANCIAS GENERALES / GENERAL TOLERANCES	
		PESO / WEIGHT (kg)	
NOMBRE / NAME	DIBUJADO / DRAWN	COMPROBADO / REVISED	APROBADO / APPROVED
FECHA / DATE	01-06-2015	01-06-2015	01-06-2015
ESCALA / SCALE	DENOMINACIÓN		
1/100	EJEMPLO CIMENTACIÓN AW3000 TH120 MACIZA		
	NAME		
	FOUNDATION EXAMPLE AW3000 TH120 SOLID		
PLANO N° / DRAWING N°		REVISIÓN / REVIEW	
DG200522		B	
HOJA N° / SHEET N°			
		3-5	
FORMATO / FORMAT		A3	

Este plano es propiedad exclusiva de **acciona windpower** y su reproducción total o parcial está totalmente prohibida y queda amparada bajo la legislación vigente. Los contraventores serán perseguidos legalmente tanto en España como en el extranjero. El uso, copia o venta de esta publicación, solo podrá realizarse con autorización expresa y por escrito de **acciona windpower**.
 This drawing is the exclusive property of **acciona windpower** and is covered by current legislation. Full or partial reproduction is prohibited. Anyone who does so will be prosecuted, whether in Spain or abroad. This publication may be used, copied or sold only with the express written authorization of **acciona windpower**.

CABLE TRENCH SECTIONS



NOT VALID FOR CONSTRUCTION


*TECHNICAL CONSIDERATIONS			
ROAD CROSSINGS WILL BE PERPENDICULAR IF POSSIBLE			
TRENCHES WILL BE PARALLEL TO WIND FARM INTERNAL ROADS			
THE DEPTH BETWEEN SURFACE AND THE BOTTOM PART OF THE CABLES WILL NOT BE LESS THAN 0,80 M. IN CASE OF CROSSING THIS DISTANCE WILL NOT BE LESS THAN 1 M.			
COMPACTATION OF SELECTED MATERIAL	95% OF MODIFIED PROCTOR TEST (AASHTO T180)		
Date	R. No.	Description	R.Date
Date	*NOTE		
FOR DISTANCES HIGHER THAN 20 CM NO PROTECTION IS			

Company	Project title CABLE TRENCH SECTIONS	Drawing title Leon Nel	Drawing No.	Scale	Coordinate system	Designed
			Sheet	Format		Approved

Nondek reserves all rights to this document. Copying, use or distribution without explicit permission from Nondek strictly prohibited.



NEEDED.



TECHNICAL DATA	
MINIMUM CBR IN PLATFORM	20%
COMPACTION OF FIRM	98% OF MODIFIED PROCTOR TEST (AASHTO T180) IN BASE
	95% OF MODIFIED PROCTOR TEST (AASHTO T180) IN SUBBASE
DESIGN REFERENCE WEIGHT FOR TRANSPORT VEHICLE AXLE	12 TON
*NOTE	
BOTH CUT AND FILL SLOPE WOULD CHANGE DEPENDING ON THE FINAL SOIL CONDITIONS.	

NOT VALID FOR CONSTRUCTION

Annex C.02.3

Technical Specifications of the Wind Turbines

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date 15/08/2018 Rev: A</p>

Technical Specifications of the Wind Turbines

1. INTRODUCTION

This Annex contains the main technical specifications of wind energy turbine selected for the Project.

2. Technical Specifications of the Wind Turbines

These documents were provided by Energética Argentina S.A.

- Technical specifications of the wind turbine.
- Power curve.
- Acoustic emission of the wind turbine.
- Beacons system of the wind turbine.
- Plans Main Components disposition in the nacelle.
- General Plan of the wind turbine.



- Rev	Date	Description of the revision
"A"	31/10/17	Elaboration
"B"		
"C"		
"D"		
"E"		

<p style="text-align: center;"><i>Performed</i></p> <div style="text-align: center;">  31 -10 - </div>	<p style="text-align: center;"><i>Reviewed</i></p> <div style="text-align: center;">  31 -10 </div>	<p style="text-align: center;"><i>Approved</i></p> <div style="text-align: center;">  31 -10 -2017 </div>
--	---	---

	TECHNICAL SPECIFICATION	DATE: 31/10/17
	AW 132/3300 IEC IIB TH120 WIND TURBINE	Revision : A
		AUTHOR: EGM
		CHECKED: JAL
		APPROVED: MNP

ROTOR	Number of blades	3
	Orientation	Upwind
	Diameter	132 m
	Swept area	13 720 m ²
	Rotational direction	Clockwise
	Rotational speed	Variable - 7 ... 14 rpm
	Hub height	120 m
	Power regulation	Full span blade pitch
	Over speed control	Full span blade pitch
	Rotor shaft tilt angle	5°
	Nominal tip speed	85.5 m
Cone angle	5°	
BLADES	Material.	GRE
	Total length	64.7 m
	Weight range	16400 kg ± 3% / blade
	Pitch	Full span
	Aerodynamic Brake	Full feathering
HUB	Hub type	Cast iron
	Protection	Epoxy
PITCH SYSTEM	Pitch bearings	Double row four point contact bearing
	Actuation	Hydraulic
	Linkage	Through hydraulic cylinders
	Failsafes	Accumulators on hub
DRIVE TRAIN	Gearbox	3 stages, 2 planetary / 1 parallel
	Gearbox nominal power	3630 kW.
	Gearbox ratio	1:97 (50 Hz) / 1:117 (60 Hz)
	Input speed	Variable - 7 ... 14 rpm
	Output speed	Variable - 680 ... 1365 rpm (50 Hz) Variable - 816 ... 1638 rpm (60 Hz)
	Lubrication	Pressure and splash with oil cooler / oil filter
ROTOR SHAFT	Type	Forged hollow shaft
	Supporting	2 bearings
DRIVETRAIN BEARINGS	Type	Double spherical roller bearings
PARKING BRAKE	Type	Single disk
	Location	High speed shaft
YAW SYSTEM	Type	Double row four point contact bearing
	Slewing gear	external
	Slewing gear / yaw drive pinion ratio	11,2 1
	Braking system	Hydraulic Calipers
	Yaw drives system	Electrical motor gears

TECHNICAL SPECIFICATIONS

YAW GEARS AND MOTORS	Type	Planetary 4-5 stages
	Ratio	1:1430
	Yaw rate	0.09 rpm @ 50 Hz / 0.11 rpm @ 60 Hz
	Motor types	Asynchronous 4 poles
	Voltage / Frequency	230/400 V - 50-60 Hz.
	Power rating / Motor speed	3 kW / 1450 rpm @ 50 Hz 3.5 kW / 1740 rpm @ 60 Hz
HYDRAULIC POWER UNIT	Oil pump capacity	90 l/min
	Motor types	37 kW.
	Voltage / Frequency	380 V / 50-60 Hz
	Blade accumulator	2 x 20 l
	Principal accumulator	20 l
GENERATOR	Type	6 poles, double feeding
	Insulation Classes (stator/rotor)	F / H
	Rated Power	3390 kW.
	Degree of protection	PDI 54.
	Frequency	50/-60 Hz.
	Voltage	12000 V.
	Power factor (short-circuited rotor)	0.93
	Speed range	680 ... 1365 rpm (50 Hz) 816 ... 1638 rpm (60 Hz)
CONTROL SYSTEM	Power control	Converter Control Unit
	Master processor	Programmable Logical Controller
	Interface	Scada
	Power factor correction	Programmable by software
TOWER	Type	Tubular concrete
	Tower height	118 m
	Material.	Post-tensioned pre-casted concrete
	Access to the tower	Door with lock system
	Access to nacelle cabin	Ladder or elevator
OPERATING DATA	Cut-in wind speed	3 m/s
	Cut-out wind speed	25 m/s
	Nominal power	3300 kW.
	Operation temperature range	-10°C to +40°C
	Survival temperature range	-20°C to +50°C

	Mechanical Engineering Report	Doc. EI797
		Rev.: "C"
POWER CURVE FOR TRES PICOS WIND FARM AW132/3300		P. 1 / 5

POWER CURVE FOR TRES PICOS WIND FARM AW132/3300

- Rev	Date	Description of the revision
A	18/12/2017	First issue
"	24/10/2018	Power enhancement
"	25/10/2018	Grid frequency correction
"		
E		

Performed  aruiz9 2018.10.2 5 09:28:33	Reviewed  jaristegui 2018.10.25 3:45:00 PM +02'00'	Approved  Núñez Polo, Miguel 2018.10.25 15:46:36 +02'00'
---	---	---

In case of doubt, the Spanish version shall prevail.

© 2018 Nordex Energy Spain, S.A.U. Todos los derechos reservados. This document contains information property of Nordex Energy Spain and it cannot be copied, published or revealed to third parties without the written consent of the company Nordex Energy Spain. The information in the present document must be kept secret and only used in benefit of Nordex Energy Spain.

© 2018 Nordex Energy Spain, S.A.U. All rights reserved. This document contains information that is the proprietary property of Nordex Energy Spain (the "company") and may not be copied, published or disclosed to others, without the express written consent of an authorized officer of the company. All information contained herein shall be held in strict confidence and in trust for the sole and exclusive benefit of the company

	Mechanical Engineering Report	Doc. EI797
		Rev.: "C"
POWER CURVE FOR TRES PICOS WIND FARM AW132/3300		P. 2 / 5

1 INTRODUCTION

This document shows the calculated dynamic power curve for the AW132/3300 wind turbine with the following characteristics.

- Ø rotor: 132 m
- Blade: AW64.7/-2
- 50 Hz grid

This power curve is an enhanced power mode for the AW132/3300 wind turbine.

2 DYNAMIC POWER CURVE

This power curve for the AW132/3300 AW64.7-2 is valid for these conditions:

- Undisturbed flux with turbulence intensity inside the range: Lower limit: 6%
Upper limit: $11 \cdot (0.75 \cdot V_{hh} + 5.6) / V_{hh} \%$
- Inflow angle inside a range between -10 deg and 5 deg. Positive values correspond to upward flow.
- Wind shear inside a range between 0 and 0.4
- Undamaged and clean blades
- Grid voltage inside +/-5% of nominal value
- Temperature inside a range between -20°C and +35°C
- Air density equal to 1.18 kg/m³

Wind speeds considered are 10-min averages at hub height.

Power curve test should be performed with generation of reactive power and wind farm algorithms deactivated.

Calculated power corresponds to 12 kV turbine terminals.

The power curve measurement will be done according to IEC-61400-12-1 guideline and MEASNET recommendations.

Thrust coefficients are provided only for informative purpose.

In case of doubt, the Spanish version shall prevail.

© 2018 Nordex Energy Spain, S.A.U. All rights reserved. This document contains information property of Nordex Energy Spain and it cannot be copied, published or revealed to third parties without the written consent of the company Nordex Energy Spain. The information in the present document must be kept secret and only used in benefit of Nordex Energy Spain.

© 2018 Nordex Energy Spain, S.A.U. All rights reserved. This document contains information that is the proprietary property of Nordex Energy Spain (the "company") and may not be copied, published or disclosed to others, without the express written consent of an authorized officer of the company. All information contained herein shall be held in strict confidence and in trust for the sole and exclusive benefit of the company

	Mechanical Engineering Report	Doc. EI797
		Rev.: "C"
POWER CURVE FOR TRES PICOS WIND FARM AW132/3300		P. 3 / 5

Electrical capabilities of AW132/3300 have been defined to be fulfilled for a maximum ambient temperature of 35°C and an installation below 1000 m.a.s.l. As because electrical capabilities are based on a relation between active power, reactive power, voltage range and temperature; the necessary derating to operate above 35°C of ambient temperature could be obtained by derating the active power or the reactive power.

If the rated reactive power capability of $\pm 1200\text{kVAr}$ is required, the active power of 3300kW can be delivered between -20°C and 35°C. Rated active power at 40°C will be 3150kW in these conditions. Linear interpolation for rated active power calculation between 3300kW at 35°C and 3150kW at 40°C can be considered for intermediate temperature values.

If the rated reactive power capability is not required, the active power of 3300kW can be delivered inside temperature range between -20°C and 40°C. Rated reactive power until 35°C will be $\pm 1200\text{kVAr}$ and at 40°C will be $\pm 355\text{kVAr}$. Linear interpolation for rated active power calculation between 3300kW at 35°C and 3150kW at 40°C can be considered for intermediate temperature values.

In case of doubt, the Spanish version shall prevail.

© 2018 Nordex Energy Spain, S.A.U. All rights reserved This document contains information property of Nordex Energy Spain and it cannot be copied, published or revealed to third parties without the written consent of the company Nordex Energy Spain. The information in the present document must be kept secret and only used in benefit of Nordex Energy Spain.

© 2018 Nordex Energy Spain, S.A.U. All rights reserved. This document contains information that is the proprietary property of Nordex Energy Spain (the "company") and may not be copied, published or disclosed to others, without the express written consent of an authorized officer of the company. All information contained herein shall be held in strict confidence and in trust for the sole and exclusive benefit of the company

Wind Speed (m/s)	Dynamic Power (kW)
3.0	31
3.5	89
4.0	177
4.5	280
5.0	405
5.5	560
6.0	743
6.5	963
7.0	1219
7.5	1515
8.0	1844
8.5	2202
9.0	2571
9.5	2903
10.0	3159
10.5	3280
11.0	3310
11.5	3325
12.0	3325
12.5	3325
13.0	3325
13.5	3325
14.0	3325
14.5	3325
15.0	3325
15.5	3325
16.0	3325
16.5	3325
17.0	3325
17.5	3325
18.0	3325
18.5	3325
19.0	3325
19.5	3325
20.0	3325
20.5	3325
21.0	3325
21.5	3325
22.0	3325
22.5	3325
23.0	3325
23.5	3325
24.0	3325
24.5	3325
25.0	3325

Table N° 1 Theoretical dynamic power curve

In case of doubt, the Spanish version shall prevail.

© 2018 Nordex Energy Spain, S.A.U. All rights reserved. This document contains information property of Nordex Energy Spain and it cannot be copied, published or revealed to third parties without the written consent of the company Nordex Energy Spain. The information in the present document must be kept secret and only used in benefit of Nordex Energy Spain.

© 2018 Nordex Energy Spain, S.A.U. All rights reserved. This document contains information that is the proprietary property of Nordex Energy Spain (the "company") and may not be copied, published or disclosed to others, without the express written consent of an authorized officer of the company. All information contained herein shall be held in strict confidence and in trust for the sole and exclusive benefit of the company

Wind Speed (m/s)	Thrust coefficient
3.0	0.9647
3.5	0.9350
4.0	0.9048
4.5	0.8647
5.0	0.8468
5.5	0.8396
6.0	0.8332
6.5	0.8219
7.0	0.8024
7.5	0.7775
8.0	0.7471
8.5	0.7075
9.0	0.6479
9.5	0.5817
10.0	0.5260
10.5	0.4715
11.0	0.4036
11.5	0.3506
12.0	0.3050
12.5	0.2663
13.0	0.2344
13.5	0.2090
14.0	0.1868
14.5	0.1676
15.0	0.1511
15.5	0.1372
16.0	0.1248
16.5	0.1141
17.0	0.1044
17.5	0.0961
18.0	0.0887
18.5	0.0824
19.0	0.0763
19.5	0.0709
20.0	0.0659
20.5	0.0617
21.0	0.0576
21.5	0.0542
22.0	0.0506
22.5	0.0478
23.0	0.0449
23.5	0.0424
24.0	0.0402
24.5	0.0382
25.0	0.0362

Table N° 2 Thrust coefficient

In case of doubt, the Spanish version shall prevail.

© 2018 Nordex Energy Spain, S.A.U. All rights reserved. This document contains information property of Nordex Energy Spain and it cannot be copied, published or revealed to third parties without the written consent of the company Nordex Energy Spain. The information in the present document must be kept secret and only used in benefit of Nordex Energy Spain.

© 2018 Nordex Energy Spain, S.A.U. All rights reserved. This document contains information that is the proprietary property of Nordex Energy Spain (the "company") and may not be copied, published or disclosed to others, without the express written consent of an authorized officer of the company. All information contained herein shall be held in strict confidence and in trust for the sole and exclusive benefit of the company



- Rev	Date	Description of the revision			
A	05/07/17	Initial release			
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: center; vertical-align: bottom;">  05 -07 - </td> <td style="text-align: center; vertical-align: bottom;">  05 -07 </td> <td style="text-align: center; vertical-align: bottom;">  05 -07 -2017 </td> </tr> </table>			 05 -07 -	 05 -07	 05 -07 -2017
 05 -07 -	 05 -07	 05 -07 -2017			

1. Introduction

The levels of Estimated Sound Power (L_{wa}) are shown for turbine AW132/3300.

These values of sound power are valid only under these conditions:

- Network tension under +2.5% of the nominal value.
- Generation of reactive power and control algorithms of the park, deactivated.
- Temperature within the range of -20°C and +40°C
- Without icing conditions, that is, temperature higher than +5°C and relative humidity under 80%
- Nacelle gates and tower base closed for the measured turbine as well as all the others which are at sight.

Wind speeds represented are referred to the height of 10 meters above the ground level. To extrapolate all other speeds to the hub height, IEC61400-11:2002 Ed.2.1. must be applied. A typical value of the longitude of roughness length is 0.05m, although this value depends on the concrete field.

1. INTRODUCTION

Estimated Sound Power levels (L_{wa}) are provided for the AW132/3300 wind turbine.

These sound power levels are valid only for the following conditions:

- Grid voltage below +2.5% of nominal value
- Generation of reactive power and wind farm algorithms deactivated
- Temperature inside a range between -20°C and +40°C
- No iced conditions. Temperature above +5°C and relative humidity below 80%
- Nacelle and ground doors closed for either measured wind turbine and everyone in sight

The represented wind speeds are referenced to a height of 10 meters above ground level. For the extrapolation to other hub height wind speed IEC 61400-11:2002 Ed.2.1 has to be applied. A typical value of roughness length is 0.05m; however, it depends on the site terrain.

2. Levels of Sound Power 2. Sound Power Levels

Wind speed at 10m height (m/s)	6	7	8	9	10
Wind speed at 120m height (m/s) [$z_0=0.05m$]	8.8	10.3	11.8	13.2	14.7
Sound Power Level (dBA) TH120	108.5	108.5	108.5	108.5	108.5

Wind speed at 10m height (m/s)	6	7	8	9	10
Wind speed at 84m height (m/s) [$z_0=0.05m$]	8.4	9.8	11.2	12.6	14.0
Sound Power Level (dBA) T84	108.5	108.5	108.5	108.5	108.5

Note: It is assumed the roughness length of 0.05m for the extrapolation of speed at the height of the hub.

NOTE Roughness length of 0.05m is assumed to the hub height wind speed extrapolation

3. Apparent Sound Roughness Level

Guaranteed

The maximum level of apparent sound level guaranteed will include a tolerance to consider measurement uncertainty. Tolerance is equal to combined standard uncertainty defined in norm IEC 61400-11:2002 Ed.2.1 and is applied to the level of sound power reported in section 1 and to the results of the test. As a reference value, a typical combined standard uncertainty is $\leq 1dB$.

Measures will be done in the positions defined in the norm IEC 61400-11 Ed. 2.1. The analysis of data will be conducted according to norm IEC 61400-11

3. Apparent Sound Power Level Guaranteed

The guaranteed max apparent sound power level will include a tolerance to account for measurement uncertainty. The tolerance is equal to the standard combined uncertainty defined in IEC 61400-11:2002 Ed.2.1 and is applied to both the sound power level reported in section 1 *and* the test result. For reference purposes, a typical standard combined uncertainty is $\leq 1dB$.

Measurements are to be carried out at the reference position as defined in IEC 61400-11 Ed. 2.1. The data analysis must be carried out according to IEC 61400-11 Ed. 2.1

4. Tonality

It can be expected a tonal audibility of $\Delta L_a \leq 2\text{dB}$ along the whole operational range.

4. Tonality

A tonal audibility of $\Delta L_a \leq 2\text{dB}$ can be expected over the entire operational range.

5. Octave Bands

Only for informative purposes the maximum range of octave bands expected is shown (not guaranteed)

5. Octave Bands

Maximum expected octave band spectra are provided for informational purposes only (not guaranteed).

Octave Bands	32	63	125	250	500	1000	2000	4000	8000
L _{wa} (dBA)	73.6	84.7	98.1	103.8	103.0	99.5	97.9	95.9	89.3

Values represented for the wind speed bin associated with the highest sound power level

	GENERAL DOCUMENT GENERAL DOCUMENTATION	Doc. DG200178
		Rev.: "C"
AW3000 SISTEMA BALIZAMIENTO AW3000 OBSTACLE MARKING AND LIGHTING		P. 1 / 6

AW3000



Rev	Date	Description of the revision
"A"	23/02/2009	<i>Elaboration / First Edition.</i>
"B"	03/02/2012	<i>Add mid-tower lighting system</i>
"C"	04/03/2015	<i>Update standard obstruction light models and UPS Nacelle Pictures Update standard obstruction light models and UPS. Nacelle pictures.</i>
"D"		

<p style="text-align: center;"><i>Performed</i></p> <div style="text-align: center;">  LHL 04 -03 -2015 </div>	<p style="text-align: center;"><i>Reviewed</i></p> <div style="text-align: center;">  E.S.S. 04 -03 -2015 </div>	<p style="text-align: center;"><i>Approved</i></p> <div style="text-align: center;">  MNP 04 -03 -2015 </div>
---	---	--

	GENERAL DOCUMENT	Doc. DG200178
	GENERAL DOCUMENTATION	Rev.: "C"
AW3000 SISTEMA BALIZAMIENTO AW3000 OBSTACLE MARKING AND LIGHTING		P. 2 / 6

1. OBJECT

The wind energy turbines Acciona Wind power AW3000 will be signaled to fulfil the requirement of local administrations of air navigation.

In this document two types of signaling are described. In any case, notification and AW coordination with the client are necessary.

- Light signals.
 - Nacelle beacons.
 - Tower beacons a half height.
- Structure Painting
 - Tower signaling (painting)
 - Rotor signaling (painting)

2. NACELLE BEACONS.

These beacons can be installed in the nacelle in conformity with Annex 14 of ICAO and the corresponding civil area administration

Depending on the requirements of the place where they are installed they can be day or night lights

The current models are lights of average intensity with LED technology and they take photoelectric cell, the control and the automatic synchronization system with other beacons.

Down below the two options are shown:

1. AIM

Different lighting and marking options are available for Acciona Wind power AW3000 wind turbines based on meeting specific local regulations, particularly aviation navigation requirements.

Two main marking systems are described in this document. These marking systems require notification and coordination with the customer:

- Light signals
 - Nacelle lighting system
 - Mid-tower lighting system
- Structure painting
 - Tower marking (paint)
 - Rotor marking (paint)

2. OBSTRUCTION LIGHTS

Obstruction lights in compliance with ICAO Annex 14 and the corresponding Civil Aviation Administration can be installed on AW3000 WTG's.

Day and/or night time operation is possible, depending on the specific site requirements.

The current references are medium intensity lights with LED technology, integrated photocell, monitoring and automatic flash synchronization between lights.

Two standard options are described in the table below:

	GENERAL DOCUMENT GENERAL DOCUMENTATION	Doc. DG200178
		Rev.: "C"
AW3000 SISTEMA BALIZAMIENTO AW3000 OBSTACLE MARKING AND LIGHTING		P. 3 / 6

	Day time mode	Day time mode
Option	20.000cd	2.000cd
A	off	2.000cd



Figure N° 1 Medium intensity light

In case the aviation local authorities for a specific project require another type of obstruction light, depending on the case low/medium/high intensity, its integration in the turbine can be studied.

In case the aviation local authorities for a specific project require another type of obstruction light, depending on the case low/medium/ high intensity, its integration in the turbine can be studied.

These lights can be used as single light or as multiple light systems, ensuring proper synchronization and communication.

These lights can be used as single light or as multiple light systems, ensuring proper synchronization and communication.




Figure 2. Obstruction light(s) in nacelle

	GENERAL DOCUMENT	Doc. DG200178
	GENERAL DOCUMENTATION	Rev.: "C"
AW3000 SISTEMA BALIZAMIENTO AW3000 OBSTACLE MARKING AND LIGHTING		P. 4 / 6

The obstruction light system can be integrated in the SCADA system, rising an alarm in case of failure (and with no impact to turbine operation).

The obstruction light system can be integrated in the SCADA system, rising an alarm in case of failure (and with no impact to turbine operation).

An extra kit for providing an uninterrupted power supply (UPS) for 12 hours for the obstruction lights is available if required.

An extra kit for providing an uninterrupted power supply (UPS) for 12hours for the obstruction lights is available if required.

3. MID-TOWER LIGHTING SYSTEM:

3. Mid-tower lighting system

As per the criteria of the FAA and other marking standards, the point for requiring lights in an intermediate height is to make the obstacle visible from any direction.

As per the criteria of the FAA and other marking standards, the point for requiring lights in an intermediate height is to make the obstacle visible from any direction.

This means the lights shall be installed in a height is not hidden by the blades.

This means the lights shall be installed in a height is not hidden by the blades.

The system consists of three red steady low intensity lights installed on the outside of the tower, along a ring at the middle of the tower and is visible from all viewing angles. It is anticipated that mid-level lightning may be required for structures with ground-tip heights above 150 meters and 500 feet (USA)

The system consists of three red steady low intensity lights installed on the outside of the tower, along a ring at the middle of the tower and is visible from all viewing angles. It is anticipated that mid-level lighting may be required for structures with ground-tip heights above 150 meters and 500 feet (USA).



Figure N° 3 UPS



Figure 4. Low intensity light

4. TOWER MARKING

If required, the bottom and upper section of the tower can be painted using alternated colored stripes. In the picture below an example is shown:

4. TOWER MARKING

If required, the bottom and the upper section of the tower can be painted using alternated colored stripes. In the picture below an example is shown:




Figure N° 5 Tower marking

	GENERAL DOCUMENT GENERAL DOCUMENTATION	Doc. DG200178
		Rev.: "C"
AW3000 SISTEMA BALIZAMIENTO AW3000 OBSTACLE MARKING AND LIGHTING		P. 6 / 6

5. PARTIAL ROTOR MARKING

Several painted patterns consisting of colored stripes at the blade tips are available. In the picture below an example is shown:

5. PARTIAL ROTOR MARKING

Several painted patterns consisting of colored stripes at the blade tips are available. In the picture below an example is shown:









Figure N° 6 Rotor marking



LAS CANTIDADES Y TIPOS DE COMPONENTES DE LAS IMAGENES MOSTRADAS PUEDEN VARIAR EN FUNCION DEL MODELO DE AEROGENERADOR / QUANTITY AND TYPE OF COMPONENTS MAY CHANGE DEPENDING ON WINDTURBINE MODEL

REV/REV	FECHA / DATE	REALIZADO / CREATED	MODIFICACIÓN / MODIFICATION
E	16-05-17	JIL	ACTUALIZAR PLANO CON MULTIPLICADORA / UPDATE DRAWING WITH GEARBOX
D	23-09-14	DSV	ACTUALIZAR PLANO CON CARCASA MODULAR / UPDATE DRAWING WITH MODULAR NACELLE COVER
C	03-04-13	JIL	ACTUALIZACION DE PLANO / DRAWING UPDATE
B	11-02-13	ARO	ACTUALIZACION GENERAL MAQUINA Y DENOMINACION / GENERAL MACHINE AND NAME UPDATE
A	10-11-10	OFG	CREACIÓN DEL PLANO / DRAWING CREATION

MATERIAL / MATERIAL		TOLERANCIAS GENERALES / GENERAL TOLERANCES		PESO / WEIGHT (kg)	
DIBUJADO / DRAWN	COMPROBADO / REVISED	APROBADO / APPROVED			
NOMBRE / NAME	16-05-2017	16-05-2017			
FECHA / DATE	16-05-2017	16-05-2017			
ESCALA / SCALE	DENOMINACIÓN				
DISPOSICION EQUIPOS NACELLE AW3000					
NAME AW3000 NACELLE EQUIPMENT ARRANGEMENT					
Este plano es propiedad exclusiva de acciona windpower y su reproducción total o parcial está totalmente prohibida y queda amparada bajo la legislación vigente. Los contraventores serán perseguidos legalmente tanto en España como en el extranjero. El uso, copia o venta de esta publicación, solo podrá realizarse con autorización expresa y por escrito de acciona windpower .					
This drawing is the exclusive property of acciona windpower and is covered by current legislation. Full or partial reproduction is prohibited. Anyone who does so will be prosecuted, whether in Spain or abroad. This publication may be used, copied or sold only with the express written authorization of acciona windpower .				PLANO Nº / DRAWING Nº DG200237	
				REVISIÓN / REVIEW E	
				HOJA Nº / SHEET Nº 1-1	
				FORMATO / FORMAT A3	



MODELO	(*) Rotor	(*) Altura buje	(*) Pala-torre (Mínima distancia)	(*) Raíz de pala	(*) Cuerda pala máxima	(*) Pala-suelo (a mínima distancia pala-torre)	(*) Punta pala-torre	(*) Punta pala-suelo
MODEL	Rotor	Hub height	Blade-tower (Minimum distance)	Blade root	Maximum Blade chord	Blade-ground (at minimum distance blade-tower)	Blade tip-tower	Blade tip-ground
	(D) m	(T) m	(B) m	(Ra) m	(C) m	(H) m	(P) m	(S) m
AW140 TH120	140	120	3,54	2,40	3,70	86,33	13,3	51,15
AW132 TH120V	132	120	2,52	2,40	3,70	110	12,7	54,9
AW132 TH120		120	2,88	2,40	3,70	110	12,6	55,10
AW132 T112.5		112.5	2,93	2,40	3,70	102,55	13,74	47,36
AW132 T84		84	2,86	2,40	3,70	74	13,75	18,90
AW125 TH137.5	125	137.5	2,88	2,40	3,70	128	12,50	76,00
AW125 TH120		120	2,88	2,40	3,70	110	12,50	58,60
AW125 TH100		100	2,88	2,40	3,70	90	12,50	38,60
AW125 T87.5		87.5	2,88	2,40	3,70	77	13,50	25,90
AW125 TH80		80	2,88	2,40	3,70	70	12,50	18,50
AW116 TH120	116	120	2,88	2,40	3,70	110	11,80	63,00
AW116 TH100		100	2,88	2,40	3,70	90	11,80	43,00
AW116 T92		92	2,89	2,40	3,70	82	12,70	35,00
AW109 TH100	109	100	-	2,414	3,946	-	-	-
AW109 T95.5		95.5	-	2,414	3,946	-	-	-
AW100 TH100	100	100	-	2,414	3,85	-	-	-

(*): Dimensiones aproximadas / Approximate dimensions

LAS CANTIDADES Y TIPOS DE COMPONENTES DE LAS IMAGENES MOSTRADAS PUEDEN VARIAR EN FUNCION DEL MODELO DEL AEROGENERADOR
 QUANTITY AND TYPE OF COMPONENTS MAY CHANGE DEPENDING ON WIND TURBINE MODEL

REV/REV	FECHA / DATE	REALIZADO / CREATED	MODIFICACIÓN / MODIFICATION
K	27-02-18	MSZ	AÑADIDA TH120V. ACTUALIZACIÓN TABLA TH120V ADDED. UPDATED TABLE DIMENSIONS
J	20-09-17	JIL	DESCRIPCIÓN ACTUALIZADA / UPDATED DESCRIPTION
I	25-08-17	MSZ	AÑADIDA ALTURAS BUJE 112.5 Y ROTOR AW140. ACTUALIZACIÓN TABLA 112.5 HUB HEIGHT AND AW140 ROTOR ADDED. UPDATED TABLE DIMENSIONS
H	31-03-16	MSZ	AÑADIDA ALTURAS BUJE 80, 84 Y 137.5. ACTUALIZACIÓN TABLA 80, 84 AND 137.5 HUB HEIGHT ADDED. UPDATED TABLE DIMENSIONS
A	14-06-11	ARO	CREACIÓN DEL PLANO / DRAWING CREATION

MATERIAL / MATERIAL		TOLERANCIAS GENERALES / GENERAL TOLERANCES		PESO / WEIGHT (kg)		
DIBUJADO / DRAWN	COMPROBADO / REVISED	APROBADO / APPROVED				
NOMBRE / NAME	FECHA / DATE	FECHA / DATE	PLANO Nº / DRAWING Nº DG200274			
FECHA / DATE	27-02-2018	27-02-2018	REVISIÓN / REVIEW K			
ESCALA / SCALE	DENOMINACIÓN					HOJA Nº / SHEET Nº
S/E	PL. GENERAL AEROGENERADOR AW3000 GENERAL ARRANGEMENT OF AW3000					1-1
Este plano es propiedad exclusiva de acciona windpower y su reproducción total o parcial está totalmente prohibida y queda amparada bajo la legislación vigente. Los contraventores serán perseguidos legalmente tanto en España como en el extranjero. El uso, copia o venta de esta publicación, solo podrá realizarse con autorización expresa y por escrito de acciona windpower . This drawing is the exclusive property of acciona windpower and is covered by current legislation. Full or partial reproduction is prohibited. Anyone who does so will be prosecuted, whether in Spain or abroad. This publication may be used, copied or sold only with the express written authorization of acciona windpower .						FORMATO / FORMAT A3

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date 15/08/2018 Rev: A</p>

Annex C.02.4

Schedule of Planned Preparations for Project Development

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date 15/08/2018 Rev: A</p>

Schedule of the Planned Preparations for Project Development

1. INTRODUCTION

Schedule of Planned Preparations of Project Development

This Annex has been provided by Energética Argentina S.A.



Energética Argentina SA - ENERGÉTICA I / TRES PICOS - 30 x AW132

		2018												2019											
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
COG - KIP (hours)	18.7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
Network Project (MTP)																									
Commercial Operation Date (COD)																									
MANUFACTURING																									
0	5.5																								
30																									
LT (H)																									
30	8.0																								
30	1.7 (H)																								
30	1.4																								
24																									
SHIPPING	30	3																							
PORT ARRIVAL	30	3																							
CUSTOMER CLEARANCE	30	3																							
SHIPPING - Pre-ops	30	17																							
SHIPPING - Erecton	30	17																							
OFF-DELIVERY - Pre-ops	30	17																							
OFF-DELIVERY	30	17																							
SHIPPING	30	15																							
PORT ARRIVAL	30	15																							
CUSTOMER CLEARANCE	30	15																							
OFF-DELIVERY	30	15																							
Engineering DOP	0	1	X	X	X	X	X	X	X	X	X	X	X												
Procurement DOP	0	1	X	X	X	X	X	X	X	X	X	X	X												
Site Mobilization	0	1	X	X	X	X	X	X	X	X	X	X	X												
Proc.	0	1	X	X	X	X	X	X	X	X	X	X	X												
MTO Foundations	30	1.60																							
MTO Platforms	30	1.60																							
MTO Work	0	1	X	X	X	X	X	X	X	X	X	X	X												
Substation - Civil Works	0	1	X	X	X	X	X	X	X	X	X	X	X												
Substation - Electromechanical	0	1	X	X	X	X	X	X	X	X	X	X	X												
Substation - Main Transformers	0	1	X	X	X	X	X	X	X	X	X	X	X												
Substation - Test and Commissioning	0	1	X	X	X	X	X	X	X	X	X	X	X												
Substation Link - Construction	0	1	X	X	X	X	X	X	X	X	X	X	X												
Substation Work	0	1	X	X	X	X	X	X	X	X	X	X	X												
Owner Ready - Foundations/Platforms Finished	CUSTOMER	30	30																						
Concrete Top Pre-ops	30	1.70																							
Horizontal pipes	30	1.70																							
Owner Erecton	30	1.70																							
Mobile Erecton	30	1.70																							
Horizontal joints	30	1.70																							
Commissioning Cabling	30	1.70																							
Mobile Erecton	30	1.70																							
Owner Cabling	30	1.70																							
Quality Review	30	1.70																							
Pre-commissioning	30	2.00																							
Commissioning	30	2.00																							
MTO to MTO DOP	30	2.00																							

Develas / TH
TH / W

22
15

CHAPTER 03.

Environmental Baseline

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date 15/08/2018 Rev: A Page 2 of 5</p>

CHAPTER 03. Environmental Baseline

Index

1. INTRODUCTION 3
2. Update Reports and Environmental Baseline Amplification

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p> <p>2</p> <p>Wind Power Centre 1</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>		<p>Date 15/08/2018</p> <p>Rev: A</p> <p>Page 3 of 5</p>

CHAPTER 03.

Environmental Baseline

1. INTRODUCTION

By virtue of modifications the energetic venture proprietor anticipates to be developed in the Project presented under File OPDS N° 2145 - 9512/16, in the present report there is an amplification and update of the Environmental Baseline, with respect to the Biotic Context.

The site of the Wind Energy Center has not been modified with respect to EIA (Original and Addendum). It is located South of the Buenos Aires Province, in the Tornquist Distric, next to Paraje García del Río and at approximately 5 Km from the city of Tres Picos, taking as a reference the Northeast vortex of the Project. (see Figure N° 1).

So, the characterization of the receiver environment in which the Project is placed is clearly described in Point 7, named "Baseline" of the Original EIA (Date: 09/02/2012).




Figure N° 1 Google Image with the geographical location of the Project.

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date 15/08/2018 Rev: A Page 4 of 5</p>

Even though the Project will be located in a rural area where the main activities are agriculture and farming, the three properties and their proximal context are highly modified by infrastructure works of local, regional and national importance. Among them, these are the most prominent ones:

- High voltage aerial line of 132 KV.
Property of Transba S.A. It bonds the ET Bahía Blanca with the ET Tornquist; it crosses North to South the Rural Property "Reyrolles".
- Medium voltage aerial lines of 13,2 KV (rural).
Property of Cooperativa of Tornquist. They provide electric energy to the three rural properties, among others.
- Rails and railway station.
Near the Rural Property of "San Bautista Sur" and "Reyrolles". There is also the "Paraje García del Río", which has an ancient railroad building (inhabited) and the ex-school N° 22 of the Buenos Aires Province.
- National Route N° 33
At the moment the route trace is being modified into a highway of two lanes (with two driving lanes each other), separated by a central quarry of 23.30 meter wide).



Figure N° 2 Google Image showing infrastructure works around the Project.

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date 15/08/2018 Rev: A Page 5 of 5</p>

For the above said, at the moment the study area has a strong anthropic alteration; the fauna of these plots of land is limited mainly to those species that have adapted to live with human presence in disturbed areas.

2. Update Reports and Environmental Baseline Amplification

Two reports corresponding to the Biotic Context of the Project environment are added below.

- Baseline Report: Flora and vegetation, (August 24th, 2018)
- Baseline Report: Fauna, (September 4th, 2018).

Energetic Wind Center Project I

Baseline Report: Flora and Vegetation

Long, M.A.

Date: 24/8/18

INTRODUCTION

Study Sector Setting in the phyto geographical regional area

The sector analyzed is located in the foot-of-the-mountain area, to the Southwestern of the Sierras Australes from Buenos Aires. The diverse topography represents an ecotone or transitional sector between the topographical areas of La Pampa and Espinal (Morello *et al.* 2012) and it receives the influence of typical mountain flora. For this reason, the area encases great botanic and conservation interest when it presents little anthropic transformation.

As typical features of this ecotone, there are two strata: the lower one, herbaceous, that does not reach the half meter height, and the upper one, with 2 or 3 meter-high shrubs. In the herbaceous stratum grass called flechillas (*Amelichloa*, *Jarava*, *Nassella*, *Piptochaetium*) predominates, and other native species join the *Bromus*, *Pappophorum*, *Poa*, *Bothriochloa*, *Aristida*, *Melica*, *Chascolytrum*, among others (Cabrera 1971; Frangi & Bottino 1995). In a lesser extent, there are other herbaceous families and shrubs: Asteraceae, Oxidaceae, Malvaceae and from the Verbenaceae family. An important feature for the conservation is the presence of terrestrial orchids. In the area there are two of the species representative of the South of Buenos Aires: *Bipinnula pennicillata* y *Brachystele dilatata*. Besides, as an unusual feature there can be ferns.

Because of the agricultural and farming use, most of the ecological region of Pampa is transformed almost in full, mostly without its characteristic flowers. The fields that have not been worked or are in rest, often have high percentage of herbs and exotic shrubs, an abundance of yellow flowers (*Diplotaxis tenuifolia*), Russian thistle (*Salsola kali*), thistle (*Carduus thoermeri*), among others.

STUDY AREA

It includes three fields in the proximities of García del Río, in the District of Tornquist, Buenos Aires. The coordinates of the quarters in each field are:

Plot A: Guanaco Chico Field: 38°22'11.09"S - 62°15'21.82"O Plot

B: Reyrolles Field: 38°21'22.69"S - 62°14'20.94"O

Plot C: San Bautista Sur Field: 38°21'5.31"S - 62°13'3.49"O

OBJECTIVES:

- Evaluate plant diversity.
- Estimate the vegetable coverage and the percentage of bare land.
- Identify interesting botanic species with biologic, eco systemic or cultural value.
- Classify the field sectors in their value for conservation by flower signaling in the winter period.
- Suggest management recommendations with emphasis to protect native vegetation and minimize the impact on species in danger.

METHODOLOGY

- **Sampling sites:** Each field was divided into homogeneous sectors with respect to management and general type of landscape.




Figure 1- Image of the sector where the wind turbines of the Energetic Wind Center I Project will be located. The different lots are detailed: Campo Guanaco Chico, Reyrolles y San Bautista Sur (yellow-framed), location of the wind turbines (white), and sampling sites (M1 to M79). Blue circles point out tree-observation sites, which resulted all of cultivated origin.

- **For flower diversity and identification of botanic species of interest:**

In each sampling sector (M1 to M7) random walks were performed for the collection of botanic samples and the preparation of a list with presence/absence of species.

In the case of species of difficult identification in the field, samples were taken to determine identification with especial bibliography, under binocular magnifier glass in the office. The period in which the study was performed is not the proper one for identification of flowers (end of August), because most of the perennial species are in vegetative state, without flowers or fruit (which are the ones used in the identification of taxon) and most of the annual ones are barely in a seedling state. So, the flowery richness and its abundance in this time of the year is underestimated with respect to other values that can be obtained during springtime.

Considering taxonomic determinations, it is stated the name given to a tentative sample, indicated as "cf." i.e., name to be confirmed, or if it is only known its genre but not its species (sp.). For the identification of the seedling state,

rosette or vegetative, Fernández *et al.* was consulted. (2016) and specialized works for certain taxon.

For the native species conservation status Delucchi (2006) and the database of endemic plants from Argentina and the Southern Cone (PlanEAR) were consulted and their geographical distribution was considered. For this report, the categories of conservation risks indicated in Table 1 were employed.

Table 1- Categories of extinction risk for native species in function by Delucchi (2006), database of PlanEAR, UICN and geographical distribution information.

Risk Category	Definition
CR: In critical danger	The species is considered in extremely high risk of extinction in wild state. It includes species that have demonstrated a strong shrink in its distribution, there is a generalized menace in their habitat and/or are endemic (exclusive of a reduced area).
IN: Lightly endangered	The species run minor risk of extinction, but there are signs that their populations are at present under threat by a shrinkage in their habitat and/or for being endemic that face anthropic alterations or use.
VU: Vulnerable	The species runs potential risk of extinction. There are anthropic alterations that may cause shrinkage of the population, especially if they are endemic.
NP: No at risk	The species is not under any risk of extinction neither at short or medium term, and on the contrary it shows signs of expediency in face of environmental degradations.
SD: No data	It has not been studied or data are insufficient.

- **Estimation of abundance of species**

These fields contain sections already worked out, where the cultivation covers practically 100% of the field. In these sectors only surveys of the surrounding flora that develops in little patches or in the borders of the cultivated land were carried out. The census of abundant species was developed only in the areas of natural pastures (M2, M3, M4, M5 and M5, M7 in Figure 1). The estimation was done in two ways: a) By land: through the examination of the three sections randomly within each of the sampling areas already mentioned, where it was estimated the coverage of each species in 1 m² range; b) By air: the previous visual estimation was corroborated through drone-taken aerial images from 30 m height.

- **Presentation of the flower and vegetation information:**

The totality of species in each sector were listed. For each of them it was indicated: a) data pm the species: scientific name, current name (if any), family; origin

(native, cosmopolitan or exotic) and the category of conservation (if any); b) data on the presence/absence in each sector.

Classification of field sectors for recommendations:

The fields were classified in grassland areas of low, moderate and high value of conservation. The presence of the following species is used as indicators of the environmental quality:

Area of moderate value of conservation:

- Grassland: more than 40% of the coverage of native grass, with the presence of one or more species belonging to the genres *Amelichloa*, *Nassella*, *Jarava*, *Paspalum*, *Piptochaetium*, *Panicu*, *Bromus*, *Melica* and *Bothriochloa*.
- Shrubs: presence of *Prosopidastrum angusticarpum*, *Discaria americana*, *Baccharis* spp., *Acanthoscyclus buniifolius*, *Aloysia gratissima*, *Caesalpinia gilliessii*, *Gutierrezia mandonii*, only if they have a coverage inferior to 30% (otherwise it is assumed as a history of intensive grazing).

Area of high value of conservation:

- If, besides the elements of the previous situation, there is recognition of:
 - rare or endemic species (according categories provided by Rabinowitz *et al.* 1986)
 - species in danger of extinction (under any of the existing categories)
 - species that might have any particular value of conservation: ecologic, cultural or economic service.

RESULTS

In Table 2 the study of species and census of abundance are shown, and there are interest data for some plants, which correspond to the site where the Electrical Wind Energy Center I Project will be developed

A total of 64 species of vascular plants were studied, with 62% (n=39) native ones, coming from the South Cone, and some of them endemic ones, which means with a reduced area of distribution, in this case, the center of Argentina. The 38% are exotic species, circumscribed mostly in cultivation areas or high pastures. In general terms, the area presents a native-exotic proportion lesser than that estimated for a natural grassland in pristine condition (3:1).

The three fields to which this project correspond present a vegetation coverage of 100% with very small areas of barren soil (generally sandstone or gavel). Nevertheless, the plant composition is not equal all along the sample areas (signaled as M1 to M7 in Figure 1).

Guanaco Chico Field: (Figures 2,4 to 7) two different areas are distinguished from the floristic point of view where the wind turbines will be located:

- Area of high value of conservation: The sampling sector M1 is a cultivated land, with a few patches of natural grassland and abundance of exotic or occasional species, associated to anthropic modifications.
- Area of high value of conservation: The sector M2 (Figure 2) instead, is an area of grassland with 50% of the coverage with *Amelichloa caudata*, and the occasional presence of two types of shrubs (less than 20%): *Discaria americana* (native) and *Prosopidastrum angusticarpum* (endemic of the rough soils in San Luis, La Pampa, Southwestern part of Buenos Aires, Neuquén and North of Río Negro). This composition and relative abundance of the species named are indicators of the conservation value assigned.

Reyrolles Field: (Figures 3,8 to 11) patches of vegetation corresponding to Figure 1 , from M3 (a and b), M4 and M5 were evaluated.

- Area of high value of conservation: The M3 sector corresponds to grassland similar to M2 (Guanaco Chico Field) but with diversity somewhat higher, a 30% of *Amelichloa caudata* and 40% of *Nassella sp.*, both typical species of native grassland. As surrounding shrubs (in lower proportion and lesser height than in M2) native species of shrubs *Margyricarpus pinnatus* and *Discaria americana* were found.
- Areas of high value of conservation: sector M4 and M5 The first one constitutes a zone of soft hills with sandy soil, and the second, next to the first one, is more regular with a layer not so sandy but with more gravel. In both, vegetation changes considerably with respect to the surrounding area, with the influence of being near the foot of the grove in Sierras Australes of Buenos Aires. The *Nassella* y *Piptochaetium* have a

moderate to low coverage, with surrounding species typical of that at the foot of the mountains: *Dichondra sericea*, *Oxalis articulata*, *Discaria americana*, *Adesmia incana*, *Hysterionica pinnifolia*, *Margyricarpus pinnatus*. Two relevant findings are: a terrestrial orchid, *Bipinnula penicillata* (Figures 10 and 11) and a tiny fern with very primitive features, *Ophioglossum crotalophoroides* (Figure 9), with various individuals distributed along the area between M4 and M5. Both species encase great interest from the point of view of the conservation or for being scarce and sensible to anthropic modifications.

San Bautista Sur Field: (Figures 12 and 13) covers sectors M6 and M7.

- Area of low value of conservation: in its mayor part the field contains cultivation lands, completely transformed (sector M6).
- Area of moderate value of conservation: sector M7. It is a grassland covered by *Amelichloa ambigua* (50% coverage); *Nassella* sp. (30%), with surrounding species like *Acaena myriophylla* and *Hysterionica pinnifolia*.

TABLE 2- Study of species, estimation of abundance (like percentage of coverage) and data of botanic interest, for the Project CE Energética I. Study developed at the end of August, 2018.

References: M1 a M7, sampling areas. LOT A -Guanaco Chico Field: M1= cultivated area; M2= rough hills. LOT B- Reyrolles Field: M3= natural grassland; M4= sandland hills; M5= antenaes. LOT C- San Bautista Sur Field: M6= cultivated land; M7= patch of grassland near the fencing. In gradation of colour and number: 0= absent; 1= present with very low coverage; 20%-30 %, moderate coverage; 40%-50% high coverage; >80% very high coverage. ; presence of species of high value of conservation in low abundance. Categories of conservation (under definitions in Table 1): CR= critical danger; EN= moderate danger; VU= vulnerable; NP= no danger; SD= no data.

Relieved species	Guanaco Chico M1	Guanaco Chico M2	Reyrolles M3	Reyrolles M4	Reyrolles M5	San Bautista Sur. M6	San Bautista Sur. M7	Origin	Category of conservation	Plant Outline	Family
<i>Acaena myriophylla</i>	0	0	0	0	0	0	1	native	VU	sub shrub	Rosaceae
<i>Adesmia incana</i>	0	0	0	0	1	0	0	native	VU	perennial herb	Fabaceae
<i>Amelichloa caudata</i>	1	50%	30%	20%	0	0	50%	native	IN:	perennial herb	Poaceae
<i>Anemone decapetala</i>	0	0	0	1	0	0	0	native	VU	perennial herb	Ranunculaceae
<i>Aphanes parodii</i>	0	1	1	1	0	0	1	native	NP	annual herb	Rosaceae
<i>Baccharis ulicina</i>	1	0	0	1	0	0	1	native	NP	sub shrub	Asteraceae
<i>Bipinnula pennicillata</i>	0	0	0	1	0	0	0	native	CR	perennial herb	Orchidaceae
<i>Bothriochloa barbinodis</i>	0	1	1	0	0	1	0	native	NP	perennial herb	Poaceae
<i>Bowlesia incana</i>	80%	1	0	1	1	0	1	native	NP	annual herb	Apiaceae
<i>Bromus cf aulethicus</i>	0	0	0	0	0	1	1	native	IN:	perennial herb	Poaceae
<i>Cardus thoermeri</i>	0	1	0	0	0	0	0	adventicia	_	perennial herb	Asteraceae
<i>Carex bonariensis</i>	1	0	0	1	0	0	0	native	VU	perennial herb	Cyperaceae
<i>Centaurea sp.</i>	1	0	0	0	0	1	1	adventicia	_	perennial herb	Asteraceae
<i>Centunculus minimus</i>	0	0	0	1	0	0	0	adventicia	_	annual herb	Primulaceae
<i>Chaptalia cf integerrima</i>	0	0	1	0	0	1	1	native	VU	perennial herb	Asteraceae
<i>Chevreulia sarmentosa</i>	1	1	1	1	0	0	0	native	NP	perennial herb	Asteraceae
<i>Cliococca selaginoides</i>	0	0	0	0	1	0	0	native	VU	perennial herb	Linaceae
<i>Conyza sp.</i>	1	1	0	0	0	0	0	native	SD	perennial herb	Asteraceae

<i>Crop or Weed</i>	40%	0	0	0	0	80%	0	SD	SD	herb	SD
<i>Daucus pusillus</i>	0	0	0	0	0	0	1	native	NP	annual herb	Apiaceae
<i>Dichondra sericea</i>	0	0	0	0	1	0	0	native	VU	perennial herb	Oleaceae
<i>Diplotaxis tenuifolia</i>	1	0	0	0	0	0	1	adventicia	_	perennial herb	Brassicaceae
<i>Discaria americana</i>	0	1	1	1	0	0	0	native	VU	shrub	Rhamnaceae
<i>Eragrostis curvula</i>	0	0	0	0	0	0	1	adventicia	_	perennial herb	Poaceae
<i>Erodium cicutarium</i>	50%	1	1	0	0	1	1	adventicia	_	annual herb	Geraniaceae
<i>Erodium moschatum</i>	0	0	0	0	0	0	1	adventicia	_	annual herb	Geraniaceae
<i>Fissidens sp.</i>	1	1	0	0	0	0	0	native	SD	moss	Fissidentaceae
<i>Fumaria agraria</i>	0	0	0	0	0	1	1	adventicia	_	annual herb	Papaveraceae
<i>Galium richardianum</i>	0	0	0	0	1	0	0	adventicia	_	perennial herb	Rubiaceae
<i>Gamochaeta coarctata</i>	1	1	1	1	1	1	1	native	SD	perennial herb	Asteraceae
<i>Gamochaeta falcata</i>	1	1	0	0	0	1	1	native	SD	perennial herb	Asteraceae
<i>Geranium molle</i>	1	0	0	0	0	0	0	adventicia	_	annual herb	Geraniaceae
<i>Habranthus cf tubispathus</i>	1	0	0	0	0	0	0	native	VU	perennial herb	Amaryllidaceae
<i>Hedeoma medium</i>	0	0	0	0	1	0	0	native	IN:	sub shrub	Lamiaceae
<i>Hirschfeldia incana</i>	1	0	0	0	0	1	0	adventicia	_	annual herb	Brassicaceae
<i>Hypochaeris sp.</i>	1	0	1	1	0	1	1	native	SD	perennial herb	Asteraceae
<i>Hysterionica pinnifolia</i>	0	0	0	1	0	0	1	native	VU	sub shrub	Asteraceae
<i>Juncacea sin identificar</i>	0	0	0	0	0	0	1	native	SD	perennial herb	Juncaceae
<i>Lepidium aletes</i>	0	0	0	1	0	0	0	native	VU	perennial herb	Brassicaceae
<i>Lepidium didymum</i>	0	0	0	0	0	1	0	native	NP	annual herb	Brassicaceae
<i>Lolium perenne</i>	1	1	0	0	0	0	0	adventicia	_	perennial herb	Poaceae
<i>Malva sylvestris</i>	0	0	0	0	0	1	0	adventicia	_	perennial herb	Malvaceae
<i>Margyricarpus pinnatus</i>	0	0	1	1	0	0	0	native	IN:	crawling shrub	Rosaceae
<i>Medicago minima</i>	80%	0	0	1	0	1	1	adventicia	_	perennial herb	Fabaceae
<i>Micropsis spathulata</i>	0	1	0	1	0	0	0	native	VU	perennial herb	Asteraceae
<i>Nassella sp.</i>	1	1	20%	20%	0	0	30%	native	CR	perennial herb	Poaceae

<i>Ophioglossum crotalophoroide</i>	0	0	0	1	1	0	0	native	CR	perennial herb	Ophioglossaceae
<i>Opuntia microdasys</i>	0	0	0	0	0	0	1	adventicia	_	suculenta	Cactaceae
<i>Oxalis articulata</i>	1	1	0	1	1	0	0	native	VU	perennial herb	Oxalidaceae
<i>Oxalis perdicaria</i>	0	0	0	1	0	0	0	native	NP	perennial herb	Oxalidaceae
<i>Panicum bergii</i>	0	0	1	0	0	0	0	native	VU	perennial herb	Poaceae
<i>Pappophorum vaginatum</i>	1	0	0	0	0	1	1	native	VU	perennial herb	Poaceae
<i>Parietaria debilis</i>	0	0	0	1	0	0	0	adventicia	_	annual herb	Urticaceae
<i>Piptochaetium</i> sp.	1	1	0	20%	0	1	1	native	VU	perennial herb	Poaceae
<i>Prosopidastrum</i>	0	1	0	0	0	0	0	native	CR	shrub	Fabaceae
<i>Rumex</i> sp.	0	1	0	0	0	0	0	adventicia	_	perennial herb	Polygonaceae
<i>Samolus valerandi</i>	1	0	0	0	1	1	1	native	NP	perennial herb	Primulaceae
<i>Schinus molle</i>	0	0	0	0	0	1	0	adventicia	_	tree	Anacardiaceae
<i>Senecio madagascariensi</i>	1	0	0	0	0	0	0	adventicia	_	perennial herb	Asteraceae
<i>Silybum marianum</i>	1	1	0	0	0	1	1	adventicia	_	perennial herb	Asteraceae
<i>Solanum atriplicifolium</i>	1	0	0	0	0	0	0	adventicia	_	perennial herb	Solanaceae
<i>Stellaria media</i>	0	0	0	1	0	1	1	adventicia	_	annual herb	Caryophyllaceae
<i>Taraxacum officinale</i>	1	0	0	0	0	1	1	adventicia	_	perennial herb	Asteraceae
<i>Veronica arvensis</i>	0	0	0	1	0	0	0	adventicia	_	annual herb	Plantaginaceae

Figure 2: Area of floristic interest in Guanaco Chico Field(M2). It constitutes a flowering of rough and loose stones , which presents native original grassland and two shrub species typical of the foot-of-the-mountain vegetation: *Discaria americana* (native) and *Prosopidastrum angusticarpum* (endemic). Area of the orange range: 15 hect approx.



Figure 3: Sight of the area of floristic interest in Reyrolles Field (sector M4 and M5). It is a sandy flowering with natural grassland and the presence of vulnerable species among others: terrestrial orchid *Bipinnula pennicillata* and *Ophioglossum crotalophoroides*. Range area: 53 has approx.






Figure 4- Guanaco Chico Field, sector M1, correspondent to cultivated field.



Figure 5- Guanaco Chico Field, sector M2, view of the grassland *Amelichloa ambigua*.



Figura 6- *Prosipidastrum angusticarpum* endemic species of the centre of Argentina (Sector M2)




Figure 7- *P. angusticarpum*, detail of flowers (Reference Photo for recognition- Source: IBODA).



Figure 8- Reyrolles Field, sandy hills in sector M4 with grassland.



Figure 9- *Ophioglossum crotalophoroides*, fern in danger of conservation. A pencil was used a reference for the size. (Sectors M4 and M5).



Figure 10- *Bipinnula pennicillata*, terrestrial orchid of conservation interest in the sector M4 (two individuals signaled with arrows and circles)



Figure 11- *B. pennicillata*, detail of the flower that blooms in springtime, as well as the basal leaves from Figure 10 they wither (Reference photo, source: IBODA).



Figure 12- San Bautista Sur Field (sector M6) cultivated area.



Figure 13- San Bautista Sur Field. View of the sector with native grassland in M7.

Management Recommendations

The sectors where the wind turbines will be located differ in environmental quality:

- a) The sectors indicated in Figure 1 as M2 (Guanaco Chico Field), M3, M4 and M5 (Reyrolles) and M7 (San Bautista Sur) are located between the main areas where mitigation tasks of the impact on the soil movement and the placing of roads, mills and towers will take place. In all these sites the activity will affect patches of native grassland which receives the influence of the foothills of the Sierras Australes Bonaerenses. In the particular case of M4 and M5, it is added that there exist two main species for conservation categorized as in critical danger (Table 2).
- b) Sectors M1 (Guanaco Chico Field) and M6 (San Bautista Sur), present great alterations caused by agriculture and farming, with no importance from the botanic point of view. In general, the Tornquist District presents a moderate risk (6-50 mg/ has year) with respect to wind erosion, while it maintains a vegetable coverage (Silenzi *et al.* 2011).

Due to seasonal weather in the region, the peak in maximum growth and flowering of plants happens between ends of October and ends of December (Marban & Bahía 2015). The blossoming enables the detection of plenty of species and improves the certainty in the identification of them. For more information about flower diversity in the sites affected by the Project, it is recommended to perform a new study of the flora during the period of November-December.

To solve the extraction of flora and the presence of bare land and barren soil, it is recommended the application of any of the following actions, or their application in a combined way:

ASSISTED TRANSLOCATION

The assisted translocation with the aims of preserving species consists of their movement in a programmed way, from one site to the other where they can develop properly (UICN 2012). Even though it is rather risky for the survival of the species, it is a possibility of mitigation action, for rare or threatened plants which grow in sites with future modification. (Rosselló-Graell 2002). In this case, it is recommended to do the assisted translocation of the species *Bipinnula pennicillata* and *Ophioglossum crotalophoroides*, of the sectors M4 and M5 (and of any other similar species similar in rareness which may be detected in other time of the year). The process of assisted translocation has several stages (Rosselló- Graell 2002): the first one is that of selecting the receiver site, where the species will have a better probability to survive. The most alike are the ecological conditions of the new site and the original one, the best probability of survival of the translocated species will be. In the case of the aforementioned species, they can be taken to other sites within the limits of their original distribution, and to improve their survival at the long run, their introduction in other protected areas in the zone is suggested: Provincial Park Ernesto Tornquist (Ruta Pcial 76, Km 222) and Reserva Sierras Grandes (Sierra de la Ventana), both dependant from OPDS. The second stage is that of selecting the majority of individuals to move and the strategy of transplantation, which may consist of extracting soil panels or individual plants

with covered or bare root (the decision between economising efforts or maximising survival). In the case of the species in Reyrolles, the specialist in charge will decide the best way to perform the translocation. The third stage is the implementation, where the species is translocated, and the fourth stage is that of the caring to get a full rooting in the new site (implant), and the monitoring of the survival and estate of the species once they have been implanted. So, if this mitigation action is carried out, it must be assured the maintenance of a specialist that monitors the process until the plants develop on their own, period which the specialist will evaluate in relation to the vitality of the plants.

It is suggested the contact with a specialist in translocation of native plants with preservation purposes, with ample experience in the flora from Buenos Aires:

Tec. Univ. Mauro Fossati
Botanic Garde of Agronomy – National University of Buenos Aires E-mail: cyathea_australis1@hotmail.com

SPONTANEOUS RESTOCKING OF EMPTY SPACES FROM SEED SOURCES OF NEIGHBOURING POPULATIONS

RESTOCKING ASSITED THROUGH ROLLS OF NATIVE SPECIES SEEDS

The sites of relieved grassland (M2, M3, M4, M5 and M7) present less floristic diversity than the expected for a pasture not submitted to grazing. The species found there are those the surviving livestock does not consume (no palatable), missing or growing in a low proportion the palatable ones.

The removal of soil for the development of the Wind Farm Project will leave a big area of barren land, with no vegetation at all. This may bring severe consequences due to wind and rain erosion, and due to the withdrawal of native species of grassland that already are in severe retraction (Bilenca & Miñarro 2004). The restocking of these bare lands from souces of surrounding grassland seeds might prove a quick solution, economical and operative, but as so said, it will recover only some few species of the hundred native grassland in the area, under optimal conditions. To avoid this, it is possible to enrich the zones with barren land using rolls of native grassland. (Castillo & Marino 2012; Parera & Carriquiri 2014, Figure 14). They are produced by cultivating native grassland in quarters without working, borders of fencing and neighbouring roads. The rolls are fitted into the site, they are dismantled and distributed so that the seeds can be dispersed. The same dried grass serves as a protection so the wind and rain do not remove them until germination. To get a good plant growth, these actions must be done once the heavy machine work is done. But, on the other side, during the works are done, there is the risk of blast and washing of the soil. It is recommended to enrich the soil in the removed sector with other species, especially leguminous plants which are nitrogen fixing. (Milano 2018).



Figure 14- Recovering of degraded soil from rolls of native pastures cultivated in places with grassland of good quality. A- The rolls are dismantled on the ground to be treated. B- Then it is dispersed by hand to get a better distribution of the seeds. (Source: Casillo & Marino 2012).

MONITORING OF THE PROCESS OF RESTAURATION OF THE VEGETAL COVERAGE IN THE AFFECTED SECTOR.

The district of Tornquist is considered in its mayor part as an area of high biodiversity in the national and international range. (Crisci *et al.* 2001; Frangi & Bottino 1995; Kristensen & Frangi 1995). So, monitoring is recommended during preconstruction and construction stages, and as far as possible, up to two subsequent spring-summer periods, when the aspects detailed in Table 3 are attended:

Table 3- Tentative Scheme for a monitoring of the restoration process of the sector

Actions	Moment suggested to make
<ul style="list-style-type: none"> Observe that the vegetable cover advances in areas that have been left with bare land. 	Immediately after the construction process.
<ul style="list-style-type: none"> Detect the presence of invader species (Check database: I3N Argentina) which have advanced with the soil removal and the introduction of machinery. 	Stage of preconstruction, construction and post construction, immediate to the final stage.
<ul style="list-style-type: none"> If translocation or replanting measures have been applied, check their implantation and installation. <u>are successful.</u> 	Months after the remediation action.

BIBLIOGRAPHY

- Bilenca, D. & Miñarro, F. 2004. Identificación de Áreas Valiosas de Pastizal (AVPs) en las pampas y Campos de Argentina, Uruguay y sur de Brasil. Fundación Vida Silvestre Argentina, Buenos Aires, 353 pp.
- Cabrera, A.L. 1971. Fitogeografía de la República Argentina. *Bol. Soc. Arg. Bot.*, 14: 1-42.
- Castillo, J. & Marino, G.D. 2012. Seed roll to restore the pasture. Improvement of the forage offer through replanting of pasture species. Ed. Aves Argentinas y Fundación Vida Silvestre Argentina, Buenos Aires, 12 pp.
- Crisci, J.V., Freire, S., Sancho, G. & Katinas, L. 2001. Historical Biogeography of the Asteraceae from Tandilia and Ventania Mountain Ranges (Buenos Aires, Argentina). *Caldasia*, 23: 21-41.
- Delucchi, G. 2006. Las especies vegetales amenazadas de la provincia de Buenos Aires: An update. *APRONA Bol. Cient. Nro. 39*: 19-31.
- Fernández, O.A.; Leguizamón, E.S. & Acciaresi, H.A. 2016. Malezas e invasoras de la Argentina II: descripción y reconocimiento. EdiUNS, Buenos Aires, 936 pp.
- Frangi, J.L. & Bottino, O. 1995. Comunidades Vegetales de la Sierra de la Ventana, Provincia de Buenos Aires, Argentina. *Revista de la Facultad de Agronomía, La Plata*, 71(1): 93-133.
- Kristensen, M.J. & Frangi, J.L. 1995. La Sierra de la Ventana: una isla de Biodiversidad. *Ciencia Hoy*, 5 (30): 25-34.
- Marbán, L. & Bahía, R. 2015. Colores del pastizal: una herramienta para su conservación. XXXV Jornadas Argentinas de Botánica, Salta, Argentina.
- Milano, C. 2018. Leguminosas herbáceas nativas: una alternativa para la restauración de pastizales y suelos degradados en el sudoeste bonaerense. Tesis de Maestría en Ciencias Agrarias, Dpto. Agronomía, Universidad Nacional del Sur, Bahía Blanca, 173 pp.
- Morello, J.; Matteucci, S.D.; Rodríguez, A.F. & Silva, M. 2012. Ecorregiones y complejos ecosistémicos Argentinos. Orientación Gráfica Ed., Buenos Aires, 800 pp.
- Parera, A. & Carriquiry, E. 2014. Manual de Prácticas Rurales asociadas al Índice de Conservación de Pastizales Naturales (ICP). Proyecto de Incentivos a la Conservación de Pastizales Naturales del Cono Sur de América del Sur. Ed. Aves Uruguay, Buenos Aires, 204 pp.
- Rabinowitz, D., Cairns, S. & Dillon, T. 1986. Seven forms of rarity and their frequency in the flora of the British Isles. En Soule, M.E. (Ed.). *Conservation Biology: The Science of Scarcity and Diversity*. Pp: 182-204.

Rosselló-Graell, A.; Draper, D.; Correia, A.I.D. & Iriondo, J. M. 2002. Translocación de una población de *Narcissus cavanillesii* A. Barra & G. López en Portugal como medida de minimización de impacto. Ecosistemas 2002/3. URL:<http://www.aeet.org/ecosistemas/023/investigacion7.htm>

Silenzi, J.C.; Echeverría N.E.; Bouza, M.E. & De Lucia, M.P. 2011. Degradación de suelos del SO Bonaerense y su recuperación. Jornadas "Evolución y futuro del Desarrollo de producciones agrícola-ganaderas en el SO Bonaerense, organizadas por la Academia Nacional de Agronomía y Veterinaria, Universidad Nacional del Sur, Bahía Blanca.

IUCN Species Survival Commission. 2012. Guidelines for Reintroductions and Other Conservation Translocations. August 2012. Adopted by SSC Steering Committee at Meeting SC 4 6, 5th September 2012

Databases looked up:

Flora Argentina. URL: <http://www.floraargentina.edu.ar/>

Flora del Cono Sur. IBODA. URL: <http://www.darwin.edu.ar/Proyectos/FloraArgentina/fa.htm>

INB Argentina. Sistema Nacional de Información sobre Especies Exóticas Invasoras. <http://www.inbiar.uns.edu.ar/>

PlanEAR. URL: <http://www.lista-planear.org/>

Report of the baseline of Energetic Wind Center I:
Fauna Carrizo Martín Andrés
Date: 4/09/2018

Area of Study

The site of the future Wind Farm is located South of Buenos Aires province, in the District of Tornquist, near Paraje García del Río and approximately at 5 Km from the town of Tres Picos (Figure N° 1).

The lots that compose the site are at 20 kilometers of an important area for the conservation of birds (AICA). It is about **AICA (BA14)**: Sierras Australes de Buenos Aires (Figure 2).

It covers the Sierras Australes which encase special interest for some birds of patagonic-andino origin and that represent isolated populations that inhabit almost exclusively in the mountain peaks and high valleys, where they breed. Such is the case of the canastero pálido (*Asthenes modesta*), the gaucho serrano (*Agriornis montana*), the jilguero austral (*Sicalis lebruni*) and the piquitodeoro común (*Catamenia analis*). As well some species of different ensembles live in the place, like those of the Arbustal de Llanura Árido, of Mild Grassland and of Grassland. There have been detected also some endemic cases from Argentina: the espartillero pampeano (*Asthenes hudsoni*), the cacholote pardo (*Pseudoseisura gutturalis*) and the monjita castaña (*Neoxolmis rubetra*). One species of restricted distribution, the monjita chocolate (*Neoxolmis rufiventris*), reaches the area in winter (Di Giacomo 2007).

With the aim of establishing the diversity of the fauna in the area of the Wind Energy Center I there is a data baseline and it is suggested a monitoring schedule for the area which enables the fulfillment of objectives to establish:

- The number of species in existence in the site and their seasonal variation.
- The presence of threatened species.
- The migrant status of the species in existence.
- Activity and seasonal abundance of bats.
- Preliminary recommendations and the suggestion of a tentative schedule for monitoring 2018/2019.



Figure 1. Location and limits (in red) of the future Wind Farm site.




Figure 2. AICA BA14 Sierras Australes de Buenos Aires.

Birds

The avifauna of the region is well documented and it is known about 330 species of birds for the Southwest of Buenos Aires, of which 25% present a migratory behavior (Belenguer et al. 1993, Petracci et al. 2018).

For the District of Tornquist there are approximately 180 species of birds registered at present (Doiny Cabré y Lejarraga 2015)

During the two studies during August 2018, 142 species were registered in the site of the future Energetic Wind Center, 3 of which are in danger of extinction (Table 1).

Common Name	Scientific Name	Migratory Status	Threatening Status in	Status UICN-BirdLife
Ñandú	<i>Rhea americana</i>	R	VU	NT
Inambú Común	<i>Nothura maculosa</i>	R	NA	LC
Martineta	<i>Eudromia elegans</i>	R	NA	LC
Colorada	<i>Rhynchotus rufescens</i>	R	NA	LC
Chiflón	<i>Syrigma sibilatrix</i>	R	NA	LC
Bandurria Austral	<i>Theristicus melanopsis</i>	Mp	NA	LC
Jote Cabeza Negra	<i>Coragyps atratus</i>	R	NA	LC
Cauquén común	<i>Chloephaga picta</i>	Mp	AM	LC
Milano Blanco	<i>Elanus leucurus</i>	R	NA	LC
Gavilán Ceniciento	<i>Circus cinereus</i>	R	NA	LC
Carancho	<i>Caracara plancus</i>	R	NA	LC
Chimango	<i>Milvago chimango</i>	R	NA	LC
Halconcito Colorado	<i>Falco sparverius</i>	R	NA	LC
Tero Común	<i>Vanellus chilensis</i>	R	NA	LC
Chorlito Cabezón	<i>Oreopholus ruficollis</i>	Mp	NA	LC
Gaviota Capucho Café	<i>Larus maculipennis</i>	R	NA	LC
Paloma Doméstica**	<i>Columba livia</i>	R	NA	LC
Paloma Picazuró	<i>Columba picazuro</i>	R	NA	LC
Paloma Manchada	<i>Columba maculosa</i>	R	NA	LC
Torcaza	<i>Zenaida auriculata</i>	R	NA	LC
Torcacita	<i>Columbina picui</i>	R	NA	LC
Loro Barranquero	<i>Cyanoliseus patagonus</i>	R	AM	LC
Cotorra	<i>Myiopsitta monachus</i>	R	NA	LC

Pirincho	<i>Guira guira</i>	R	NA	LC
Lechuza de Campanario	<i>Tyto alba</i>	R	NA	LC
Lechucita Vizcachera	<i>Athene cunicularia</i>	R	NA	LC
Carpintero Campestre	<i>Colaptes campestris</i>	R	NA	LC
Bandurrita Común	<i>Upucerthia dumetaria</i>	Mp	NA	LC
Hornero	<i>Furnarius rufus</i>	R	NA	LC
Leñatero	<i>Anumbius annumbi</i>	R	NA	LC
Pico de Plata	<i>Hymenops perspicillatus</i>	Mp	NA	LC
Golondrina Ceja Blanca	<i>Tachycineta leucorrhoa</i>	Mp	NA	LC
Ratona Común	<i>Troglodytes aedon</i>	R	NA	LC
Calandria Grande	<i>Mimus saturninus</i>	R	NA	LC
Cachirla Común	<i>Anthus correndera</i>	Mp	NA	LC
Misto	<i>Sicalis luteola</i>	R	NA	LC
Chingolo	<i>Zonotrichia capensis</i>	R	NA	LC
Cachilo Ceja Amarilla	<i>Ammodramus humeralis</i>	R	NA	LC
Verdón	<i>Embernagra platensis</i>	R	NA	LC
Loica Común	<i>Sturnella loyca</i>	R	NA	LC
Cabecita Negra Común	<i>Carduellis magellanica</i>	R	NA	LC
Gorrión	<i>Passer domesticus**</i>	R	NA	LC
References: R=resident, Mp=Partial Austral Migrant , Ma=Austral Migrant, MN= Nearctic Migrant				
References of threatening status in Argentina: NA= not threatened, VU=vulnerable; AM= threatened ,EN= In danger.				
References of threatening status UICN/Birdlife International: LC: Minor Preoccupation, NT: Nearly Threatened, VU: Vulnerable, EN: In danger, CR: Critical Danger				

Table 1. Birds registered within the site during the investigation

In the area of the future Wind Farm there are 6 species which potentially may be present or use the aerial space, and that are at least under one of the categories of danger at a national level (MAyDS and AA, 2017), and three of which are also under international categories of danger (UICN/BirdLife International) (Table 2)

Common Name	Scientific Name	Migratory Status	Status en Argentina	UICN- BirdLife
Batitú	<i>Bartramia longicauda</i>	Mn	VU	LC
Loica Pampeana	<i>Sturnella defilippi</i>	Mp	AM	VU
Gavilán Planeador	<i>Circus buffoni</i>	R	VU	LC
Monjita Castaña	<i>Neoxolmis rubetra</i>	Mp	VU	LC
Espartillero Pampeano	<i>Asthenes hudsoni</i>	Mp	AM	VU
Tachurí Canela	<i>Polystictus pectoralis</i>	Ma	VU	NT
References: R=resident, Mp=Parcial Austral Migrant , Ma=Austral Migrant,Mn= Nearctic Migrant				
References of threatening status in Argentina: NA= not threatened, VU=vulnerable; AM= threatened, EN= In danger.				
References of threatening status UICN/Birdlife International: LC: Minor Preoccupation, NT: Nearly Threatened, VU: Vulnerable, EN: In danger, CR: Critical Danger				

Table 2. Threatened Species of potential presence in the site.

Preliminary Recommendations. Birds

It is suggested that through a methodology of counting points and vantage points *investigations should continue in order to establish the presence, abundance, seasonal presence and use of the aerial space for all the species in general, with particular emphasis in the ones mentioned below:*

Ñandú (*Rhea americana*) vulnerable (VU). Present in the site and the fields around the site, point census will permit to establish their presence and abundance during the construction stage.

Cauquén Común (*Chloephaga picta*) Threatened(AM). Observed in very low numbers in the field where they stay little time and continue their migratory journey. Samplings with frequency are suggested to establish their abundance and use of the aerial space (see schedule).

Loro Barranquero (*Cyanoliseus patagonus*) Threatened (AM).Present in the site, sampling along a year may permit the use of the aerial space.

Monjita castaña (*Neoxolmis rubetra*) vulnerable (VU). Partial Austral Migrant has been registered in bands in the proximities during its migratory path. Samplings will permit to establish if the species is present in the site.

Gavilán Planeador (*Circus buffoni*) vulnerable (VU). Present in the zone, point census

will permit to establish their presence and abundance during the pre-construction stage.

Loica Pampeana (*Sturnella defilippii*) in danger(EN). The counting points during the whole year will permit to establish their presence and potential use for nesting in the place.

Tachurí Canela (*Polystictus pectoralis*) vulnerable (VU). It is austral migrant; it is not discarded that it may be present in the area. The point census will permit to establish their presence and abundance during the pre-construction stage.

Batitú (*Bartramia longicauda*). threatened (AM) Species that breeds in the Northern Hemisphere and visits us during summer. Its presence is known in the zone and it is not discarded that it might be present in the site or use the aerial space.

Espartillero Pampeano (*Asthenes hudsoni*) threatened (AM) inhabitant of pajonales and espartillares it is not discarded that it might be present in the zone. The point census will permit to establish their presence and abundance during the pre-construction stage.

The numerous Migrant species known in the zone, either austral ones and those which come from the Northern Hemisphere, require special attention to establish if they use the site or it is within their migratory path.

Mammals

Even though terrestrial mammals are not in danger of collision with the wind turbines, these might be affected by the different human activities like truck circulation, traffic, constructions, maintenance works, noise generation, the increase of human presence, etc. To this it must be added the infrastructure of the turbines, new roads or electrical wiring that may affect the species within or near the Wind Park, making them leave the area or avoid it, what is translated as a shrinking in the life quality of their habitat or directly the loss of it, as a result of the current exploitation of the place.

How this impact is manifested on the animals will depend on the ecological role of each species.

The site where the Energeti Wind Center I Project is developed, presents a strong anthropic alteration and it is anticipated that the mammals present in the zone are those which tolerate high environmental modifications and the human presence.

These species are confirmed to be present in the site:

El **Zorro gris** (*Lycalopex gymnocercus*), present in the site, it is abundant and highly distributed, even in places modified by humans. It is hunted for being considered harmful for the sheep cattle and fowl. (Canevari y Vaccaro, 2007).

The **Liebre europea** (*Lepus europaeus*), present in the site, it is a species introduced which lives in all kind of environment and generally prefers open zones. It has crepuscular and night habits and it is also seen in the day in places where it is not observed or pursued (Canevari y Vaccaro, 2007).

The Vizcacha (*Lagostomus maximus*) present in the site. It is abundant and without any problem of conservation mainly in the national range, but in the Buenos Aires Province has almost disappeared in the North because it is hunted for its meat and for being considered harmful for agriculture. (Canevari y Vaccaro, 2007). Photo 1 and 2.

The **Peludo** (*Chaetophractus villosus*) present in the site, it lives in mainly open zones like grasslands, scrublands and savannahs, and also in environments modified by men. It is abundant and well distributed, of mainly nightly habits, although in winter can also be active during the day (Canevari y Vaccaro, 2007). Photo 3.

The **Mulita Pampeana** (*Dasypus hybridus*) present in the site, it is active day and night and in Argentina it is considered potentially vulnerable.

The Gato **del Pajonal** (*Leopardus colocolo*) present in the site, it lives in the grasslands, pastures, shrubs, and open woods. It is quite tolerant to modified environments. It suffers high pressure of hunting because it is considered extremely harmful. It is considered Vulnerable in the national level and near threat (NT) by UICN.



Photo 1. Viscacha Caves photographed in the site.



Photo 2. Vizcacheras photographed in the site.



Photo 3. Peludos Caves photographed in the site.

Preliminary Recommendations for mammals

Bats constitute the group of mammals for which there is enough information of the negative impact Wind Farms have over the different species as a result of collisions. For many places the knowledge about what species are present is scarce and/ or in other cases null. As a first measure it is recommended to implement a monitoring program during the pre-construction stage for over one-year term, which permits to establish the presence and abundance of the different species. Such study will be done through

the use of methodologies of ultrasound samplings.

In the case of the **Xenatros** (peludos and mulitas) as a first measure it is recommended to prepare a ***protocol of procedures*** for the staff that works in the Wind Park, which established the steps to take in case of encounters with the species of the group in order to guarantee the survival of the animals that inhabit the site during the construction stage.

In the case of the **Gato de Pajonal** it is suggested to investigate the zone, to establish its abundance in the place and to spread the voice among the population in order to raise awareness about the situation.

FINAL CONSIDERATIONS

Wind energy has undeniable value in the production of clean energy and as a tool to fight against climate change, nevertheless, it is not exempt of negative impacts over the fauna where two of the most affected groups are birds and bats.

Collisions, inconveniences and displacements, the barrier effect and habitat destruction are the main renown negative factors. It is important to do a correct sampling during the pre-construction stage to obtain truthful information that permits to take measures in order to minimize potential impacts.

There is a tentative schedule of monitoring 2018/2019 for the Energetic Wind Center I which counts with:

- For birds, the sampling will be monthly. It is advisable to double efforts (fortnightly) during the migration season of Cauquenes (period May/August).
- For the group of chiropters, the use of ultrasound with monthly sampling.
- It is advised that the information obtained be contrasted with that of other wind projects neighbor to the site with the aim of enriching the Adaptation Management Plan of each of them in a way that the results permit taking better decisions having in mind the synergy effect at a regional level.

ACTIVITY	2018											MONTH											2019
	S	O	N	D	E	F	M	A	M	J	J	A	S	O	N	D	E	F	M	A	M	J	J
1) Summer Migrant Birds	█																						
2) Winter Migrant Birds (Cauquenes, etc)												█											
3) Bats	█																						

BIBLIOGRAPHY LOOKED UP

Abba, A.M. y M.H. Cassini. 2010. Ecological differences between two sympatric species of armadillos (*Xenarthra*, Mammalia) in a temperate region of Argentina. *Acta Theriologica* 55: 35– 44.

Atienza, J.C., I. Martín Fierro, O. Infante, J. Valls y J. Domínguez. 2011. Directrices para la evaluación del impacto de los parques eólicos en aves y murciélagos (versión 3.0). SEO/BirdLife, Madrid.

Belenguer C., Delhey K.J.V., Di Martino S., Petracci P.F. y A. Scorolli. 1993. Lista comentada de la avifauna observada en la región de Bahía Blanca (Provincia de Buenos Aires). Trabajo presentado en la Ira Reunión de Ornitología de la Cuenca del Plata, Puerto Iguazú, Misiones.

Bibby, C.J., Hill, D.A., Burgess, N.D. y S. Mustoe. 2000. *Bird Census Techniques*. Academic Press, 302 pp.

BirdLife International. 2016. Ficha técnica: *Rhea americana*. Consultado en <http://www.birdlife.org> el28/06/2018.

BirdLife International. 2016. Ficha técnica: *Phoenicopterus chilensis*. Consultado en <http://www.birdlife.org> el08/06/2018.

Burkart, R., Bárbaro, N.O., Sanchez, R.O y D.A. Gomez. 1999. Eco-regiones de la Argentina. Administración de Parques Nacionales. BuenosAires.

Canale, A., J. Tella y S.M. Zalba. 2015. Cambios estacionales en la abundancia de una población urbana de loro barranquero (*Cyanoliseus patagonus*) en Bahía Blanca, Buenos Aires. Reunión Argentina de Ornitología XVI, La Plata, Buenos Aires,Argentina.

Canevari, M. y O. Vaccaro. 2007. Guía de mamíferos del sur de América del Sur. Buenos Aires: L.O.L.A.

Darrieu, C.A. y A.R. Camperi. 2001. Nueva lista de las aves de la provincia de Buenos Aires. *Cobiobo* Nro. 2, *ProBiota* Nro. 3, Buenos Aires, Argentina. 50pp.

Di Giacomo, A. G. 2007. Caldenal del Sudoeste de Buenos Aires. En Di Giacomo, A. S., M. V. De Francesco y E. G. Coconier (editores). 2007. Áreas importantes para la conservación de las aves en Argentina. Sitios prioritarios para la conservación de la biodiversidad:58-59. *Temas de Naturaleza y Conservación* 5. CD-ROM. Edición Revisada y Corregida. *Aves Argentinas/Asociación Ornitológica del Plata*, Buenos Aires.

Doiny Cabré y R. Lejarraga. 2015. *Aves de Sierra de la Ventana*. Guía de campo.

Mazar Barnett J. y M. Pearman. 2001. Lista comentada de las Aves Argentinas. Lynx Edicions, Barcelona, España.

McNab B. K. 1980. Energetics and the limits to a temperate distribution in armadillos. *Journal of Mammalogy* 61: 606–627. doi: 10.2307/1380307

MAyDS y AA (Ministerio de Ambiente y Desarrollo Sustentable y Aves Argentinas). 2017. Categorización de las aves de la Argentina (2015). Informe del Ministerio de Ambiente y Desarrollo Sustentable y Aves Argentinas, edición electrónica. C. A. Buenos Aires, Argentina. XX pp.

Narosky, S., Di Giacomo, A.G. y B.M. López Lanús. 1990. Notas sobre aves del sur de Buenos Aires. *Hornero* 13:173-178.

Narosky, T. y Di Giacomo, A.G. 1993. Las Aves de la provincia de Buenos Aires, distribución y estatus. Asociación Ornitológica de la Plata. Vazquez Mazzini Editores y LOLA, Buenos Aires
Petracci, P.F. 2002. Lugares donde observar aves en Bahía Blanca y zonas aledañas. *Nuestras Aves* 43: 4-8.

Petracci, P., M. Carrizo, R. Scoffield y C. Doiny Cabré. 2018. Lista de las Aves del sudoeste de la provincia de Buenos Aires, Argentina / Checklist of the birds of the southwest of Buenos Aires province, Argentina. Editorial del Autor. Bahía Blanca, 24 págs.

Petracci, P.F., H. Ibáñez, A. Scorolli, N. Cozzani, D. Blanco, V. De la Balze, D. Forcelli, S. Goldfeder, D. Mac Lean, M. Carrizo, M. Zamorano, J. Cereghetti, R. Sarriá y J. Veiga. 2008. Monitoreo poblacional de cauquenes (*Chloephaga* spp.) migratorios en las provincias de Buenos Aires y Río Negro. Una actualización sobre su estado crítico de conservación. Secretaría de Ambiente y Desarrollo Sustentable de la Nación, Buenos Aires.

S.D. Muñoz, N.O. Maceira y K. Pütz. 2015. First insights into the migratory pattern of an Upland Goose (*Chloephaga picta*) based on satellite tracking. *Ornitología Neotropical* 26: 245- 253.

Sutherland, W.J., I. Newton y R. E. Green. 2004. *Bird Ecology and Conservation. A Handbook of Techniques.* Techniques in Ecology & Conservation. Biology, Oxford.

Willmott, J., E.A. Costello, C. Gordon, G. Forcey, S. Casto, G. Beaulac, E. Pilla. 2012. Bird y Bat Collision Risks y Wind Energy Facilities. Inter-American Development Bank. Environmental Safeguards Unit. Discussion paper No. IDB-DP-354.

Chapter 04

Specific Studies

Chapter 04 Specific Studies

Index

1. INTRODUCTION 3
2. Annex C.04 3

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date: 15/08/2018 Rev: A Page 3 of 3

Chapter 04 Specific Studies

1. INTRODUCTION

in this document a series of specific studies done are incorporated having in mind the project range and the Wind Center environment receiver.

The particular characteristics of the project and the environment receiver vulnerability determine which are the environmental factors over which it is necessary to focus the study and analyze in detail.

2. Annex C.04

Below there are some reports, whose goal is to evaluate potential environmental impacts (positive or negative) of the Wind Energy Center.

- C.4.1. Analysis of the Surface affected by the Wind Power Plant
- C.4.2. Analysis of Noise Effects produced by wind turbines
- C.4.3. Analysis of Shadow Effects produced by wind turbines
- C.4.4. Analysis of Low Frequency Fields and the Corona Effect
- C.4.5. Analysis of the Production Intake of "Clean" Electric Energy into the Regional System
- C.4.6. Analysis of the Possible Contribution in Reduction of Emission Factors
- C.4.7. Analysis of Energy Production Effect on the saving of Methane Tankers.

Annex C.04.1

Analysis of the Surface affected by the Wind Power Plant

Analysis of the Surface affected by the Wind Power Plant

Index

1.	INTRODUCTION	3
2.	ESTIMATE ON THE AFFECTED SURFACE	4
2.1.	PREPARATORY STAGE OF THE SITE AND CONSTRUCTION	4
2.2.	OPERATIVE STAGE AND MAINTENANCE	5
3.	SERVICES	5

ANALYSIS OF THE SURFACE AFFECTED BY THE WIND POWER PLANT

1. INTRODUCTION

This report contains an estimation of the actual surface that will be affected by different facilities that make up the Project, during the stages of preparation, construction and set-up of the Wind Energy Center.

Wind Energy Parks have very different characteristics in reference to the occupation of surfaces, compared to other power stations of different electric energy. They require an ample surface for a good advantage of wind resources, but the actual use of the affected surface is much less than the required ground for an adequate exploitation of that source of renewable energy.

There is actual advantage of the soil in the sites where they will be installed: The Transformer Station and mounting areas for the Wind Energy Turbines, cable ducts, internal roads and the workroom (see Figure N° 1)




Figure N° 1 Google Image with the location of the facilities necessary for the project.

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	Study on Environmental Awareness Addendum	
<p>Doc. N° CEEN-IA-2655-08/18</p>	N° 2 Wind Energy Centre 1	<p>Date: 15/08/2018 Rev: A Page 4 of 5</p>

2. ESTIMATE ON THE AFFECTED SURFACE

2.1. PREPARATORY STAGE OF THE SITE AND CONSTRUCTION

In Table N° 1 there is an estimate of the occupation of the minimal surface that will be affected during the preparation and construction stages of the Wind Energy Center.

Table N° 1 Minimum Affected Surface. PREPARATORY STAGE OF THE SITE AND CONSTRUCTION

#	Description	Dimensions	Affected surface (m2)
1	Area assigned to the Transformer Station. Perimeter Fencing.	110m x 100m	11,000
2	Underground Collector Network Area (underground ducts in 33 KV, PAT earthing system and communication links).	22.000m x 2,5 ¹ m	55,000
3	Area assigned to foundations, mounting platforms and temporary storage of components for the Wind Energy	30 x 3680 m ²	110,400
4	Area assigned for internal roads.	18,000m x 6m	108,600
5	Area assigned for the workroom.	Gl.	11,000
Total			296,000

Note (1): It is assumed that 2.5 meters is the width that comprises the trench and the ridge of soil adjacent during the duct construction stage, up to its final cover.

For illustration, in Figure N° 2 there are two photographs where the area occupied by the internal road, the foundation and the mounting platform of a wind energy turbine can be seen; Source: Acciona Energía (internet).



Figure N° 2 Photographs where the area occupied during the installation of a wind energy turbine can be observed.

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	Study on Environmental Awareness Addendum	
<p>Doc. N° CEEN-IA-2655-08/18</p>	N° 2 Wind Energy Centre 1	<p>Date: 15/08/2018 Rev: A Page 5 of 5</p>

So we can conclude that during the preparation and construction stage the total surface affected by the work will be of approximately 29.6 has.

2.2. OPERATIVE STAGE AND MAINTENANCE

In Table N° 2 there is an estimate of the occupation of the minimal surface that will be affected during the preparation and construction stages of the Wind Energy Center.

Table N° 2 Minimum Affected Surface. Operative Stage and Maintenance

#	Description	Dimensions	Affected surface (m2)
1	Area assigned to the Transformer Station. Perimeter Fencing.	110m x 100m	11,000
2	Area assigned for each wind energy turbine.	Gl.	110,400
3	Area assigned for internal roads.	18,000m x 6m	108,600
Total			230,000

Total affected area (hectares)	23,0
Percentage of the total surface (950 hectares)	2.42%

It is not considered the surface that will be affected by underground ducts, because once the trench is covered the surface can be used to continue with the rural activity.

3. CONCLUSION

During the preparation and construction stage of the Wind Energy Center the total surface affected will be of approximately 29.6 hectares and during the operative stage, of 23 hectares.

As indicated in the Addendum EIA, the permanent occupation of the area affected by infrastructure works of the Wind Energy Center will be of 2.4% of the total surface of the site (3 portions of the field).

Rural production (agriculture and farming) and the installation of the new venture with energetic purposes match completely; the field can support both activities without difficulties.

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p align="center">Study on Environmental Awareness Addendum N° 2</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>		<p>Date: 15/08/2018 Rev: A</p>

Annex C.04.2

ANALYSIS OF NOISE EFFECTS PRODUCED BY WIND TURBINES

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p style="text-align: center;">Study on Environmental Awareness Addendum N° 2</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>		<p>Date: 15/08/2018 Rev: A</p>

ANALYSIS OF NOISE EFFECTS PRODUCED BY WIND TURBINES

1. INTRODUCTION

This Annex contains the Analysis of Sound Effects produced by Wind Energy Turbines in the environment of the Wind Energy Center.

This report was developed using the calculation software “WindPRO 3.2.701 by EMD International A/S, *Noise*”. The same was provided by Energética Argentina S.A. and elaborated by Nordex Energy Spain, S.A:

DECIBEL - Main Result

Calculation: 20180911_AR_Tres Picos_Noise study_R05-V11

Noise calculation model:

ISO 9613-2 General

Wind speed at 10 m height (m/s)

8.8 m/s

Ground attenuation:

General, terrain specific

Ground factor for porous ground: 0.2

Meteorological coefficient, C0:

0.0 dB

Type of demand in calculation:

1: WTG noise is compared to demand (DK, DE, SE, NL etc.)

Noise values in calculation:

All noise values are mean values (Lwa) (Normal)

Pure tones:

Fixed penalty added to source noise of WTGs with pure tones Model:

5.0 dB(A)

Height above ground level, when no value in NSA object:

2.0 m; Don't allow override of model height with height from NSA object

Uncertainty margin:

0.0 dB; Uncertainty margin in NSA has priority


Deviation from "official" noise demands. Negative is more

restrictive, positive is less restrictive.:

0.0 dB(A)

WTGs

Easting	Southing	Z	Row data/Description	WTG type			Power, rated [kW]	Rotor diameter [m]	Hub height [m]	Noise data			Wind speed [m/s]	LwA,ref [dB(A)]	Pure tones
				Valid	Manufact.	Type-generator				Creator	Name				
1	569.039	5,755,805	240.0 A01	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
2	569.420	5,755,927	250.0 A02	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
3	564.750	5,754,326	211.5 A03	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
4	565.227	5,754,284	240.0 A04	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
5	566.485	5,754,771	225.7 A05	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
6	566.887	5,754,779	230.0 A06	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
7	567.288	5,754,817	258.7 A07	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
8	567.951	5,754,808	244.1 A08	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
9	568.472	5,755,252	260.0 A09	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
10	568.993	5,754,979	247.1 A10	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
11	569.445	5,755,023	240.0 A11	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
12	563.917	5,753,448	214.0 A12	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
13	564.267	5,753,642	220.0 A13	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
14	564.666	5,753,614	232.5 A14	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
15	565.065	5,753,652	210.6 A15	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
16	565.463	5,753,689	206.5 A16	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
17	566.052	5,753,745	217.0 A17	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
18	565.681	5,754,244	235.2 A18	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
19	566.649	5,753,853	240.0 A19	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
20	567.053	5,753,891	240.0 A20	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
21	567.476	5,753,931	255.5 A21	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
22	567.952	5,753,976	253.9 A22	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
23	568.388	5,754,017	250.0 A23	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
24	568.809	5,754,057	250.0 A24	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
25	569.224	5,754,103	247.0 A25	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
26	564.598	5,752,770	220.0 A26	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
27	565.305	5,753,015	210.0 A27	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
28	567.486	5,753,028	250.0 A28	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
29	568.065	5,753,088	250.0 A29	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No
30	568.474	5,753,340	255.9 A30	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	USER	Level 0 - Calculated - DG200506-A - 09-2014	8.8	107.1	No



Calculation Results

Sound level

Noise sensitive area

No.	Name	Easting	Southing	Z	Imission height [m]	Demands Sound level			Demands fulfilled ?	
						Noise [dB(A)]	From WTGs [dB(A)]	Distance to noise demand [m]	Noise	
A	D01	564,967	5,752,909	210.0	2.0	50.0	49.7	42	Yes	
B	D02	566,441	5,754,409	230.0	2.0	50.0	49.9	15	Yes	
C	D03	568,357	5,754,859	250.0	2.0	50.0	49.8	38	Yes	
D	D04	569,320	5,753,611	250.0	2.0	50.0	46.6	238	Yes	

Project:

20180525_AR_TresPicos_MAG_05

Licensed user:

NORDEX ENERGY SPAIN, S.A.

Av. Innovation City 3 ES-31621

Sarriguren

+34 948720535

Iker Mateos / imateos@nordex-online.com

Calculated:

11/09/2018 8:55/3.2.701

DECIBEL - Main Result


Calculation: 20180911_AR_Tres Picos_Noise study_R05-V11

Distances (m)

WTG	A	"	"	"D"
1	4997	2949	1166	2212
2	5379	3343	1507	2318
3	1433	1693	3646	4625
4	1399	1221	3182	4148
5	2402	365	1874	3063
6	2680	579	1472	2699
7	3004	940	1070	2363
8	3537	1562	409	1818
9	4216	2199	409	1847
10	4527	2615	647	1407
11	4952	3066	1100	1418
12	1180	2701	4659	5405
13	1013	2305	4267	5053
14	766	1945	3895	4654
15	749	1571	3506	4255
16	924	1215	3122	3858
17	1370	770	2560	3271
18	1514	778	2746	3694
19	1929	594	1982	2682
20	2306	802	1624	2284
21	2709	1140	1280	1871
22	3170	1572	972	1416
23	3596	1986	843	1017
24	4010	2394	921	678
25	4421	2800	1150	501
26	394	2467	4301	4796
27	354	1798	3566	4059
28	2522	1732	2028	1924
29	3103	2093	1795	1359
30	3533	2297	1524	888

DECIBEL - Map 8.8 m/s

Calculation: 20180911_AR_Tres Picos_Noise study_R05-V11



Noise [dB(A)]	
	35
	40
	45
	50
	55



Map: Blank map , Print scale 1:75,000, Map center UTM (south)-WGS84 Zone: 20 East: 566,681 North: 5,754,348

New WTG

Noise sensitive area

Noise calculation model: ISO 9613-2 General Wind Speed (m/s) 8.8 m/s
 Height above sea level from active line object

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N° 2</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>		<p>Date: 15/08/2018 Rev: A</p>

Annex C.04.3

ANALYSIS OF SHADOW EFFECTS PRODUCED BY WIND TURBINES

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>Awareness Addendum N° 2</p>	<p>Date: 15/08/2018 Rev: A</p>

ANALYSIS OF SHADOW EFFECTS PRODUCED BY WIND TURBINES

1. INTRODUCTION

This Annex contains the Analysis of Sound Effects (flickering) produced by Wind Energy Turbines in the environment of the Wind Energy Center.

This report was developed using the calculation software “WindPRO 3.2.712 by EMD International A/S, *Shadow*”. The same was provided by Energética Argentina S.A. and elaborated by Nordex Energy, USA Inc.

SHADOW - Main Result

Calculation: 20180924_AR_Tres Picos_Noise R05-V11_Shadow

Assumptions for shadow calculations

Maximum distance for influence

Calculate only when more than 20 % of sun is covered by the blade Please look in WTG table

Minimum sun height over horizon for influence 3 °
 Day step for calculation 1 days
 Time step for calculation 1 minutes

Sunshine probability S (Average daily sunshine hours) [CHILLAN]

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
12.12	10.93	8.47	5.90	3.60	2.75	3.90	5.07	6.52	8.57	9.95	10.25

Operational hours are calculated from WTGs in calculation and wind distribution: WASP_TresPicos2_120m_20y

Operational time

N	NNE	ENE	E	ESE	SSE	S	SSW	WSW	W	WNW	NNW	Sum
1,770	584	308	294	528	382	401	490	615	719	881	1,701	8,674

Idle start wind speed: Cut in wind speed from power curve

A ZVI (Zones of Visual Influence) calculation is performed before flicker calculation so non visible WTG do not contribute to calculated flicker values. A WTG will be visible if it is visible from any part of the receiver window. The ZVI calculation is based on the following assumptions:

Height contours used: Height Contours: TresPicos_SRTM_UTM WGS84_10m_MAG_O


Obstacles used in calculation

Eye height for map: 1.5 m

Grid resolution: 1.0 m

All coordinates are in

UTM (south)-WGS84 Zone: 20



WTGs

Easting	Southing	Z	Row data/Description	WTG type			Noise data					
				Valid	Manufact.	Type-generator	Power, rated [kW]	Rotor diameter [m]	Hub height [m]	Calculation distance [m/s]	RPM [dB(A)]	
1	569.039	5,755,805	240.0 A01	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
2	569.420	5,755,927	250.0 A02	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
3	564.750	5,754,326	211.5 A03	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
4	565.227	5,754,284	240.0 A04	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
5	566.485	5,754,771	225.7 A05	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
6	566.887	5,754,779	230.0 A06	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
7	567.288	5,754,817	258.7 A07	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
8	567.951	5,754,808	244.1 A08	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
9	568.472	5,755,252	260.0 A09	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
10	568.993	5,754,979	247.1 A10	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
11	569.445	5,755,023	240.0 A11	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
12	563.917	5,753,448	214.0 A12	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
13	564.267	5,753,642	220.0 A13	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
14	564.666	5,753,614	232.5 A14	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
15	565.065	5,753,652	210.6 A15	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
16	565.463	5,753,689	206.5 A16	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
17	566.052	5,753,745	217.0 A17	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
18	565.681	5,754,244	235.2 A18	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
19	566.649	5,753,853	240.0 A19	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
20	567.053	5,753,891	240.0 A20	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
21	567.476	5,753,931	255.5 A21	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
22	567.952	5,753,976	253.9 A22	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
23	568.388	5,754,017	250.0 A23	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
24	568.809	5,754,057	250.0 A24	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
25	569.224	5,754,103	247.0 A25	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
26	564.598	5,752,770	220.0 A26	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
27	565.305	5,753,015	210.0 A27	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
28	567.486	5,753,028	250.0 A28	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
29	568.065	5,753,088	250.0 A29	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5
30	568.474	5,753,340	255.9 A30	Yes	Acciona	Windpower	AW132/3300/-3.300	3.300	132.0	120.0	1.713	12.5

Project:

20180525_AR_TresPicos_MAG_05

Licensed user:

NORDEX USA Inc.

300 South Wacker Drive, Suite 1500

US-CHICAGO, IL 60606

312 386 4137

Gabriel / gantonietti@nordex-online.com

Calculated:

9/24/2018 12:36 PM/3.2.712

SHADOW - Main Result

Calculation: 20180924_AR_Tres Picos_Noise R05-V11_Shadow

Shadow receptor-Input

No.	Easting	Southing	Z	Width	Height	Elevation	Degrees from	Slope of	Direction mode	Eye height
			[m]	[m]	[m]	a.g.l.	south cw	window		(ZVI) a.g.l.
			[m]	[m]	[m]	[m]	[°]	[°]		[m]
A	569,318	5,753,619	250.0	1.0	1.0	1.0	0.0	90.0	Fixed direction	2.0
B	568,361	5,754,858	250.0	1.0	1.0	1.0	0.0	90.0	Fixed direction	2.0
C	566,442	5,754,395	228.5	1.0	1.0	1.0	0.0	90.0	Fixed direction	2.0
D	564,962	5,752,916	210.0	1.0	1.0	1.0	0.0	90.0	Fixed direction	2.0

Calculation Results

Shadow receptor

No.	Shadow, worst case		Shadow, expected values	
	Shadow hours per year [h/year]	Shadow days per year [days/year]	Max shadow hours per day [h/day]	Shadow hours per year [h/year]
A	61:18	94	0:50	24:38
B	130:18	164	1:12	55:42
C	81:32	164	1:00	36:33
D	60:54	66	1:08	24:11

Total amount of flickering on the shadow receptors caused by each WTG

No.	Name	Worst case [h/year]	Expected [h/year]
1	A01	12:00	12:00
2	A02	12:00	12:00
3	A03	3:10	1:15
4	A04	10:46	4:26
5	A05	12:00	12:00
6	A06	4:50	1:55
7	A07	11:53	4:52
8	A08	121:45	52:13
9	A09	12:00	12:00
10	A10	12:00	12:00
11	A11	12:00	12:00
12	A12	12:00	12:00
13	A13	12:00	12:00
14	A14	12:00	12:00
15	A15	2:54	1:06
16	A16	12:00	12:00
17	A17	12:00	12:00
18	A18	32:29	1:22 PM
19	A19	12:00	12:00
20	A20	12:00	12:00
21	A21	26:33	1:26 PM
22	A22	8:07	3:55
23	A23	12:00	12:00
24	A24	12:00	12:00
25	A25	12:00	12:00
26	A26	60:54	24:11
27	A27	12:00	12:00
28	A28	12:00	12:00
29	A29	10:01	8:51
30	A30	42:30	5:06 PM

Total times in Receptor wise and WTG wise tables can differ, as a WTG can lead to flicker at 2 or more receptors simultaneously and/or receptors may receive flicker from 2 or more WTGs simultaneously.

Project:

20180525_AR_TresPicos_MAG_05

Licensed user:

NORDEX USA Inc.

300 South Wacker Drive, Suite 1500

US-CHICAGO, IL 60606

312 386 4137


Gabriel / gantonietti@nordex-online.com

Calculated:

9/24/2018 12:36 PM/3.2.712

SHADOW - Map

Calculation: 20180924_AR_Tres Picos_Noise R05-V11_Shadow



0 500 1000 1500 2000 m

Map: Blank map , Print scale 1:50,000, Map center UTM (south)-WGS84 Zone: 20 East: 567,000 North: 5,754,340

New WTG

Shadow receptor

Flicker map level: Height Contours: TresPicos_SRTM_UTM WGS84_10m_MAG_OPT.map (1)

Annex C.04.4

ANALYSIS OF LOW FREQUENCY FIELDS AND THE CORONA EFFECT

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date: 15/08/2018 Rev: A Page 2 of 12</p>

ANALYSIS OF LOW FREQUENCY FIELDS AND THE CORONA EFFECT

Index

1.	INTRODUCTION	3
2.	ANALYSIS FO CE, CM, RI AND RA OF ELECTRODUCTS IN 132 KV	4
2.1	ELECTRIC FIELD	4
2.2	MAGNETIC FIELD	5
2.3	RADIO INTERFERENCE AND AUDIBLE NOISE	6
2.3.1.	RADIO INTERFERENCE	7
2.3.2.	AUDIBLE ACOUSTIC NOISE	8
3.	ANALYSIS OF ELECTROMAGNETIC FIELDS OF LOW FREQUENCY IN THE WIND ENERGY PARK	9
3.1	ELECTRIC FIELD	10
3.2	MAGNETIC FIELD	10
4.	CONCLUSIONS	11
5.	BIBLIOGRAPHIC REFERENCIAS	11

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date: 15/08/2018 Rev: A Page 3 of 12</p>

ANALYSIS OF LOW FREQUENCY FIELDS AND THE CORONA EFFECT

1. INTRODUCTION

This report contains the analysis of low frequency fields and the corona effect produced by new facilities required for the functioning of the Wind Energy Center I.

One of the most important aspects from the environmental point of view are the electromagnetic effects originated about the environment by electric facilities of high and medium tension. Particularly, in the present Annex electric field intensity (CE), magnetic induction (CM) and the audible noise levels (RA) and electromagnetic interference (RI) in case of the presence of the corona effect, framed in the Resolution 77/98 of the Energy Secretary.

Estimations has been done using the "ad hoc" program developed by ICON srl that permits to determine the levels of the electric field, magnetic fields, radio interference and noise audible by the corona effect. The results of this program have been validated with results provided by the declared literature in the References of the present report.

A very important aspect to highlight in this study is that the Original Project has been modified, identifying two relevant evaluation zones with greater access to the public which are:

- a) The zone where the High Tension Line is developed and where it will be vinculated to the Wind Energy Park.
- b) The zone where the collector network of 33 KV of Wind Energy Park is developed.

Given that the Project area is crossed by the High Tension Line of 132 KV between the Transformer Station in Bahía Blanca and the Transformer Station in Tornquist, where the Wind Energy Park will be vinculated, it contains an analysis of the electromagnetic fields in it to demonstrate that the new Project will not modify them adversely.

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date: 15/08/2018 Rev: A Page 4 of 12</p>

2. ANALYSIS FO CE, CM, RI AND RA OF ELECTRODUCTS IN 132 KV

In the Project area the presence of magnetic fields under the existence of high tension electric ducts determine the electric and magnetic field levels of the aerial Electric ducts of 132 KV that crosses the Project area. It corresponds to LAT of 132 KV of TRANSBA which is developed between the Transformer Station in Bahía Blanca and the Transformer Station in Torquist.

Considering the opening of the electric duct of 132 KV already in existence and the hollow of supply pipeline at the Transformer Station of the WInd Energy Center, the electromagnetic fields are of the same magnitud that the ones corresponding to LAT 132 KV.

2.1 ELECTRIC FIELD

In point 4.1 of the Annex, Resolution 77/98 of the Energy Secretary , it is established that the superior limit value of the electric field not disrupted, for the lines in condition of nominal tension and the conductor at maximum annual temperature, is 3 KV/m in the hedge of the serving strip and out of it , at 1.0 meter from the ground.

In the same point in the Resolution 77/98, where the limit for the level of the electric field is specified, in any position, it should be the same of the contact currents for a pilot case: child on wet land and big vehicle on dry pavement should not exceed the security limit of FIVE THOUSAND AMPERES (5mA)".

With the electric fiel levels obtained it can be assured that the contact current for the pilot case that is especified in Resoluton 77/98 will result sensibly less to 5mA.

The electric field originated by electric ducts 132 KV are only dependent on the simple three-face system existing that crosses the field where the Project is developed.

In Figure N° 1 it is shown the distribution of the electric field of the electric duct in existence, which corresponds to the LAT of 132 KV, between the Transformer Station Bahía Blanca (ETBB)- Transformer Station of the Wind Energy Park (ET PE ENERGETICA I) and between the latter and the Transformer Station Tornquist of TRANSBA (ETTO).




Figure N° 1

It is important to highlight that the Electric Fields originated by the High Tension Line will not be modified by the presence of the new Wind Energy Park given that they depend on the electric duct tension and not of the charge.

2.2 MAGNETIC FIELD

In point 4.2 of the Annex, Resolution 77/98 of the Energy Secretary, it is established that the superior limit value of the magnetic induction for the lines in conditions of maximal tension defined by the thermal limit of the conductors, is 25 μ T (250mG) in the hedge of the serving strip and out of it at 1.0 meter from the ground.

The aerial electric duct of 132 KV in existence creates magnetic fields that are function of the charging current which circulates through the conductors. Given that the estimation done in the magnetic field is done at a maximum capacity of transmission, the presence of the Wind Energy Park will not influence in the levels indicated.

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date: 15/08/2018 Rev: A Page 6 of 12</p>

given that the modification in the power flows by the High Tension Line will never reach the limits admissible of transmission considered for the estimation of the magnetic field level originated by such electric duct.

In Figure N° 2 it is shown the magnetic field originated by the circulation of current obtained at the maximum transmission capacity of each electric duct of High Tension.

The magnetic field levels obtained are registered under the limit admitted established in the point 4.2 of the Annex I of the Resolution 77/98 of the Energy Secretary.




Figure N° 2

2.3 RADIO INTERFERENCE AND AUDIBLE NOISE

The electromagnetic interference originated by an aerial line of transmission is characterized by being a highly unstable phenomenon. The main cause for this instability is the superficial state of

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date: 15/08/2018 Rev: A Page 7 of 12</p>

the conductors that is unpredictable and unmeasurable in practical terms, for the analytic prediction of the interference level is ideal.

Naturally it also depends on weather conditions by which the course of the electric duct develops. On the other hand, the dependence of the geometric configuration of the conductors and semi-conductors if it has them, quantity of three-phase systems, heights with respect to the ground, disposition of guard cable/s and size of the conductors are all parameters perfectly modeled.

The radio interference levels (RI) and audible noise (RA) increase with the level of tension, and experience shows that they are really relevant for operative tensions superior to 300 KV.

In this particular case, the area affected by the Project only has one Line of 132 KV in existence which progresses between ETBA and ET Tornquist and is over which the estimation of RI and RA levels are done, and they are verified as of the admitted limits established by Resolution 77/98.

2.3.1. RADIO INTERFERENCE

In the point 2.1 of Annex I of the Resolution 77/98 of the Energy Secretary it is established that the maximum level of radio interference is 54 dB during 80% in daytime, measured at a minimum horizontal distance of 5 times the height of the aerial line in its suspension poles or towers.

The level distribution of radio interference determined for a frequency of 1.0 MHz and under the condition of wet conductor, is that shown in Figure N° 3.




Figure N° 3

As can be seen the radio interference levels calculated are fewer that the limit of 54 dB established by the Resolution 77/98 for a distance of 5 times the height of the line.

These are levels in the existing facilities which the presence of the Energy Park will not affect.

2.3.2. AUDIBLE ACOUSTIC NOISE

In the point 2.2 of Annex 1 of the Resolution 77/98 of the Energy Secretary it is established that the maximum level of audible noise will not exceed 53 dB. This value must not be passed 50% of the times in conditions of wet conductor in the limit of the serving strip from the center to the course of the LAT.

In Figure N° 4 it is shown the distribution of the audible noise estimated of the aerial LAT at different distances of the axis of the course and at 1.0 meter height for the case L50-rain.




Figure N° 4

As can be seen the audible noise levels RA(dBA) estimated, originated by the corona effect under the presumed conditions, are lower than the maximum level established as limit by the Resolution 77/98 of the Energy Secretary.

It is important to say that the Wind Energy Park I has no influence over these audible noise levels.

3. ANALYSIS OF ELECTRO MAGNETIC FIELDS OF LOW FREQUENCY IN THE WIND ENERGY PARK. Respect to the electromagnetic contamination inside the Wind Energy Park, the most affected zone is the one corresponding to the course of the medium tension collector network.

The collector network of medium tension was designed through an underground course of cables of 33 KV single -pole wires insulated in reticulated polyethylene XLPE.

3.1 ELECTRIC FIELD

Wires of 33 KV adopted in the project have a metallic shield, which is connected to earth (or potential zero) in its both ends. For this designed condition, the cables of the collector network will have a confined electric field within them, because the metallic shield constitutes a "Farady cage", so the field intensity will be null in the outer side of the wires.

3.2 MAGNETIC FIELD

In Figure N° 5 there are the results of the estimation of the magnetic field at 1.0 meter over ground level and for different conditions of mounting.

In the zones where the collectors course only have one three-phase wiring system, the magnetic induction is the lowest, being under 2 μT in the parts which group 5 wind energy turbines.

In the zones with three-system grouping it is increase the magnetic field level reaching levels of 4 μT , under the limit level of 25 μT established in current regulation.




Figure N° 5

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date: 15/08/2018 Rev: A Page 11 of 12</p>

4. CONCLUSIONS

From the results obtained in the estimations done, under the presuppositions adopted, for the environmental parameters analyzed in the present Annex to the Addendum N° 2 of the Environmental Impact Study, the aerial electric duct of 132 KV in existence and the perimeter of the Transformer Station of 132 /33 KV of the Wind Energy Park, meet all the requirements in the Resolution 77/98 of the Energy Secretary.

Considering the inside of the Transformer Station of the Wind Energy Park, there are no evaluations given that it is not possible for the operation and maintenance personnel to access to it.

Respect to the levels of magnetic induction of the collector network of the Wind Energy Plant are verified maximum limits accepted by ENRE reaching maximum levels of 4 μ T, quite under the limit of 25 μ T accepted by current regulations in Argentina. While, with respect to the electric field of the collector network of medium tension, because it is underground its effect is null. On the other hand, in normal operation the wind energy turbines, the underground collector network does not add radio interference, corona or audible noise effects.

5. BIBLIOGRAPHIC REFERENCIES

1. Electric Power Research Institute. Transmission Line Reference Book, 345 kV and Above / Second Edition Revised. California. 1982.
2. Peek, F. Dielectric Phenomena in High Voltage Engineering. McGraw-Hill. New York. 1929.
3. IEEE Std. 656. "IEEE Standard Procedures for Measurement of Audible Noise from Overhead Transmission Lines". 1992.
4. IEEE Std. 644. "IEEE Standard Procedures for Measurement of Power Frequency Electric and Magnetic Fields from AC Power Lines". 1994.
5. IEEE Std. 539. "IEEE Standard Definitions of Term Relating to Corona and Field Effects of Overhead Power Lines".1990.
6. IEEE Corona and Field Effects Subcommittee Report Radio Noise Working Group, "A Survey of Methods for Calculating Transmission Line conductor Surface Voltage Gradients". IEEE Transactions on Power Apparatus and Systems. Vol. 1. No.6. USA. 1979.
7. ANSI/IEEE Std. 430. "IEEE Standard Procedures for the Measurement of Radio Noise from Overhead Power Lines and Substations". 1986.

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date: 15/08/2018 Rev: A Page 12 of 12</p>

8. N. H. Malik, "A review of the charge simulation method and its application", IEEE Trans. Electrical Insulation Vol. 24, February 1989.
9. IEEE, "Magnetic Field from Electric Power Lines-Theory and Comparison Measurements", IEEE Trans. on Power Delivery, Vol. 3, N° 4, October 1988.
10. IEEE Subcommittee Report, "A comparison of methods for calculating audible noise of high voltage transmission lines", IEEE Trans. PAS. Vol.101, N° 10, October 1982, pp.4090-4099
11. IEEE Radio Noise Subcommittee, "Comparison of radio noise predictions methods with CIGRE/IEEE survey results", IEEE Trans. PAS Vol.92, May/June, 1973.
12. IEEE Subcommittee, "Review of Technical Consideration on Limit to Interference from Power Lines and Stations", IEEE Trans. PAS Vol. 99, Jan/Feb, 1980, P. 365-388.

Annex C.04.5

ANALYSIS OF THE PRODUCTION CONTRIBUTION OF "CLEAN" ELECTRIC ENERGY TO THE REGIONAL SYSTEM

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date: 15/08/2018 Rev: A Page 2 of 4</p>

**ANALYSIS OF THE PRODUCTION CONTRIBUTION
OF "CLEAN" ELECTRIC ENERGY TO THE REGIONAL
SYSTEM**

Index

1. INTRODUCTION..... 3

2. CONTRIBUTION OF "CLEAN" ELECTRIC ENERGY PRODUCTION TO THE REGIONAL SYSTEM..... 3

3. CONCLUSION 5

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	Study on Environmental Awareness Addendum N°	
<p>Doc. N° CEEN-IA-2655-08/18</p>	2 Wind Power Centre 1	<p>Date: 15/08/2018 Rev: A Page 3 of 4</p>

ANALYSIS OF THE PRODUCTION CONTRIBUTION OF "CLEAN" ELECTRIC ENERGY TO THE REGIONAL SYSTEM

1. INTRODUCTION

The objective of the present study is to evaluate the effect of the contribution of electric energy from wind resource, related to the regional consumption of electricity and particularly of the Tornquist District.

It is to be named that the Energetic Wind Center I will add its generation to the National Interconnected System through the new Transformer Station (132/33/13,2 KV) which will be located between ET Bahía Blanca and ET Tornquist, as of an opening in the LAT of 132 KV which TRANSBA S.A. operates, in the province of Buenos Aires.

2. CONTRIBUTION OF "CLEAN" ELECTRIC ENERGY PRODUCTION TO THE REGIONAL SYSTEM

To determine what the production of electric energy that the Wind Energy Center might add in the regional energetic demand represents, it has been taken as reference the demand supplied by the Cooperativas Eléctricas in: Chasicó, Felipe Sola, Sierra de la Ventana, Saldungaray and Tornquist.

In Table N° 1, it is shown the data provided by the electric energy demand and the number of clients by category of the Tornquist District. Following, in Table N° 2, it is shown the results of the relation estimates in percentages between electric energy production of the WInd Energy Center and the annual demand supplied by the local Cooperativas.

Table N° 1

Supplier Entity-	Electric Energy Demand (MW-h/Año) - Per Category and Total								
	Residencial	Comercial	Industrial	5-	A. Public	Official	Elect. Rural	Other	Total
Coop. de Chasico	181	261			61		663		1,167
Coop. de Felipe Sola	27	4				11	181		223
Coop. de S. de la Ventana	2,686	3,927			708		193		7,515
Coop. de Saldungaray	1,252	869		29	432		260	67	2,908
Coop. de Tornquist	6,577	7,119	751		1,448		1,802		17,696
Total	10,723	12,181	751	29	2,649	11	3,098	67	29,509

Supplier Entity-	Number of Users- Per category and total								
	Residencial	Comercial	Industrial	5-	A. Public	Official	Elect. Rural	Other	Total
Coop. de Chasico	77	39			2		146		264
Coop. de Felipe Sola	14	2				3	48		67
Coop. de S. de la Ventana	1,601	402			1		22		2,026
Coop. de Saldungaray	659	132		1	1		58	18	869
Coop. de Tornquist	3,823	670	1		4		400		4,898
Total	6,174	1,245	1	1	8	3	674	18	8,124

Note (1): Data available in the WEB, <http://www.energia.gob.ar> (Year 2016).

Table N° 2

Structure of the regional market			
Category	Clients (1)	% Energy	MWh (1)
Residential	6,174	36.3%	10,723
Comercial	1,245	41.3%	12,181
Industrial	1	2.5%	751
Sanitary Services	1	0.1%	29
Public Lightning	8	9.0%	2,649
Official	3	0.0%	11
Rural Electrification	674	10.5%	3,098
Others	18	0.2%	67
Total	8,124	100.0%	29,509

Total Generated by the Wind Energy Center "Energetica I"	436,905
Total demand of the Tornquist District (%)	6.75
Total to be contributed to the Regional Electric	93.25

3. CONCLUSION

As it can be seen in Table N° 2 the average individual consumption per year of electric energy of the "Residential Category Users" is of 1.736,80 KW-h/Year (144.73 KW-h/Month). This is to say that the production of the Wind Energy Center might supply 251.557 users of this category.

Besides, it can be said that the 30 wind energy turbines might supply the total demand (annual) provided by the Electric Cooperativas of the Tornquist District (6.7% of the generation) and the rest might be supplied by the Regional Electric System (93.25%); see Figure N° 1.




Figure N° 1 Effect of the Contribution of "Clean" Electric Energy in the Regional System

Annex C.04.6

Analysis of the Possible Contribution in Reduction of Emission Factors

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	Study on Environmental Awareness Addendum N°	
<p>Doc. N° CEEN-IA-2655-08/18</p>	2 Wind Power Centre 1	<p>Date: 15/08/2018 Rev: A Page 2 of 6</p>

ANALYSIS OF THE POSSIBLE CONTRIBUTION IN REDUCTION OF EMISSION FACTORS

Index

1.	INTRODUCTION	3
2.	OBJECTIVE	3
3.	METHODOLOGY	3
3.1.	DATA USED FOR THE ESTIMATION	4
3.1.1.	Lower calorific value of the fuels	4
3.1.2.	Emission factors by fuel type	4
3.1.3.	Thermal generation and fuel consumption	4
4.	ANALYSIS OF THE POSSIBLE CONTRIBUTION IN REDUCTION OF EMISSION FACTORS	6

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Power Centre 1</p>	<p>Date: 15/08/2018 Rev: A Page 3 of 6</p>

ANALYSIS OF THE POSSIBLE CONTRIBUTION IN REDUCTION OF EMISSION FACTORS

1. INTRODUCTION

The present report contains the analysis of the reduction in emission factors that 30 Nordex-Acciona wind energy turbines, model AW132/3300 TH120 of the Wind Power Center may add, compared to the production of the Thermal Centre whose energetic resources are: natural gas, fuel oil, coal or gas oil.

2. OBJECTIVE

The objective of the present report is to estimate the earning in tones equivalent in petrol, of carbon dioxide (CO₂), oxide nitrogen (NO₂), sulfur dioxide (SO₂) and the particle material (PM) associated, which is obtained through the electric energy generation that the 30 wind energy turbines of the Wind Power Center may produce.

3. METHODOLOGY

In a Thermal Power Center in operation emissions may be determined by measurements in the funnel or in the evacuation ducts of the pollutants generated in the several processes, or through the theoretical estimate applying emission factors.

For this case in particular, we will use the emission of factors. This factor is a medium value which determines the quantity of a pollutant emitted to the atmosphere, by a certain activity associated to the emission of that pollutant.

Energy balances which express in tones equivalent to petrol (TEP) and the conversion made are done in base of the lower calorific power (LCP) of each of the fuels.

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	Study on Environmental Awareness Addendum N°	
Doc. N° CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date: 15/08/2018 Rev: A Page 4 of 6

3.1. DATA USED FOR THE ESTIMATION

3.1.1. Lower calorific value of the fuels

In Table N° 1 the lower calorific power of fuel (LCP) used in the thermal park in our country.

Table N° 1 Calorific power of each fuel.

Natural Gas	8.300 Kcal/m ³
Fuel Oil.	9.800 Kcal/Kg.
Coal (National Calorific Equivalent)	5.400 Kcal/Kg.
Gas Oil.	10.200 Kcal/Kg.

3.1.2. Emission factors by fuel type

For estimations of CO₂ emissions, the specific emission factors for each type of fuel are adopted, indicated in Table N° 2, which are the ones recommended by EPA (Environmental Pollution Agency) and the guides of IPCC (Intergovernmental Panel and Climate Change) in tnC/TJ. In our country CAMMESA and the Energy Secretary use them.

Table N° 2 CO₂ emission factors for each fuel.

Natural Gas	15,3 (EPA)
Fuel Oil.	21,25 (EPA)
Sub-bituminous Coal	26,2 (IPCC)
Gas Oil.	20,2 (EPA)

3.1.3. Thermal generation and fuel consumption

In Table N° 3 there are the consumption data of fuel in the thermal park statistically obtained by CAMMESA for 2014.

Table N° 3 Fuel Consumption Data for 2014.

Year N°	Thermal generation-GWh	Natural Gas (dam ³)	Fuel Oil. (tn)	Coal (tn)	Gas Oil.
2014	82,606	14,355,409	2,717,285	1,004,377	1,484,395

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	Study on Environmental Awareness Addendum N°	
Doc. N° CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date: 15/08/2018 Rev: A Page 5 of 6

With the data obtained in the previous table and the values indicated by the LCP of the fuels, it is obtained the tonnes equivalent in petrol and the carbon dioxide production associated (see Table N° 4).

Table N° 4

Denomination	Natural Gas	Fuel Oil tn	Gas Oil tn	Mineral Coal tn
TEP	502,204	11,032,749	2,465,763	1,401,973
CO ₂ (tn)	2,182,023	27,993,218	8,689,363	4,696,440

It can be seen that in 2014 to produce 82,606 GWh of thermal generation, there has been an emission of 43,561,044 Tn of CO₂. This equals an average specific emission of 0.527 Tn of CO₂/MWh

For the most severe estimation of the three parameters regulated by Resolution SE N° 182/95, oxide nitrogen (NO_x), sulfur dioxide (SO₂) and particle material (PM) ratios of emissions are adopted corresponding to the situation of the situation of the Generation Park of the National Interconnected System(SIN),

In Table N° 5 the parameters mentioned and the respective national values equivalent per unit of generated energy are presented.

Table N° 5

Denomination	National Equivalent Kg / MW-h Generated
NO _x	0.95
SO ₂	0.34
MP	0.03

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	Study on Environmental Awareness Addendum N°	
<p>Doc. N° CEEN-IA-2655-08/18</p>	2 Wind Power Centre 1	<p>Date: 15/08/2018 Rev: A Page 6 of 6</p>

4. ANALYSIS OF THE POSSIBLE CONTRIBUTION IN REDUCTION OF EMISSION FACTORS

With the aim of determining the reduction of emission factors of the energetic venture, it is used the values of energy produced by the Wind Energy Center in a one-year period and the data of the specific average emission obtained by data available in CAMMESA.

The reduction of emission of pollutants in the atmosphere during one-year period that might add the Wind Energy Center is shown in Table N° 6.

Table N° 6

Total generated MW-h/Año	Total of CO2 Tn	Total of NOx Tn	Total of SO2 Tn	Total of MP Tn
436,905	230,396	415	149	13

Note: Data corresponding to the energetic production have been taken by Energética Argentina S.A.

In Table N° 7 there are estimated the emission factors of pollutants which might be avoided during the service life of the Wind Energy Center, making a contribution to the Global Climate Change Program. For the estimation it is taken a period of 20 years of sustained production, according to data provided by the wind energy turbine manufacturer.

Table N° 7

Total generated MW-h/ 20 Years	Total of CO2 Tn	Total of NOx Tn	Total of SO2 Tn	Total of MP Tn
8,738,100	4,607,920	8,300	2,980	260

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p style="text-align: center;">Study on Environmental Awareness Addendum N° 2</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>		<p>Date: 15/08/2018 Rev: A Page 1 of 7</p>

Annex C.04.7

ANALYSIS OF ENERGY PRODUCTION EFFECT ON THE SAVING OF METHANE TANKERS.

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N° 2</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>		<p>Date: 15/08/2018 Rev: A Page 2 of 7</p>

ANALYSIS OF ENERGY PRODUCTION EFFECT ON THE SAVING OF METHANE TANKERS.

Index

1.	OBJECTIVE.....	3
2.	INTRODUCTION.....	3
3.	METHODOLOGY	5
4.	DATA USED FOR THE ESTIMATION	5
4.1.	Lower calorific value of the fuels(LCV)	5
4.2.	Data of the Stations of Combined Cycle and conversion factors.....	6
4.3.	DATA ON THE CAPACITY OF METHANE TANKERS	6
5.	ESTIMATION OF EARNING OF METHANE TANKERS.....	6
6.	CONCLUSION	7

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N° 2</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>		<p>Date: 15/08/2018 Rev: A Page 3 of 7</p>

ANALYSIS OF ENERGY PRODUCTION EFFECT ON THE SAVING OF METHANE TANKERS.

1. OBJECTIVE

The objective of the present study is to evaluate the quantity of methane tankers that are required to produce the same quantity of electric energy that might generate the Wind Energy Center, whose energetic production will be injected in the National Interconnected System (SADI).

2. INTRODUCTION

It is public knowledge that in the Argentine Republic due to the lack of Natural Gas (GN) we had to resort to the importation of Liquid Natural Gas (GNL) due to reasons which are out of reach in this investigation.

The provision of GN to the Gas Natural Transportation System in the Argentine Republic is obtained from the gas in a liquefied state and it is transported by special ships called "methane tankers". It is regasified in a vessel designed for that especial purpose (regasification vessel). Then, in a gasified state, it is introduced in the national network through a gas duct which connects the quay with th network mentioned. Regularly methane tankers bring the GBI from producer countries to the quay, where they stay moored to the regasification vessel.

Such venture is localized in the distal end of the estuary of Bahía Blanca, at 1 Km East of Puerto Cuatrerros, at 6Km approximately of Puerto Galván on the Northerm shore, at approximately 2 Km from General Cerri , and at 10 Km approximately from TGS Plant of General Cerri. In General, Cerri TGS processes natural gas, using the facilities of Puerto Galván for the storage, reception and delivery of the products obtained.

In Figure N° 1 there are two photographs with the site of the regasification vessel and the methane tankers in action.



Figure N° 1.

Mainly the GN obtained from GNL is used as primary fuel by the Thermal Power stations. As an example, Figure N° 2 illustrates the Thermal Power Station Luis Piedra Buena of 2x310 MW, installed in the city of Bahía Blanca (Buenos Aires Province).



Figure N° 2 Photograph of the Thermal Power Station Luis Piedra Buena.

In Figure N° 3 it is illustrated the Power Station of Combined Cycle, as such it is installed in Loma de la Lata (Neuquén Province) with three TG of 375 MW and one TV of 178 MW.



Figure N° 3 Photograph of the Power Station of Combined Cycle, Loma de la Lata.

3. METHODOLOGY

The methodology used is based on determining the volume of Natural Gas consumed per year in one of the most efficient Thermal Power Stations as those of combined cycle, considering that it has such a size that generates the energy equivalent to that produced by the Wind Energy Park analyzed

Then, the volume of Natural Gas is changed into Liquid Natural Gas. Finally, from the volume of GNL that the methane tankers transport, it may be determined the quantity of vessels that can be earned considering that the production of a Power Station of Combined Cycle is substituted by one Wind Energy Station.

4. DATA USED FOR THE ESTIMATION

4.1. Lower calorific value of the fuels(LCV)

In Table N° 1 it is indicated the LCV of the GN used in the thermal park in our country for the Stations with Natural Gas as fuel.

Table N° 1 LCV of the GN

Natural Gas.	8.300 Kcal/m ³
--------------	---------------------------

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N° 2</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>		<p>Date: 15/08/2018 Rev: A Page 6 of 7</p>

4.2. Data of the Stations of Combined Cycle and conversion factors.

For the estimation of the natural gas consumption in a Station of Combined Cycle, the following data were considered:

Table N° 2 Data of the Station of Combined Cycle.

Specific consumption thermal generation (Heat rate)	MJoule/MWh	10,962
Calorific value GN	Kcal/m ³	8,300
Conversion factor	MJoule/Kcal	0.004184

4.3. DATA ON THE CAPACITY OF METHANE TANKERS

In Table N° 3 typical transport capacity of Methane Tankers is indicated. Table N° 3 Transport capacity of GNL of Methane Tankers.

	Capacidad (m3)	Eslora (m)	Manga (m)	Calado (m)
Qmax	266.000	345	55	13,7
Qflex	216.000	315	50	13,6
170's	170.000	290	45,8	12,9
151's	151.000	291	43,4	12,4
138's	138.000	284,4	43,4	12,4

5. ESTIMATION OF EARNING OF METHANE TANKERS.

In Table N° 4 the results of the estimation is presented.

Table N° 4

Characteristic data of the Wind Energy Station Energética I		
Installed Power Annual	MW	99.75
Energy generated.	MWh	436,905

Characteristic data of the Station of Combined Cycle (fuel: gas)		
Annual energy produced	MWh	436,905
Specific consumption thermal generation	MJoule/MWh	10,966
Calorific value GN	Kcal/m ³	8,300
Conversion factor	MJoule/Kcal	0.00418554
Volume of GN/Year required by C.C.C.	m ³ /year	137,914,590
Volume of GN/Year required by C.C.C.	m ³ /year	226,089

Requirement of GNL		
Volume GNL transported/methane tanker	m ³ /Tanker	138.000
Number of tankers	Tankers/GNL	1,64

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N° 2</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>		<p>Date: 15/08/2018 Rev: A Page 7 of 7</p>

6. CONCLUSION

It can be concluded that to produce the annual electric energy estimated of the Wind Energy Station, may avoid the importation of approximately 1,6 Methane Tankers per year, whose associated cost is approximately U\$S 25.906.000. Apart from all the implications that it takes. For example: a) Reduction of environmental risk intrinsic of this activity; b) reduction of energy expenditure associated to the charging, transportation and discharging of GNL related to the methane tanker, among others.

CHAPTER 05

ADDENDUM REPORT N°2

CHAPTER 05

ADDENDUM REPORT N°2

Index

1.	PRESENTATION	4
2.	ANTECEDENTS	4
3.	INTRODUCTION	5
4.	PUBLIC ENQUIRY DOCUMENTS	7
5.	DESCRIPTIVE MEMORY OF THE UPDATED PROJECT	7
5.1.	GENERAL ASPECTS RELATED TO THE UPDATED PROJECT	7
5.1.1.	Electric Energy Transport System	7
5.1.2.	Wind Farm	7
5.1.3.	Workroom	8
5.1.4.	Waste disposal and liquid effluent treatment	8
5.1.5.	Treatment of dangerous and/or chemical substances, others that will be stored in the site	
5.1.6.	Areas of lending materials	14
5.1.7.	Collection of aggregates	15
5.1.8.	Underground Water Resource Operation	15
6.	Evaluation Methodology on environmental impacts	16
7.	Information research	16
8.	Environmental Baseline	17
9.	Identification and Evaluation on environmental impact	17
9.1.	Identification of the stages of the Project	18
9.2.	Identification of the activities or actions of the Project	18
9.3.	Identification of the components of the Influential area	21
10.	Analysis of environmental impact related to the updated Project	21
10.1.	Environmental Impact related to the localization of components	23
10.1.1.	Soil use affectation and use of the space	23
10.2.	ENVIRONMENTAL IMPACT RELATED TO THE PRESENCE AND OPERATION OF WIND ENERGY TURBINES	25

10.2.1.	Analysis of Noise Effects produced by wind turbines	26
10.2.2.	Analysis of shadow effects (flickering) produced by wind turbines	28
10.2.3.	Affectation by Low Frequency Fields and the Corona Effect	30
10.2.4.	Affectation of flora and fauna	32
10.2.5.	Affectation of fauna	33
10.2.6.	Affectation of the landscape quality	34
10.2.7.	Affectation of aerial security	36
10.2.8.	Emission factors avoided to the atmosphere	37
10.2.9.	"Clean" electric energy production	38
10.2.10.	Wind Energy Turbine production on the earning of methane tankers	39
11.	Mitigation Actions and Environmental Management Plan	39
11.1.	Environmental Monitoring Program	41
12.	Conclusion	43
13.	Annex C.05	44

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date: 15/08/2018 Rev: A Page 4 of 44

CHAPTER 05

ADDENDUM REPORT N°2

1. PRESENTATION

The present document corresponds to the Addendum Report N° 2 to the Environmental Impact Study (EIA) of the Wind Energy Station Energética I, to be developed next to the Paraje García del Río, in the Tornquist District, Buenos Aires Province, Argentine Republic, presented according to File OPD N° 2145-9512/16.

It emerges due to modifications presented in the Project presented by the company Energética Argentina S.A. in the Addendum (13/06/2016) and Declared Environmentally Suitable according to Resolution OPDS N° 2351/16- August 2nd, 2016.

2. ANTECEDENTS

Down below there is a comparative chart with the general description of the Original project and the sequence of modifications (Addendum and Addendum N°2) of the Wind Energy Station.

Wind Energy Station Tres Picos and II EIA Original (09-022012) SOGESIC S.A	Wind Energy Station Energética I Addendum to EIA (13-06-2016)	Wind Energy Station Energética I Addendum N° 2to EIA (15-08-2018) Energética Argentina S.A.
Transport System of the Wind Energy Plant.		
Connection Point to the SADI PDI N°: 1140. Opening un "U" of the Line in 132 KV between ET Bahía Blanca (500/132 KV) and ET Tornquist (132/33/13.2 KV). Between Pickets N° 151 and N° 152	Connection Point to the SADI Idem to EIA Original.	Connection Point to the SADI Idem to the Adenda at EIA.
Transformer Station (MT/AT) 132/33 /13.2 KV 2x110/110/15 MVA.	Transformer Station (MT/AT) Idem to EIA Original.	Transformer Station (MT/AT) 132/33 /13.2 KV 1x110/110/40 MVA. On machine left on cold reserve.
Wind Farm		
Comprised by <u>73 wind energy turbines</u> Trademark: Guodian United Power. Model: UP77-1500 KW. Rotor 77 meters Hub Height 80 meters Complementary:	Comprised by <u>31 wind energy turbines</u> Trademark: Siemens. Model: SWT 113-3,2 MW. Rotor 113 meters Hub Height 92.5 meters Complementary:	Comprised by <u>30 wind energy turbines</u> Trademark: Nordex-Acciona. Model: AW132/3300, TH120. Rotor 132 meters Hub Height 120 meters Complementary:

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Power Centre 1	Date: 15/08/2018 Rev: A Page 5 of 44

3. INTRODUCTION

The wind Energy Station Energética I is a private venture, property of the company Energética Argentina S.A. which will require an investment of approximately U\$S 119.000.000 (VAT not included).

Summary Chart with the update general description of the Project.

General Description of the Project - Wind Power Plant Energética 1	
Electrical Energy Transportation System and its bonding to SADI	<p>1- Transformer Station (MT/AT)</p> <p>Level of Tension: 132/33/13,2 KV.</p> <p>Total Power Installed: 1x110/110/40 MVA.</p> <p>Length of access way to the ET: 1,585 Km (from neighborhood street).</p> <p>2- Opening of Overhead Power Line in High Voltage and bonding to ET (MT/AT)</p> <p>Level of Tension: 132 KV.</p> <p>Place of bonding to SADI: Between pickets N°151 and N°152 of the LAT in 132 KV (existing) between EE.TT Bahía Blanca and ET Tornquist.</p> <p>Length of the installation hollow: 50 meters</p>
Wind Farm	<p>3- Total Power Installed: 99.75 MW.</p> <p>It will be conformed of 30 wind turbines Nordex-Acciona, model AW132/3300TH120 class IEC JIB and their complementary.</p> <p>Complementary:</p> <ul style="list-style-type: none"> ▪ 2 Poles with meteorological stations; of 48 meters and 82 meters (existing). ▪ 30 foundations for wind turbines. ▪ 30 set-up platforms for wind turbines. ▪ 18,0 Km of internal ways to be constructed and 5,0 Km of access ways to realign. ▪ 22.0 Km of underground tubes for: <ul style="list-style-type: none"> - Collector of Electrical Energy Network in 33 KV- - Earthing System. <p>System of Communication Network.</p>

In Table N° 1 there is a summary of the Wind Energy Park (Addendum) and Updated.

Table N° 1

	Addendum Project at EIA	Addendum Project N° 2 at EIA
Wind Farm	<ul style="list-style-type: none"> ▪ Total Power Installed: 99.2 MW. ▪ Quantity of wind power turbines 31 units ▪ Total Production of energy 430.276 MW-h/Year. ▪ Capacity Factor. 49,5%. ▪ Number of sites- total surface. 3 - 950 has. ▪ Internal Electricity Network of the P.E and connection to ET Transformation level of each wind energy turbine 0.69 KV a 33 KV. Tension level of the service network. 33 KV. Configuration. Radial. Line type. Underground. ▪ Approximate length of internal roads. 20.8 Km. ▪ Approximate length of underground ducts. 23.1 Km. ▪ Wind Energy Turbine Trademark: Siemens. Model: SWT 113-3,2 MW. Generator Type: Synchronic, PMG Wind Turbine Power. 3.2 MW. Gearbox. None Hub Height 92.5 meters Rotor Diameter 113 meters Rotation speed: Variable - 6.5 ... 15.8 rpm Power Regulation: Pitch, with variable speed. "Swept area": 10.000 m². Noise level. 107,5 dB(A). 	<ul style="list-style-type: none"> ▪ Total Power Installed: 99.75 MW. ▪ Quantity of wind power turbines 30 units ▪ Total Production of energy 436.905 MW-h/Year. ▪ Capacity Factor. 50,0%. ▪ Number of sites- total surface. 3 - 950 has. ▪ Internal Electricity Network of the P.E and connection to ET Transformation level of each wind energy turbine 12 KV a 33 KV. Tension level of the service network. 33 KV. Configuration. Radial. Line type. Underground. ▪ Approximate length of internal roads. 18.0 Km. ▪ Approximate length of underground ducts. 22.0 Km. ▪ Wind Energy Turbine Trademark: Nordex-Acciona. Model: AW132/3300, TH120. Generator Type: Asynchronous, 6 poles, double-fed. Wind Turbine Power. 3.325 MW. Gearbox. SI (oil quantity 1.000 liters) Hub Height: 120 meters Rotor Diameter 132 meters Rotation speed: Variable - 7.0 ... 14.0 rpm Power Regulation: Pitch, with variable speed. "Swept area": 13.720 m². Noise level. 108,5 dB(A). Concrete and iron for foundation volume: 436 m³-33.2

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 7 of 44

4. PUBLIC ENQUIRY DOCUMENTS

Under compliance of current legislation, Energética Argentina S.A. made the required arrangements in the Town Hall of Tornquist, in the Energy and Mining Ministry, and in the National Administration of Argentinian Civil Aviation (ANAC), among others, with reference to the update of permits and authorizations for the modifications done in the Project.

In Annex C.05.1 Documents/Notes associated to the Project are added with the presentation in due course.

5. DESCRIPTIVE MEMORY OF THE UPDATED PROJECT

In Chapter 02 there is an updated technical description of the wind energy turbines selected and the works expected to be developed for the Project.

5.1. GENERAL ASPECTS RELATED TO THE UPDATED PROJECT

5.1.1. Electric Energy Transport System

The installations corresponding to the Transport System of Electric Energy of the Wind Energy Plant will not have any representative modifications with reference to the Project presented in previous environmental studies.

The opening of the electric line in 132 KV will undertake directly to the Transformer Station (MT/AT) with the same technical and building characteristics.

In relation to the total power installed, in the EIA (Addendum) it was predicted the installation of two transformers with power 132/33/13.2 KV- 2x110/110/15 MVA; in the present study (Addendum N°2) it is predicted the installation of one transformer of 132/33/13.2 KV - 1x110/110/40 MVA but one machine is left under cold reserve.

The number of collector circuits between wind energy turbines predicted for the place of the interior Cells in 33 KV are equal to the ones indicated in the EIA (Addendum); that is to say there will be five (5) independent circuits comprised by underground conductors.

5.1.2. Wind Farm

The update of the Project is associated mainly to the change of the wind energy turbines. The machines will have similar power per unit (of 3.2 MW and 3.325 MW) and the Wind Farm will maintain the similar total power already installed (from 99.2MW to 99.75MW); consequently, there will be a reduction of one unit in the machines to be installed.

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 8 of 44

(31 units to 30 units). The modifications related to the Wind Energy Project can be summarized as:

- The different technical characteristics of the Wind energy turbines (technology, dimensions, etc.).
 - The wind energy turbines will be built with towers of concrete (to be developed locally).
 - Lesser number of wind turbines (one less)
 - The different geographical distribution of the wind turbines in the site.
 - Internal Roads: They will have similar technical and building characteristics and they will be 6-meter width of minimal use. The crosses and curves will be slightly affected in their dimensions, due to the higher length of the blades of the new wind energy turbines (long rigid structures of approximately 64.7 meters).
- Road distribution will be different due to the new configuration of the Wind Energy Park.
- Collector Network: The circuits will have similar technical and building characteristics, but they will be distributed differently due to the new configuration of the Wind Energy Park. There are differences in the dimensions of the conductors but with the same number of collector circuits.
 - Foundations for the wind turbines. The bedrock of the base of concrete was modified (octagonal to circular bedrock). According to preliminary studies, the depth of the excavations for the new wind energy turbines will be less (from 3.60m to 2.25m).
 - Mounting Platforms for the wind turbines: They will have a different geometrical configuration but of similar technical and building characteristics.

5.1.3. Workroom

As indicated in the Original Project, the workroom will be installed in the entrance of the Rural Property "Reyrolles".

So said by Energética Argentina S.A. there is no anticipation of installing a concrete plant in any of the three sites where the Wind Energy Center will be built. The concrete elaborated will be bought to third parties and transported to the site through mixer trucks of 6/8 m3 of capacity.

5.1.4. Waste disposal and liquid effluent treatment

Prior to the beginning of the activities the Work Contractor must present **the Waste Disposal and Effluent Treatment Program** which will be adapted to General Programs of the Developer of the Project.

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Energy Station</p>	<p>Date: 15/08/2018 Rev: A Page 9 of 44</p>

For an adequate treatment of solid, semi-solid and liquid waste prior to the beginning of the work, the following will be specified:

- Points of generation.
- Stage of segregation and weighing (in the place of generation or workroom)
- Temporary storage in the workroom (according to the type of waste).
- Transport (authorized operators).
- Treatment (authorized operators).
- Final Disposition (authorized operators)

Waste

According to that indicated by Energética Argentina S.A., all the Contractor companies must classify waste "in situ" in the following way:

- Domestic ones.
- Recyclable and /or reusable ones.
- Dangerous ones.
- Of the construction (inert ones).
- Generated by weeding.




Figure N° 1 Classification of the waste in the work.

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 10 of 44

a. Domestic waste

The gathering of domestic waste will be done no later than every 24 hours, changing the bags in the waste bins. They must be taken to the "Temporal Waste holding tank- DTR", and then be integrated into the zone or departmental collection circuit. The final disposition will be the rubbish dumps in the community of Tornquist or Tres Picos. The transport will be done through an operator with authorized vehicles, or by the company that is in charge of the facility cleaning.

In this respect it is advisable to coordinate the corresponding steps with the Town Hall in Tornquist:

- Secretaria de Desarrollo / Dirección de Medio Ambiente.
+ 54 291 6414250 / 4292272 / 4941075.
agenciadesarrollo@tornquist.gov.ar.

b. Recyclable and /or reusable waste.

As stated by Energética Argentina S.A., for the treatment of recyclable and/or reusable waste, there will be a contract with local recyclable companies. Among others, they are:

- Recycling shed. Lamela Street between Sarmiento Av and Vergara; Tornquist.
- Saldungaray Recycling Plant. Cooperativa de Trabajo "3 R"; Saldungaray.
- De la Bahía Recycling Site. +54 291 4519978 Paunero 349; Bahía Blanca.
- EcoPlant +54 291 456-3808. dgambiental@bb.mun.gba.gov.ar; General Daniel Cerri.

c. Dangerous Waste

Within a sector of the DTR there will be a specific area for the "Hazardous waste". The site will be delimited clearly and will be tagged with the correspondent signal. It must have a fire extinguisher ABC type according to the fire charge of the storage site, and it must have a kit of absorbent material for the place, which will be used in case of potential spill.

The storage in a specific site will be done in especial container bins/units with lids, barrels or buckets with a ring closure or drums with lid. They must be stored in a cover zone, well aired and on an adequate base (non-permeable) to avoid soil affectation. The liquefied waste must have its corresponding retaining container in case of possible spill.

The obligations of the especial waste generator are:

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Energy Station</p>	<p>Date: 15/08/2018 Rev: A Page 11 of 44</p>

- Inscription in the Provincial Registry of Generators and/or Operators of Especial Waste, to get the official certificate of authorization.
- Pay annually the corresponding especial tax.
- Take a registry of operations.
- Contract operators and authorized transport.
- Have the legal documents of transport, certificates of treatment and final disposition.

d. Construction waste (inert ones).

This waste will be generated mainly in different fronts of the work (foundations of the wind turbines, Transformer station, opening of the LAT, crosses of ducts with internal roads, among others). They are:

- Debris in general.
- Concrete debris.
- Parts of crossheads, brackets, linkages, columns, other.
- Parts of wooden formwork for the foundations.

They will be tried to be reused in the work, or storage them in the correct containers or in areas conditioned for that end, with protection of perimeter security.

It will be predicted the quantity needed of dumpers or containers in special sectors where they are continuously generated. All the dumpers will have a legible sign with identification at the side parts, resistant to water and outdoor conditions.

The remaining waste from the construction that are not disposed in dumps, must not interfere with vehicle or staff transportation within the work. They must be piled up with protection of perimeter security and they must be localized correctly to avoid the obstruction of circulation roads.

For the recollection, transport and final disposition it is recommended to coordinate actions with the Town Hall of Tornquist; Area: Secretaria de Desarrollo / Dirección de Medio Ambiente.

e. Waste Generated by weeding.

The mowing of vegetable species will be limited exclusively to the workroom zone, of the Transformer Station, of the foundations of structures of the LAT, of the 30 mounting platforms of the

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 12 of 44

wind energy turbines, of the underground ducts and roads. In this respect the engineering stage has predicted not to affect any zone with tree species.

The weeding actions will be programmed according to the development of the work, following a schedule of activities provided for the project. In this respect some sectors will be conditioned in the frontal part of the work, where the waste generated by vegetable species will be deposited. The storage will be done in clear places, easily-cleaned and accessible for recollection.

Special attention should be paid in the temporary dump places in order to avoid any difficulties (fire). Given the characteristics of the site, it is not expected a great deposit of waste.

It is absolutely forbidden to burn all or any of this type of waste.

It is considered convenient that the waste of vegetable species coming from weeding activities are used as nourishment for the soil that may need them given the characteristics of biodegradability.

For the recollection, transport and final disposition it is recommended to coordinate actions with the Town Hall of Tornquist; Area: Secretaria de Desarrollo / Dirección de Medio Ambiente.

Liquid Effluents

Independently of the origin or type of effluents (rain, industrial or sewage) it is completely forbidden the spill of waste liquids that may pollute natural resources. They must be collected and controlled prior their dumping in any surface of water (superficial or underground). There are three types of liquid effluents which will be generated during the work execution. They are:

- Sewage effluents.
- Effluents from the washing of elements of concrete.
- Effluents from the washing of equipment and machines.

a. Sewage effluents.

These effluents will be generated in the sewage zone of the workroom and in the front part of the the work, due to the use of chemical toilets. Collection and treatment of the sewage effluents will remain under the charge of

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Energy Station</p>	<p>Date: 15/08/2018 Rev: A Page 13 of 44</p>

the company that is giving the service. It must have the corresponding authorization and the permits authorized for the dumping of effluents.

b. Effluents from the washing of elements of concrete.

Even though it is not predicted the installation of a concrete plant in any of the three sites where the Wind Energy Plant will be built, it is presumable that there will be liquids coming from the washing of elements that have been in contact with the concrete and the hoppers of the trucks that transport them. (mixer).

For the above said, it is predicted the installation of a decanting pool (in a place to be defined within the area assigned to the workroom) coated with material agropol non-permeable (see Figure N°2) to avoid the drainage into the soil. The pool will have a level of maximum filling over which it will not be possible to do other cleanings. Once the water is evaporated and having been generated the solid waste, the latter will be disposed as inert waste.

In case of being necessary, the remaining water must be treated adequately through atmospheric trucks according the characteristics of the effluents. Before its final disposition, it will be analyzed to verify previously the values of permitted disposals.

Below there is a typical sketch of a decanting pool. The same must be identified with a sign, it must contain adequate signage and a security perimeter fencing.




Figure N° 2 Sketch of the Decanting Pool.

c. Effluents from the washing of equipment and machines.

The washing of equipment and machines for maintenance will be done outside the site of the work; in service stations or workshops authorized to that end.

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 14 of 44

In case of being necessary a sector will be prepared (inside the workroom) to contain the effluents resulting from the washing of machines, tools, parts or spare parts in general. Measures should be considered to avoid an eventual spill into the soil.

Residual liquids generated are characterized for having oils, grease, hydrocarbons, suspended solids, detergents and the concentration of different pollutants. They should be deposited in drums/containers and they will be disposed considering the legislation for the treatment of dangerous waste.

5.1.5. Treatment of dangerous and/or chemical substances, others that will be stored in the site

Prior to the beginning of the activities the Work Contractor must present **the Waste Disposal and Effluent Treatment Program** which will be adapted to General Programs of the Developer of the Project.

The dumping site for dangerous and/or chemical substances, fuels, oils, greases, paints, thinner, etc, will be placed within the workroom, in a special part assigned for it. It must be delimited and signaled properly with signs and protected from the sun and the rain.

In the case of liquid substances, they must have non-permeable floor and contention with adequate capacity for the control of eventual spills by leakage or accidental spillage.

Substances that might react if they are together, or that may be non-compatible between them, flammable or reactive, won't be placed in the same room. There will be a detail of substances stored, with safety specifications and the actions to take in case of spill or fire.

In the Annex N° C.05.2, a list is added of the dangerous and/or chemical substances, fuels, etc, that will be stored in the site with their corresponding safety data sheets (HDS).

5.1.6. Areas of lending materials

Lending materials needed for filling and leveling jobs of the different works of infrastructure (roads, platforms of mounting energy turbines, Transformer Station, workroom, etc.) will be obtained from an authorized site for extraction (within the site) and the surplus products from excavations. (wind energy turbines). Energética Argentina S.A. is doing the necessary arrangements in this respect in the Town Hall of Tornquist for the temporary permission (construction stage of the work).

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 15 of 44

Prior to the beginning of the activities the Contractor will present the correspondent authorization emitted by the Town Hall in Tornquist or whoever is under concern. Once the works have finished, the affected areas must be restored and adequate to the surrounding geography, in order to favor the recomposition of the vegetable coverage and guarantee the runoff of superficial waters into natural drainages of the soil.

5.1.7. Collection of aggregates

The aggregates required for the elaboration of concrete will be obtained from the quarries of third parties enabled for the development of this activity. The Builder of the work must:

- Verify that the companies providing the aggregates have the corresponding Declaration of Environmental Impact of the quarry, according to what is established in the Code of Mining (National Law N° 24.585) called "On the environmental protection for the mining activity"; and with the permits or licenses (two-yearly update of the DIA) emitted by competent authority in the Province.
- Optimize the use of materials/products needed for the construction of the work, considering the consumption of natural resources.

5.1.8. Underground Water Resource Operation

According to the report by Energética Argentina S.A. the water volume required for the construction of the work and the supply of the workroom will be obtained in the site of the Wind Energy Plant (underground water resource).

The Constructor is obliged to have a global plan of water resource. It must be analyzed the total need of the work, considering the supplying site/s and the determination of maximum flow rate possible to extract, in order not to alter the hydrogeological conditions of the system.

At present the site has a perforation for water extraction of approximately 50 meter-depth, located near the workroom, in the geographical coordinates: 38°21'41.44" South, 62°14'21.96" West.

In this respect the Constructor of the work will be responsible to arrange the permits and concessions needed for the temporary exploitation of the underground water resource.

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 16 of 44

6. EVALUATION METHODOLOGY ON ENVIRONMENTAL IMPACT

As indicated in previous studies (EIA Original and Addendum), the methodology of identification and environmental evaluation of the Project is framed in the integration of new "clean" technologies, coming from a renewable source of energy like the wind, for the generation of electric energy, its transformation, its transport and its final commercialization.

Given that the characteristics of construction and functioning of the Project (Addendum) are similar to the update Project that includes roads, civil works, electromechanical works, electric works and communication links among others, it is assumed that the activities during the preparation, construction and functioning stages are the same as those identified and evaluated in previous environmental studies.

For the evaluation of environmental impact, the following stages have been structured:

- Stage I Data Search
- Stage II Environmental baseline- Characterization of the environment.
- Stage III Identification and Evaluation on environmental impact
Analysis of environmental impact related to the updated Project
- Stage IV Mitigation Actions and Environmental Management Plan
- Conclusion

7. INFORMATION RESEARCH

For the preparation of the present Addendum at the EIA the following information has been provided by Energética Argentina S.A.:

- Updated Project Work.
- Documents with technical specifications of the wind energy turbines (Source: Nordex-Acciona).
- Sound and shadow reports (flickering) produced by wind turbines.
- Original Study of Environmental Impact (EIA 09-02-2012) and Addendum (EIA 13-06-2016).
- Resolution OPDS N° 2351/16 (2nd August, 2016). Corresponds to File N° 2145 - 9512/16.
- Notes, Declarations and documents associated to the Project (Town Hall of Tornquist, Ministry of Energy and Mining, ANAC, among others)

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 17 of 44

The specific information has been taken from the following data:

- Norms and legal regulations applicable to the work.
- Mapping, plans and sketches of the area (in national, provincial and local terms).
- Urban plans of the zone.
- Reports, technical and scientific articles referred to the several topics to evaluate.
- Documents of sector and energetic statistics
- Bibliographical collection. Unpublished reports and personal communications.
- Meetings with local referents.
- Consultation to specialists in person or by mail.
- Consultation to proprietors and administrative personnel in the rural properties near the sites.
- Field work, with "in situ" acknowledgment, which consisted in:
 - Identification of areas with environmental sensitivity, from the natural, ecologic and scenery point of view.
 - Investigation of soil use in the areas of study.
 - Identification of the resources: soil, water, species of flora and fauna, units of vegetation.
 - Superficial and stratigraphic explorations on the site.
 - Photographic study of the zone.

8. ENVIRONMENTAL BASELINE

The rural properties where the Wind Energy Station will be built are the same as those indicated in previous environmental studies. In this respect, in Chapter 03 of the present Addendum, two updated reports of the Environmental Baseline are added, in reference to the Biotic Medium of the surrounding site where the energetic venture will be installed.

9. IDENTIFICATION AND EVALUATION ON ENVIRONMENTAL IMPACT

The identification and evaluation of potential impacts associated to the modifications done in the Engineering Project of the Wind Energy Station have been structured according the following procedure:

- A. Identification of the stages of the Project
- B. Identification of the activities or actions of the Project
- C. Identification of the components of the Influential area

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Energy Station</p>	<p>Date: 15/08/2018 Rev: A Page 18 of 44</p>

D. Analysis of environmental impact related to the updated Project

9.1. Identification of the stages of the Project

The following stages are considered for the development of the Project:

- PREPARATORY STAGE OF THE SITE AND CONSTRUCTION
- Operative Stage and Maintenance
- Closing Stage and leaving the site.

9.2. IDENTIFICATION OF THE ACTIVITIES OR ACTIONS OF THE PROJECT

The considerations taken into account to identify the activities or actions that might have any environmental consequences are based on:

- Technical information of the projected work, updated.
- Environmental regulations where the work is framed on.
- The experience of the consulting team.

The potential contingencies are considered as emergency that must be under control through a specific plan to avoid or minimize environmental damage. During the construction stage of the work these extraordinary events are associated to spills, fires or explosions, accidents at work and of transportation. And during the operative and maintenance stages, these events are associated to withdrawal of service of the Wind Energy Station for adverse weather conditions, fires or explosions, attacks, etc.

The following are different activities that may generate environmental impact and that may come into play in different ways on the receiving medium.

PREPARATORY STAGE OF THE SITE AND CONSTRUCTION

In this stage the following activities or actions which might produce relevant effects on the environment have been predicted.

- a. Mounting and functioning of the workroom.

From the beginning of the work to the final stage the mounting of a workroom. has been predicted. It comprises the following activities:

- Clearance of the soil and vegetal coverage.
- Circulation of light vehicles.

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 19 of 44

- Circulation/use of trucks, heavy machinery and equipment.
- Generation and transport of waste.
- Generation and transport of liquid effluents.
- Generation of jobs.

b. Adaptation and construction of roads (of access and internal of the Wind Park)

It has been predicted the adaptation of 5 km of roads of access and the construction of 18 km (6 meter-width of use).

It comprises the following activities:

- Clearance of the soil and vegetal coverage.
- Filling, compacting and leveling of the soil.
- Circulation of light vehicles.
- Circulation/use of trucks, heavy machinery and equipment.
- Generation and transport of waste.
- Generation of jobs.

c. Preparation of the soil and construction of civil works in general.

It refers to the preparation of the soil and the construction of civil works for: the opening of the LAT in 132 KV the Transformer Station, the foundations of the wind energy turbines and mounting platforms, etc. Besides, the construction of the collector network (22km) for the wiring cables of electric energy, earthing systems and communication links.

It comprises the following activities:

- Clearance of the soil and vegetal coverage.
- Excavations and trenches.
- Filling, compacting and leveling of the soil.
- Circulation of light vehicles.
- Circulation/use of trucks, heavy machinery and equipment.
- Generation and transport of waste.
- Generation of jobs.

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 20 of 44

d. Mounting Platforms for the wind turbines. General wiring system.

Once the civil and infrastructure works have been done, the assemblage and mounting of the wind energy turbines is made. Following that, electric connections, earthing systems and communication links.

It comprises the following activities:

- Circulation of light vehicles.
- Circulation/use of trucks, heavy machinery and equipment.
- Generation and transport of waste.
- Generation of jobs.

e. Dismantling of the workroom, cleaning and re composition of the site.

When the final stage of construction is finished, it comes the dismantling of the workroom, cleaning and restoration of the site, in a way to get it in similar natural conditions of the initial state.

It comprises the following activities:

- Restoration of the area.
- Circulation of light vehicles.
- Circulation/use of trucks, heavy machinery and equipment.
- Generation and transport of waste.
- Generation of jobs.

Operative Stage and Maintenance

In this stage the following activities or actions which might produce relevant effects on the environment have been predicted.

- Presence of the components of the work (opening of LAT ET (MT/AT) and the Wind Energy Farm).
- Analysis of Low Frequency Fields and the Corona Effect
- Generation of noise.
- Generation of vibrations.
- Generation of the shadow effect (flickering)
- Improvement in the electric supply.
- Production of "clean" energy supplied to the regional system-
- Generation and transport of waste.
- Generation of jobs.

9.3. IDENTIFICATION OF THE COMPONENTS OF THE INFLUENTIAL AREA

To establish the potential grade of affectation reached in the natural environment, including its dynamics and interactions, it is proceeded to identify the environmental components of the area of influence potentially affected by the different activities of the work. In Table N°2 the components of the environmental system are identified and analyzed in each medium (physical, biologic, socio-economic and cultural)

Table N° 2 Identification of the components of the Influential area

#	Environmental System		
Components	Natural Medium		Socio-economical Medium
	Physi	Biologic	
	Soil Water	Flora and vegetation Fauna Ecosystems	Social aspects Economic aspects Cultural aspects.

10. ANALYSIS OF ENVIRONMENTAL IMPACT RELATED TO THE UPDATED PROJECT

The particular characteristics of the project and the environment receiver vulnerability determine which are the environmental factors over which it is necessary to focus the study and analyze in detail. For the above said, in Chapter 04 it is incorporated to the Addendum a series of reports of specific studies done that have been done taking into consideration the project range and the environment receiver.

The modifications are:

- New machine selected for the project.
- New quantity and distribution of the wind turbines in the site, considering the re-location of infrastructure works (roads, collector network, foundations and mounting platforms).

In Table N° 3 there is summary comparing the Project (Addendum) and the Updated on (Addendum N° 2) in relation to the characteristics in design of the different components that form each project; and after that, in Table N°4 a comparative summary indicating the percentage of variation.

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	Study on Environmental Awareness Addendum N°	
Doc. N° CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 22 of 44

Table N° 3 Comparative Summary in relation to the characteristics of design (Ad and Ad 2).

Addendum Project at EIA	Addendum Project N° 2 at EIA
<ul style="list-style-type: none"> ▪ Quantity of wind power turbines 31 units ▪ Internal Roads (6 meters of minimum use) Approximate length: 20.8 Km. ▪ Approximate length of underground ducts. 23.1 Km. ▪ Foundations for the wind turbines. Type and dimensions: Octagonal (Φ19,8m) - Prof: 3,6m. Total volume of excavations: 1.109 m³. Total volume of concrete: 587 m³. Total quantity of iron: 62 tones. ▪ Mounting Platforms for the wind turbines. App Surface required: 2.200 m². 	<ul style="list-style-type: none"> ▪ Quantity of wind power turbines 30 units ▪ Internal Roads (6 meters of minimum use) Approximate length: 18.0 Km. ▪ Approximate length of underground ducts. 22.0 Km. ▪ Foundations for the wind turbines. Type and dimensions: Octagonal (Φ18,8m) - Prof: 2,25m. Total volume of excavations: 935 m³. Total volume of concrete: 436 m³. Total quantity of iron: 33,2 tones. ▪ Mounting Platforms for the wind turbines. App Surface required: 3.680 m².

Table N° 4 Comparative Summary in relation to the characteristics of design (Ad and Ad 2).

Description	Addendum Project at EIA	Project Ad. N° 2 to EIA	Percentage of
▪ Quantity of wind power turbines	31 units	30 units	-3.2%
▪ Approximate length of internal roads.	20.8 Km.	18.0 Km.	-13.5%
▪ Approximate length of underground ducts.	23.1 Km.	22.0 Km.	-4.8%
▪ Foundations for the wind turbines.			
Total volume of excavation	34.379 m ³ .	28.050 m ³ .	-18.4%
Total volume of concrete:	18.197 m ³ .	13.080 m ³ .	-28.1%
Total quantity of iron:	1.922 Ton.	996 Ton.	-48.2%
▪ Mounting Platforms for the wind turbines.			
Approximate Total Surface.	68.200 m ² .	110.400 m ² .	+61.9%

In the previous table it can be observed that the total volume of earth extracted for the foundations decreases (-18%), the volume of concrete (-28%) and the quantity of iron (-48%).

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 23 of 44

The surface required for the mounting platforms, increases (+61.9%), mainly because the tower dimensions and the blades for the new machines. And consequently, for the bigger size of the main crane and of the area of maneuvers required for the mounting operations.

Following, the environmental impacts are analyzed associated to the modifications included. Even though there are no different impacts from the ones detailed in previous studies, they may affect in a different way. For that reason, it was made a new analysis of environmental impacts related to:

- New localization of components (turbines) of the Wind Energy Station.
- Presence and functioning of the wind turbines.

10.1. ENVIRONMENTAL IMPACT RELATED TO THE LOCALIZATION OF COMPONENTS

10.1.1. Soil use affectation and use of the space

Soil Use

The project will be placed in a rural area where the main activity is agriculture and farming. Part of the surface in the site where the Wind Energy station will be or its surroundings is affected by infrastructure works of great impact in the local, regional and national level, among which are:

- High voltage aerial line of 132 KV.
Property of Transba S.A. It bonds the ET Bahía Blanca with the ET Tornquist; it crosses North to South the Rural Property "Reyrolles". In this portion of field, eight structures of concrete are installed and the wiring system of approximately 2.1km.
- Medium voltage aerial lines of 13,2 KV (rural).
Property of Cooperativa of Tornquist. They provide electric energy to the three rural properties, among others.
- Rails and railway station.
Near the Rural Property of "San Bautista Sur" and "Reyrolles". There is also the "Paraje García del Río", which has an ancient railroad building (inhabited) and the ex-school N° 22 of the Buenos Aires Province.
- National Route N° 33

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 24 of 44

At the moment the route trace is being modified into a highway of two lanes (with two driving lanes each other), separated by a central quarry of 23.30 meter wide).

The new topographic distribution of the wind turbines and the complementary works will not affect the existing infrastructures, rural headquarters, or tree groups present in the rural properties or in the zone.

In Annex C.05.1 two Notes are attached. They have been sent by the Town Hall in Tornquist in relation to the possibility of Soil Use and the authorization for the new location of the wind energy turbines in neighboring roads.

Space occupation.

In Annex C.04.1 there is a detailed analysis of the surface that the new configuration of the Wind Energy Station will affect.

PREPARATORY STAGE OF THE SITE AND CONSTRUCTION

- The temporary occupation of the surface that will be affected by different components of the Wind Station will be of approximately 29.6 has.

OPERATIVE STAGE AND MAINTENANCE

- The permanent occupation of the surface that will be affected by different components of the Wind Station will be of approximately 23 has.

As well as indicated in the EIA (Addendum) the real and permanent occupation of the soil affected by the different works will be of 2.4% of the total surface of the site (950has).

The rural properties are under agricultural and farming activity; this activity and the exploitation of the wind resource with energetic ends are perfectly compatible, with which the soil can easily host both activities. It is considered that this environmental impact is negative, of low level and of punctual extension.

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	Study on Environmental Awareness Addendum N°	
Doc. N° CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 25 of 44

10.2. ENVIRONMENTAL IMPACT RELATED TO THE PRESENCE AND OPERATION OF WIND ENERGY TURBINES

As it was said before keeping similar total power installed in the Wind Energy Park (from 99.2MW to 99.75MW) the number of wind turbines was diminished in one (from 31 to 30, that is -3.2%).

In the following table it is shown the technical characteristics most representative of the wind turbines, in which base the analysis will be done.

Table N° 5 Technical characteristics of the Wind Energy Turbines of the Project (Addendum) and Updated.

Addendum Project at EIA	Addendum Project N° 2 at EIA
<ul style="list-style-type: none"> ▪ Wind Energy Turbine Trademark: Siemens. Model: SWT 113-3,2 MW. Generator Type: Synchronic, PMG Nominal Power: 3,2 MW Frequency: 50 Hz. Generation tension 0.690 KV. Gearbox. None Hub Height 92.5 meters Rotor Diameter 113 meters Maximum height of the wind turbine: 149 meters Rotation speed: 6,5 - 15,8 rpm. Power Regulation: Pitch, with variable speed. Barren area. Per unit: 10.000 m². Total Wind Farm: 310.000 m². 	<ul style="list-style-type: none"> ▪ Wind Energy Turbine Trademark: Nordex-Acciona. Model: AW132/3300, TH120. Generator Type: Asynchronous, 6 poles, double-fed. Nominal Power: 3,325 MW. +3,9%. Frequency: 50 Hz. Generation tension 12 KV. Gearbox. SI (App quantity of oil 1.000 Lit.). Hub Height 120 meters +29,7%. Rotor Diameter 132 meters +16,8%. Maximum height of the wind turbine: 186 meters +24,8%. Rotation speed: Variable - 7.0 ... 14.0 rpm Power Regulation: Pitch, with variable speed. Barren area. Per unit: 13.720 m². +37,2%. Total Wind Farm: 411.600 m². +32,8%. Color (blades, hub, trench, tower): RAL 7035 (light grey). Noise level. 108,5 dB(A). +0,9%.

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 26 of 44

Updated analysis of the potential environmental impacts associated to the presence and functioning of the new wind energy turbines includes:

- Analysis of Noise Effects produced by wind turbines
- Analysis of Shadow Effects produced by wind turbines
- Affectation by Low Frequency Fields and the Corona Effect
- Affectation of flora and fauna
- Affectation of fauna
- Affectation of the landscape quality
- Affectation of aerial security
- "Clean" electric energy production
- Emission factors avoided to the atmosphere
- Wind Energy Turbine production on the earning of methane tankers

10.2.1. Analysis of Noise Effects produced by wind turbines

The noise produced by the wind turbines is defined depending its origin, mechanic or aerodynamic type. The level of noise reached by the new wind turbines is of 108.5 dB(A), which represents an increment of +0.9% in reference to the machine used in the previous project.

The mechanic noise is that produced by the mechanic parts in movement, like transmission, electric generator, position system, fans, and hydraulic engines, among others. This noise is transmitted by the openings of the nacelle and by the surface of the tower. At present it is relatively low, due to a better engineering preoccupied to avoid vibrations; joints and bonds are used, through elastic muffles in the main components of the nacelle, and the acoustic insulation.

The aerodynamic noise is the dominant part of the acoustic impact produced by the wind turbine. It is caused by the air flow acting on the blades of the rotor and when it goes through the tower; it is produced mainly in the tips of the blades and the back part of them. Consequently, at a higher speed of turn greater will be the noise produced. The aerodynamic noise is of the wide band type, modulated in amplitude, and it can be described as a whistling.

In Annex N° C.04.2, a detailed report is presented with the results obtained from the study of the noise that will be produced by the wind turbines in the context of the Project (through a simulation technique). For that we used the calculation software “WindPRO 3.2.701 by EMD International A/S, Noise.

From the results obtained by estimation, it is predicted that the properties identified as "Internal Receptors: A,B and C" are in the order of 49.7 db(A), 49.9dB (A) and 49.8 respectively. And the identified as "External Receptor: D, Paraje García del Río" is in the order of 46,6 db(A), (see Figure N° 3).




Figure N° 3 Map of noise emitted by the wind energy turbines of the Wind Energy Station.

Source: Calculation software “WindPRO 3.2.701 by EMD International A/S, Noise.

For what was said before, it can be concluded that the inhabitant that are in the properties mentioned will not be affected, given the noise in background produced by the wind over the tree curtain that surround them and over the rural properties will be stronger than the noise produced by the closest wind energy turbines.

Wind Energy Parks are located in areas where the win is normal and so the noise in background is common. At present, in the area where the project will be placed, sound emissions correspond to noise in the background produced by the wind. It is considered that this environmental impact is negative, of medium level and of punctual extension and permanent duration (service life of the project).


 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N° CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Energy Station</p>	<p>Date: 15/08/2018 Rev: A Page 28 of 44</p>

The noise source of mayor relevance after the wind turbines remits to the operation of the power transformer, which will be located within the perimeter of the ET (MT/AT). The project predicts the operation of 1 transformer of power 132/33/13.2 KV 110/110/40 MVA (Manufacturing Standards: IEC 60076); the sound focus reaches the highest level of emission against the transformer and the value is $Leq = 82 \text{ dB(A)}$.

With basis of the information generated in this study and what is established in current regulations, the levels of noise produced by the wind turbines must be monitored and registered, verifying the compliance of the norms IRAM 4062/16, called "Disturbing noising to the neighborhood", (SE 304/99 and ENRE 0197/2011, Article 4a and b; for Wind Energy Turbines).

10.2.2. Analysis of shadow effects (flickering) produced by wind turbines

Within the environmental impacts that the project produces the shadow effect (flickering) has been identified, projected by the wind turbines in neighborhood areas, when the sun is visible.



Analysis of Shadow Effects produced by wind turbines Source: NEG-MICON.

It is possible that the flickering effect may cause disturbances in people and the fauna that live in the area of the venture. The wind turbines, as other high structures, can create high shadows when the sun is down.

It is called shadow effect (flickering) the change produced in the intensity of light caused by the shadow projected on the ground, vegetation or infrastructure in proximities of the wind turbine (see Figure N° 4).

This effect occurs under certain specific combined conditions. When:

- The sun is shining and is in a low angle (at dawn or sunset).
- The wind turbine is located directly between the sun and the property affected.
- There is enough energy in the wind to make the blades of the turbine move.

In the Argentine Republic there is no specific regulation to consider in relation to disturbances made by the shadow of wind turbines over the potential affected ones. At an international level it is common practice to apply to Guides on Environment, Health and Safety for the Wind Energy (MASS) that recommend that: *"...considering the worst hypothesis, the duration predicted by such effects for*

part of a sensible receptor they verify that it does not exceed the 30 hours per year, or 30 minutes a day in the worst period in which the flickering takes place".

In Annex N° C.04.3, a detailed report is presented with the results obtained from the study of the shadow that will be produced by the wind turbines in the context of the Project (through a simulation technique). For that we used the calculation software "WindPRO 3.2.712 by EMD International A/S, Noise.

From the results obtained, it is predictable that neighboring areas of the project (app up to 1700 meters) may be affected by the shadow effect (flickering) produced by the wind turbines, (see Figure N° 5).




Figure N° 5 Map of shadows (flickering) emitted by the wind energy turbines of the Wind Energy Station. Source: Calculation software "WindPRO 3.2.712 by EMD International A/S, Noise.

The rural properties within the site of the Wind Power Station identified as "B,C and D" will be the sites most affected by the shadow effect: it will also be affected the rural property in the neighboring site (Paraje García del Río) identified as "A".

Even though there is no regulation that might rule this effect and with the basis of the studies done, Energética Argentina S.A. must inform the potential affected neighbors by this environmental parameter. In this sense, there must be done a Study of the effect, once the Wind Farm is put into functioning.

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 30 of 44

Shadow (flickering) by wind turbines (to all affected receptors), in windows or opening facilities where specific activities are done and that may disturb people. With this information we will have the source that produces the effect and the environmental factors that with no doubt will vary the estimations done. With the results obtained, we will proceed if necessary, to implement specific ways of mitigation measures.

National Route N° 33 at about 2.1Km (Progression Km42.700 and Progression Km 44.800) can be affected by the shadow (flickering) projected by the wind turbines of the Wind Energy Farm. For this reason, it must be communicated to the authorities of the National Roads and Highways Bureau of Argentina about the environmental affectation in the road mentioned. It is understood that it might be prudent to put signs, between the Progression indicated, to call the attention and mark the potential existence of this effect.

Applying the protection measures indicated, it is considered that this environmental impact is negative, of medium level and of punctual extension and permanent duration (service life of the project).

10.2.3. Affectation by Low Frequency Fields and the Corona Effect

One of the most important aspects from the environmental point of view are the electromagnetic effects originated about the environment by electric facilities of high and medium tension. Particularly, in the present study these are evaluated: electric field intensity(CE), magnetic induction (CM) and the audible noise levels (RA) and electromagnetic interference (RI) in case of the presence of the corona effect, framed in the Resolution 77/98 of the Energy Secretary.

The admitted levels established in Annex 1 of the regulation mentioned above are detailed below:

- I. In point 4.1 of the Annex, it is established that the superior limit value of the electric field not disrupted, for the lines in condition of nominal tension and the conductor at maximum annual temperature, is 3 KV/m in the hedge of the serving strip and out of it, at 1.0 meter from the ground.
- II. In point 4.2 of the Annex, it is established that the superior limit value of the magnetic induction for the lines in conditions of maximal tension defined by the thermal limit of the conductors, is 25 μ T (250mG) in the hedge of the serving strip and out of it at 1.0 meters from the ground.

 ICONO SRL <small>Tel: (0291) 4556484 - info@iconosrl.com.ar</small>	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 31 of 44

- III. In the point 2.1 it is established that the maximum level of radio interference is 54 dB during 80% in daytime, measured at a minimum horizontal distance of 5 times the height of the aerial line in its suspension poles or towers.
- IV. In the point 2.2 it is established that the maximum level of audible noise will not exceed 53 db. This value must not be passed 50% of the times in conditions of wet conductor in the limit of the serving strip from the center to the course of the LAT.

A very important aspect to highlight in this study is that there have been identified two relevant evaluation zones with greater access to the public which are: a) the zone where the High Tension Line progresses (132KV) and where it will be bonded to the Wind Energy Park; and b) the zone where the collector network will be developed of 33 KV of the Wind Energy Park.

Given that the site is crossed by the LAT (132 KV) that joins the ET Bahía Blanca and the ET Tornquist, from which the ET (MT/AT) of the Wind Energy Park will be undertaken, an analysis of electromagnetic fields will be done to demonstrate that the new project will not modify them adversely.

Estimations have been done using the "ad hoc" program developed by ICON srl that permits to determine the levels of the electric field, magnetic fields, radio interference and noise audible by the corona effect. The results of this program have been validated with results provided by the declared literature in the References of the present report.

In Annex N° C.04.4 a detailed report is presented with the results obtained for the updated project. With the estimations done for all the environmental parameters analyzed, we can conclude that it meets the requirements in the Resolution 77/98 of the Energy Secretary. It is considered that this environmental impact is negative, of medium level and of punctual extension and permanent duration (service life of the project).

Furthermore, in function of the proper characteristics of the operation of the project and of current regulations, the intensities of the electric field, magnetic induction and the levels of audible noise and radio interference in case of presence of the corona effect must be monitored, in the frame of the Resolution 77/98 of the Secretary of Energy.

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 32 of 44

10.2.4. Affectation of flora and fauna

In Chapter 03 of the present Addendum, a report on the Biotic Medium with flora and vegetation present in the project area is included. The objective of the report is:

- Evaluate plant diversity.
- Estimate the vegetable coverage and the percentage of barren land.
- Identify interesting botanic species with biologic, eco systemic or cultural value.
- Classify the field sectors in their value for conservation by flower signaling in the winter period.
- Suggest management recommendations with emphasis to protect native vegetation and minimize the impact on species in danger.

During the preparation and construction, the vegetation will be affected in the sectors where the works will be done. (ET, trenches for ducts, foundations and mounting platforms for the wind turbines) and in the workroom. The project requires the opening of new sites where soil removal and vegetable coverage will be done. It is not predicted to affect any of the sites with tree species (which are punctual in the three sites) with any infrastructure works.

The soil and the vegetation associated are element which will be sensibly affected, due to the big movement of earth that is required. Once the work is over, the surfaces affected temporarily will be covered preserving the organic soil and respecting the measures of restitution of the fertile layer, that is why with a correct treatment of the area it will be recomposed gradually. It is considered that this environmental impact is negative, of medium level and of punctual extension and permanent duration (service life of the project).

Other aspect that might affect the vegetation is the occurrence of spills of pollutant substances (hydrocarbons, oils, lubricants/refrigerants, etc.) used in vehicles (transport, etc.) and the machinery used for the work. In this case the affectation will be rather small and the environment does not ease the scattering of the fluid. Nevertheless, there will be plans to control the potential event. To this respect, it is important to mention that all the vehicles and machinery that come into the site must be in good condition of maintenance and have the certificate of Technical Verification for vehicles updated, consequently it is rather improbable its occurrence.

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 33 of 44

As said in the Environmental Report indicated previously, it is recommended to implement a daily Monitoring Plan, during the pre-construction and construction stage of the work, and possibly up to two subsequent spring-summer periods. The same will be oriented to make Recommendations of Treatment indicated (see Chapter 03 Baseline Report- Flora and vegetation).

During the operation and maintenance stage it is not expected to harm the vegetation. In case of required, the transport vehicles will not circulate outside the Wind Energy Park roads where there is vegetable coverage; and they will not operate equipment (cranes, etc.) outside the areas assigned to each wind turbine.

On the other side, the probability of occurrence of spills with pollutant substances (hydrocarbons, oils, etc.) in the soil and vegetation is quite limited due to: A) safety measures and those for prevented maintenance proper of each turbine; B) vehicles and machinery that enter the site should be in good state of maintenance; and C) training with good environmental practices with which the personnel assigned for these tasks of maintenance count.

10.2.5. Affectation of fauna

The energetic venture will develop in an environment affected by intensive agricultural and ecological systems destined to the production of agriculture and farming, and also highly modified by anthropic actions. So, the fauna present in the site is rather scarce; it is limited mainly to those species that have adapted to live with human beings, in disturbed areas.

As well, in Chapter 03, a report of amplification and update of the Biotic Medium, with fauna present in the area of the Project is included. The objective of the report is:

- The number of species in existence in the site and their seasonal variation.
- The presence of threatened species.
- The migrant status of the species in existence.
- Activity and seasonal abundance of bats.
- Preliminary recommendations and the suggestion of a tentative schedule for monitoring 2018/2019.

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N° CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 34 of 44

With the basis of what has been developed in the report of Baseline (fauna), it is recommended to implement a Monitoring Plan oriented to make recommendations (about birds and mammals) and a Schedule (2018-2019) suggested in the report. The same must be continued during the two first years in the operation/maintenance stage, and according to the results obtained there will be modifications (frequency and mitigation measures), for the continuation of the Adaptive Treatment Plan.

10.2.6. Affectation of the landscape quality

The visual impacts associated to Wind Energy Farms come from the wind turbines installed (quantity, distribution, height, color of components, etc.) and to their functioning (rotor movement).

The social perception of the impact over the landscape of these type of projects contains certain degree of subjectivity, where several positions arise. Some sectors consider "wind Mills" a sign of environmental progress and an element of touristic attraction in the region, and welcome a new form of "clean" energy; others consider that wind turbines constitute an intrusion in the landscape creating a negative visual impact.

The project will be developed in rural properties, where there are no public at all for uses of recreation or tourism, or it presents an environment of visual attraction with valuable scenery.

It has been taken as a reference and of valuable scenery the Cerro Tres Picos, given that it is the highest point in the Buenos Aires Province and from which summit all the town can be seen (1.243 m). The lineal distance from the hill to the Northern vortex of the site is of 30km (see Figure N° 6).

Even though the region has several sight for tourism, one of the preferable places is the Provincial Park Ernesto Tornquist. It is located at a lineal distance approx. of 34 km from the site.

So, the selected sites for the project are relatively distant from the main centers of touristic attraction. It can be said that the wind turbines will be appreciated by travelers that circulate a section of the National Route N° 33, only from certain specific places at more than 1.15 Km from the nearest machine (N° 12). It is considered that this environmental impact is negative, of medium level and of punctual extension and permanent duration (service life of the project).





Figure N° 6 Google Image with the location of the Wind Energy Station projected, and the approximate distances to the summit of Cerro Tres Picos and to the entrance of the Part Ernesto Tornquist.


In figure N° 7 (A,B,C and D) there are some simulations with different views where the visual affectation that the wind turbine will produce to observers that may circulate by National Route N°33 and by the neighboring roads.



Figure N° 7 Image with a view of the wind turbines from: A) National Route N° 33



B) Neighboring road to "Guanaco Chico" (Progression km 40)



C) Neighboring road to "Guanaco Chico" and "Reyrolles"(Progression km 47)



D) Neighboring road to "San Bautista Sur" (from Tres Picos to Paraje García del Río).

10.2.7. Affectation of aerial security

The new wind turbines will reach a maximum height of 186 meters, that is 37 meter more that the machines used in the EIA (Addendum).

They count with signaling units according to International Regulations, the wind turbines AW300 have two types of signs (see Annex C.02.3 Document "Signaling System") They are:

- Light signals.
 - Nacelle beacons.
 - Tower beacons a half height.
- Structure Painting Tower
 - signaling (painting) Rotor
 - signaling (painting)

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N°: CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Energy Station</p>	<p>Date: 15/08/2018 Rev: A Page 37 of 44</p>

According to the Aeronautical Code of the Argentine Republic, there must be a study of prefeasibility of height before the Dirección de Tránsito Aéreo depending of the Administración Nacional de Aviación Civil (ANAC) to the ends that this administration does the corresponding evaluation of the project.

Energética Argentina is making all the arrangements to update the project (see Annex C.05. Note "Ref.: Authorization for the installation of the Wind Energy Park"). From the evaluation that the Aeronautical authority makes, there will certain measures of signaling and ligh beacons of the updated project.

Considering the project characteristics and current regulations , a continuous Monitoring Plan will be implemented to verify the correct functioning of the beacons in the wind turbines. Under this consideration, there are no prediction that the venture might affect the aerial security, if it meets the requirements solicited by the authorities.

10.2.8. Emission factors avoided to the atmosphere

In Annex C.04.6 there is an analysis of the reduction in emission factors that 30 Nordex-Acciona wind energy turbines, model AW132/3300 TH120 of the Wind Power Center may add, compared to the production of the Thermal Centre whose energetic resources are: natural gas, fuel oil, coal or gas oil.

The reduction of emission of pollutants in the atmosphere during one-year period that might add the Wind Energy Center is shown in Table N° 6.

Table N° 6 Emission factors avoided to the atmosphere

Total generated MW-h/Año	Total of CO2 Tn	Total of NOx Tn	Total of SO2 Tn	Total of MP Tn
436,905	230,396	415	149	13

Considering a service life of 20 years, according the information provided by the wind turbine manufacturer, we can say that the project permits that the Wind Energy Station provide the electric system approximately 8,738,100 MW-h/in 20 years.

In Table N° 7 there are estimated the emission factors of pollutants which might be avoided during the service life of the Wind Energy Center, making a contribution to the Global Climate Change Program.

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	Study on Environmental Awareness Addendum N°	
Doc. N°: CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 38 of 44

Table N° 7 Emission Factors avoided to the atmosphere during the service life of the project.

Total generated MW-h/ 20 Years	Total of CO2 Tn	Total of NOx Tn	Total of SO2 Tn	Total of MP Tn
8,738,100	4,607,920	8,300	2,980	260

10.2.9. "Clean" electric energy production

In the present Addendum we evaluated the effect of the contribution of electric energy which might be obtained from the wind resource, with relation to the regional consumption of electricity and particularly to the demand supplied by the Cooperativas Eléctricas of: Chasicó, Felipe Sola, Sierra de la Ventana, Saldungaray and Tornquist.

It is to be named that the Wind Farm will add its generation to the National Interconnected System through the new Transformer Station (132/33/13,2 KV) which will be located between ET Bahía Blanca and ET Tornquist, as of an opening in the LAT of 132 KV which TRANSBA S.A. operates, in the province of Buenos Aires.

In Annex N° C.04.5 a document is presented where it is shown that the 30 wind turbines might contribute to the system the energy demanded annually by approximately 251,557 "Users of a Residential Category". Besides, it can be said that the 30 wind energy turbines might supply the total demand (annual) provided by the Electric Cooperativas of the Tornquist District (6.7% of the generation) and the rest might be supplied by the Regional Electric System (93.25%). So, the impact produced by the generation of "clean" electric energy coming from a renewable resource like the wind is considered of a highly positive level.




Figure N° 8 Effect of the Contribution of "Clean" Electric Energy in the Regional System

 ICONO SRL <small>Tel: (0291) 4556484 - info@iconosrl.com.ar</small>	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N°: CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 39 of 44

10.2.10. Wind Energy Turbine production on the earning of methane tankers

The objective of the present study is to evaluate the quantity of methane tankers that are required to produce the same quantity of electric energy that might generate the Wind Energy Center, whose energetic production will be injected in the National Interconnected System (SADI).

In Annex N° C.04.7, there is a report in which it is shown that with the energetic production predicted for the Wind Energy station it might be possible to avoid the importation of approximately 1.6 Methane Tankers per year, whose associated cost is approximately U\$S25,906,000. Apart from all the implications that it takes. For example: a) Reduction of environmental risk intrinsic of this activity; b) reduction of energy expenditure associated to the charging, transportation and discharging of GNL related to the methane tanker, among others.

11. Mitigation Actions and Environmental Management Plan

The Environmental impact associated to the updated project that might affect in a negative form any component of the receptor medium does not differ from those evaluated in previous environmental studies.


So, environmental protection measures required for the present study have already been investigated, which should be adapted as soon as the different activities are performed with all the modifications that may be needed.

As well, they are added in the present Addendum in the reports of Environmental Baseline, Biotic Medium- see Recommendations of treatment: a) Flora and vegetation; and b) Fauna.

In this respect it is important to mention that all the Plans, Programs and Audits will be developed in the frame of the Environmental Management System of the Energética Argentina company S.A. and or of whom it is designed as the Constructor and Operator of the Wind Energy Farm. For all said the PGA must be "adapted" and presented to the corresponding administration offices once the Executive Project has been elaborated, prior the beginning of the work.

According to what is said in OPDS N° 2351/16, the company Energética Argentina S.A. must have in its organization an Area of Environmental Protection under a professional in charge with the specialty in the matter, whose function will be that of coordinate all the specific activities of the Environmental Management Plan (PGA) and Monitoring of the environmental parameters in all the stages of the Project (construction, exploitation and leaving).

Following there is the functional organization chart of the work which will be defined in detail prior to the beginning of the activities (construction stage).



- (1) According to the requirement indicated in the Resolution OPDS N° 2351/2016, Annex I, Item III, Point 19, the proponent and responsible of the Project will have in his organization an Environmental Protection Area under a professional in charge with specialty in the subject matter, and whose function will be that of coordinate the specific activities of the PGA, among others.
- (2) The support team will collaborate with technical assistance in the Environmental Protection Area, in function of the necessities and especial requirements of the Project.

In compliance with current regulations, before the beginning of the activities, Energética Argentina S.A. must have with an environmental insurance and a restoration fund, according to the General Law of the Environment N° 25.675 Article N° 22.

 <p>Tel: (0291) 4556484 - info@iconosrl.com.ar</p>	<p>Study on Environmental Awareness Addendum N°</p>	
<p>Doc. N°: CEEN-IA-2655-08/18</p>	<p>2</p> <p>Wind Energy Station</p>	<p>Date: 15/08/2018 Rev: A Page 41 of 44</p>

11.1. ENVIRONMENTAL MONITORING PROGRAM

PREPARATORY STAGE OF THE SITE AND CONSTRUCTION

Prior to the beginning of the activities, the Constructor must show the corresponding plan, defining the points that will be monitored, the frequency and the quantity of samples, among others. Following there are the general guidelines of the environmental parameters to monitor:

A. Quality of air (PM10)

Location. Area of material extraction for lending and work fronts.

Frequency: To determine according the work progress.

Quantity of samples: To determine.

B. Level of sound pressure Work noise.

Location. In the area assigned for the workroom, in the RT (AT/MT) and in the work fronts.

Frequency: To determine according to work progress.

Quantity of samples: To determine.

C. Treatment of flora and vegetation.

Location. In the area assigned for the workroom, in the RT (AT/MT) and in the work fronts. (roads, underground ducts, foundations and mounting foundations of the wind turbines)

Frequency: Periodic inspection, up to the end of the work.

The Plan will be oriented to make recommendations of Treatment indicated in Chapter 03 Baseline Report- Flora and Vegetation).

D. Fauna Treatment

Location: to be determined in the context of the project area.

Frequency: To determine.

The Plan is oriented to make the Recommendations (of birds and mammals) and the Schedule (2018-2019) suggested in Chapter 03. Baseline Report- Fauna.

OPERATIVE STAGE AND MAINTENANCE

The Operator must specify the corresponding plan once received the facilities built, defining the points that will be monitored before and after the start-up of the Wind Energy Station.

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N°: CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 42 of 44

The sites where the measurements will be done and their frequency will be defined according to the requirements determined by the Ente Nacional Regulador de la Electricidad (ENRE), the Organismo Provincial para el Desarrollo Sostenible (OPDS- Buenos Aires Province), the Dirección de Recursos Naturales (Buenos Aires Province) and the Operator of the Wind Energy station.

The electrical and environmental parameters to monitor are the following:

- a) Electric Field-Res ENRE 1.724/98-.
- b) Magnetic Field- Res ENRE 1.724/98-.
- c) Radio Interference-Res SE 77/98; publication CISPR18/1; 18/2; 18/3-.
- d) Path and contact tension (Technical Specifications ex AyEE N° 75 Norm IRAM 2281-II and IV).
- e) Audible Noise IEC651-1987; IRAM4074-188 Measurement of tension and sound Levels and 4062/16).
- f) Earthing Systems (Technical Specifications ex AyEE N° 75 Norm IRAM 2281-II and IV).
- g) Noise Level (IRAM 4062/16) -Res. SE 304/99 y ENRE 197/2011, Art 4 a) and b) for Wind Energy Turbines. (1)
- h) Vibrations (IRAM 4078/89) -Res. ENRE 197/2011, Art 4 c) for Wind Energy Turbines.
- i) Impact record of birds-Res. ENRE 197/2011, Art 4 d)for Wind Energy Turbines.
- j) Solid and semi-solid waste -Res ENRE 197/2011, Art 4 e)for Wind Energy Turbines
- k) Beacons for the wind turbines.
- l) Treatment of Flora and Fauna (continuation of the preparation and construction stage) Monitoring must continue up to two subsequent spring-summer period to the construction stage.
- m) Treatment of Fauna (continuation of the preparation and construction stage) Monitoring must continue during the two first years in the operation/maintenance stage, and according to the results obtained there will be modifications (frequency and mitigation measures), for the continuation of the Adaptive Treatment Plan.

(1) According to current regulation, the levels of noise produced by wind energy turbine will be registered annually and after the occurrence of extraordinary natural phenomenon.

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N°: CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 43 of 44

12. CONCLUSION

From the analysis done in the present Addendum N° 2 to the EIA, it is important to emphasize that the modifications included in the updated Project do not incorporate significant affectations to the environment with respect to the EIA (Addendum) presented under File OPDS N° 21 45- 9512/16 and declared environmentally suitable under Resolution OPDS N° 2351/2016.

The corresponding facilities to the Transportation System will not manifest significant modifications of the technical-building type, not even in the geographical location with respect to the Original Project.

The most significant environmental aspects in relation to the Wind Energy Station are represented by:

- The re-localization of the wind turbines inside the same rural properties; maintaining similar total power installed (from 99.2 MW to 99.75) and reducing in one unit the quantity of the wind turbines to be installed (from 31 to 30).
- The nw wind turbines will reach a maximum height of 186 meters, that is 37 meter more that the machines used in the EIA (Addendum).
- The new wind turbines will have concrete towers which will be manufactured locally in a Plant which will be installed in the Industrial Park of Bahía Blanca. This will benefit the providers of products and services already in the area, as well as the hiring of local manpower.

In the present report there is an amplification and update of the Environmental Baseline, with reference to the Biotic Medium. Considering plant information, the vegetation and fauna obtained in the site (three sites) and surrounding the project, it is convenient to follow the recommendations of treatment and monitoring schedules suggested,

The potential negative environmental impacts present a medium-to-low rate, and it is possible to mitigate them with the implementation of protection measures recommended, through a correct environmental treatment in each stage of the energetic venture.

As a conclusion of this evaluation, it results that the Wind Energy Station Project Energética I in the place selected is compatible to the context and is framed into current legal regulations, in all reference to environmental protection at a National, Provincial and local level.

 ICONO SRL Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N°	 ENERGÉTICA ARGENTINA
Doc. N°: CEEN-IA-2655-08/18	2 Wind Energy Station	Date: 15/08/2018 Rev: A Page 44 of 44

13. Annex C.05

- C.05.1. Documents/Notes and Affidavits related to the Project
 Dangerous and/or Chemical Substances, fuel, other substances that will be deposit in the site - HDS
- C.05.2. site - HDS

 Tel: (0291) 4556484 - info@iconosrl.com.ar	Study on Environmental Awareness Addendum N° 2	 Date:
Doc. Nº: CEEN-IA-2655-0 8.18	Wind Energy Station Energética I Buenos Aires Province	15/08/2018

ANEXOC.05.1

DOCUMENTS/NOTES AND AFFIDAVITS RELATED TO THE PROJECT

- Tornquist Town Hall
- I.
 - A) Feasibility for soil use.
 - B) Authorization for the location of the wind energy turbines in the surroundings of local neighboring roads, near García del Río.
 - C) Public Audience Act for "Wind Energy Park Project in the District".
 2.
 - Administración Nacional de Aviación Civil (ANAC) - Dirección de Aeródromos.
 - Authorization in height for the installation of the Wind Energy Park.
 3.
 - Ministry of Energy and Mining.
 - Authorization of entrance as Agent Generator of MEM.
 4.
 - Affidavits- Facilities free of PCBs.



Municipalidad de Tornquist
Intendente Municipal

TORNQUIST, June 6th, 2016.-

Note N°: /16 -IM-

TO THE PRESIDENT
OF THE WIND ENERGY PLANT ENERGÉTICA 1
Engineer **GUILLERMOS COCCOZ**

I am writing in my name of Tornquist Town Hall Mayor to give you the corresponding temporary authorization for the location of the Wind Energy Park in the following rural properties: Cadastral Naming: Circ 111 - Secc. Rural-Tia. 39f -Ptda. 3.533; Circ. VIII - Secc. Rural – Pla. 566 B – Ptda. 14.852; and Circ. VIII - Secc. Rural – Pla. 569 - Ptda. 45.

It is informed that this authorization will be under condition of presenting all the documentation requires by our Town Hall and that you can meet all the current National and Provincial regulations that may be necessary.

With no other matter to cover, yours

Sincerely,

Sergio Bordoni
Tornquist Town Hall
Mayor

TO R NQ UIST
Town Hall

Tornquist, 14th September, 2018

Mr. Rubén Zaia
AES Renewable Energy
Director
S / D

Ref. Authorization for the location of the wind energy turbines in the surroundings of local neighboring roads, near García del Río.

By this writing I am saying to you that with reference to the location of the wind energy turbines of the AES company in the surrounding neighboring roads near Estación García del Río according to contract N° EOL 003 of the RenovAr Project- Ronda 2 and under the Assignment of priority of office in the frame of that disposed in the Resolution M.E. and M. N° 281 /2017 and the Disposition SSER N° 1 /2018 having taken in mind the Environmental Impact Study by OPDS with Resolution N° 2351 dated 2/8/2016, the Resolution 304/99 of the National Ministry of Energy, and the regulations of the Argentine Office of Roads and Highways Law 2193, you are authorized to locate the wind energy turbines only if its placement with respect to the wiring fencing that divides the neighboring road from the field, is calculated at least in base of the blade length added to the road width.

In the case of the wind energy turbines N° 02, 11, 30, 28, 29, according what it is manifested in the file sent on 11th September,2018 (Annex), they respect the minimum distance according the uniform width of 25m of partial roads (Art 6° of Law 2193), as they are located at 90m or more of the fencing line (blade 64m+ placement 25m= 89m). In the case of wind turbines N° 17 and 27, they are placed on a local internal neighboring road (without regulations that may specify the nominal width) that goes from the fencing 80m, whose width does not exceed 15m, so by this it is respected the minimum distance of placement (blade 64m+ placement 15m= 79m).

With no other matter, yours sincerely.



**Mayor Sergio
Bordoni**

TO R NQ UIST
Town Hall

Annex.

Evaluated location of the wind energy turbines. File sent by email ,September 11th by Javier Valy from AES Company.

 **Javier Valy** paramí, Ruben Ignacio, Alfredo
Gonzalo, 11 sep

Buen día. Te comparto el layout definitivo para el parque Energética con las modificaciones requeridas para cumplir con las distancias de seguridad y requisitos del municipio de Tomquist y permitir el paso de la línea de evacuación de los proyectos de PCR

Saludos,
Javier

“D” Javier Valy
Enviado el: viernes, 17 de agosto de 2018 19:15
Para: 'Gonzalo Iparraguirre' <g@ujjib@gmail.com>
Asunto: RE: Parque Eólico Energética - Layout 30 Aeross Acciona

layout Energética

11 Km.



Mayor Sergio
Bordononi

RECORD OF A HEARING BY "WIND ENERGY FARM PROJECT IN THE DISTRICT"

In the city of Tornquist, at 14 days of the month of December of 2016, being 18.00 hours in the Board room of the Town Hall, they meet with the objective of holding the Hearing summoned by the Tornquist Town Hall and the Honorable Council, where the Argentine Energetic Company

S.A will present to the neighbors the detailed Wind Energy Plant Project proposed to be built in the surroundings of the town Tres Picos and the station García Del Río.

The following authorities are gathered: the holder of the title of the Development Agency of the Tornquist Town Hall, Dr. Gonzalo Iparraguirre; the Director or Environment of the the Town Hall of Tornquist, Ms Melisa Herrada; the councilor María Ofelia Skolak; the President of the company Energética Argentina S.A.; Engineer Guillermo Coccoz, accompanied by the Director and Technical Manager of Energética Argentina S.A, Engineer Agustina Peralta, the Commercial Manager of Energética Argentina S.A, Engineer Alejandro Hunko, and the Development Manager, Mr Agustín Marcenac; educational institutions interested in the training career about sustainable energy, as well as engineers and referents of the Cooperativas Eléctricas of the zone and general public.

The act is opened by Dr.Gonzalo Iparraguirre, who after saluting the people present, mentions the Hearing for the Wind Engery Park Project in the District", and thanks the authorities and the public in general.

The President of the company Energética Argentina, Engineer Guillermo Coccoz takes the floor and starts his speech with a power point, presenting the associated scheme of companies that boost the project and the work team that is conduction the project, and that is present in this Act to clear any doubts that may arise. Likewise, he describes the components of the wind energy farm and how they are integrated in the development of the project.

He continues showing the current energetic situation in Argentina, the characteristics of the energy matrix and the impact of importations

of gas in the fiscal deficit in Argentina. In this context, he proposes the Wind Energy as part of the solution to this severe problem, describing the advantages of this renewable source of generation of electric energy, above

the conventional sources that domain the current energy matrix of this country. Furthermore, he informs the audience about the increase in wind energy in a global level during the last 10(ten) years; which are the countries with the highest development in the world; and in our region.

SContinuing with the presentation, engineer Guillermo Coccoz shows the evolution of wind energy in time, explaining technically how wind turbines

4...

that will be installed in the project work, in function of the wind energy resource of the zone where it will be installed. Afterwards, he explains the excellency of this resource in Argentina in general, in the district of Torquist in particular.

The following topic in the presentation is the one referred to the Antecedents of Wind Energy in the country, how the new Law in Promotion of Renewable Energies (Law N° 27191) is implemented, and its main characteristics. Engineer Guillermo Cocoz continues explaining the selection mechanisms of the projects for the execution of electric energy supply contracts as of renewable sources, in function of this new law, and how the Wind Energy Farm Energética I is framed in one of these mechanisms.

From this moment, he starts to detail the particular characteristics of the Wind Energy Park Energética I, from its geographic location to the excellency of the wind energy resource in the site, reason for which the place was selected for the project. He also talks about the characteristics of modern wind energy turbines and how the technology progressed during the 7 years of development that the project has taken.

In this moment, there is room for the questions of the audience, where a representative of a local electric cooperative enterprise gives his opinion about the wind energy farm and the importance of energy supplying in the District of Tornquist.

Afterwards, the Headmaster of the Technical High School N° 1 from Tornquist, Prof. Luis Quintana, inquires if there is a definite procedure about the technological transference for the installation of local industries that may provide supplies and services to these types of projects. Engineer Guillermo Cocoz explains that technology providers for these projects have already made contact with potential local suppliers, and inasmuch as these projects move forward in their developments, these ties will deepen, and local suppliers will provide their services to wind energy farms. It is also explained that due to financial issues of the projects, it is more difficult to integrate local supplies, since the local industry does not count with experience in this type of technology.

Later, after several exchange of ideas among the public and the technical team of the project, the representative of one of the most important industries in the District becomes interested in getting to know the technical characteristics of the protection systems that will be installed in the Transformer Substation of the Park. Engineer Alejandro Hunco steps in, and informs that all the equipment to be used in the Transformer Station are defined by the technical specifications of TRANSBA (the transport company of electric energy of Buenos Aires Province and operator of the High Tension Network where the wind farm will be connected). They also explain the operative characteristics of the wind park and its connection to the interconnected



national system.

Engineer Guillermo Coccoz suggests continuing with the presentation, telling that at the end there will be another moment to answer all the questions. He continues with the presentation describing the stages of construction of the wind park, telling about the periods of time needed, the resources to use, either economic and human, and the need to get local manpower for the work.

The next topic is the Study of Environmental Impact of the Project. They look into the means analyzed by the investigation, and they indicate and describe the Positive and Negative Impacts of the Installation of the Wind Energy Park Energética I, in the selected place, so the people in the Hearing can give their opinions with better knowledge of the physical, biologic, environmental and cultural impact of the project.

To end the presentation Engineer Guillermo Coccoz informs the audience about the Declaration of the Project as Environmentally suitable recognized by the OPDS (Provincial Institution for the Sustainable Development of the Buenos Aires Province), and he concludes by explaining the importance of installing the wind park as a means of generation of clean energy, replacing the import of methane tankers, supplying clean electric energy to more than 220.000 homes in the year, and reducing CO2 emission in a volume equivalent to that produced by 1000.000 cars in a year.

Finally, he asks the attendees their opinions and comments about the installation of the wind farm Energética I in the area of the District of Tornquist, receiving positive answers about the initiative, and expressions of support by the different sectors.

Being 20.40 hours of the present day, having exposed the totality of the participants and not having formulated observations for the attendees in the Hearing, Dr Gonzalo Iparraguirre announces that the Hearing concludes, a record of it is issued.

///
116-...-1111<.....
-.....
L.;;

Dr.GONZALO IPARRAGUIRRE SECRETARY
DEDESARROLLO MUNICIPAL DAODI
TOROQUIST

MARIA OFELIA SKOLAK
PRESIDENTE BLOQUE
FRENTE PARA LA VICTORIA

Lic. Melisa Soledad Herrada
Directora de Medio Ambiente
MUNICIPALIDAD DE TOROQUIST

'f* v---j
T i =,f(c- .C)
Ce-"c...-i t

Buenos Aires, 8th June, 2016.

1 - 2) P-LI

Sirs

**ADMINISTRACIÓN NACIONAL DE AVIACIÓN CIVIL
INFRAESTRUCTURA YAERÓDROMOS**

Reception Office 1

1 - 9 June 2016

EXPTE. Nr: ANC 20033/16

Ref. Authorization in height for the
installation of the Wind Energy Park.

Dear Sirs,

As Legal Representative of the company ENERGETICA ARGENTINA S.A. I am pleased to address you to solicit authorization in height for the installation of the Wind Energy Park "Energética I", located in the District of Tornquist, in the Buenos Aires Province.

For that ends, we have fixed our legal address for communications in 1174 Corrientes Av, Floor 6 of the Autonomous City of Buenos Aires.

The Wind Energy Park "ENERGÉTICA 1" will be installed in three rural properties (Cadastral Naming: Circ 111 - Secc. Rural-Tia. 39 f - Ptda. 3.533; Circ. VIII - Secc. Rural - Pla. 566 B - Ptda. 14.852; and Circ. VIII - Secc. Rural - Pla. 569 - Ptda. 45) located in the surroundings of Paraje García del Río, of the Tornquist District, and will have a total of 31 (thirty-one) wind turbines.

Furthermore, we attach to the present letter the documentation that it detailed below:

- Statute of the Company certified by notary public.
- Form B- Petition of Authorization in Height Extense Objects.
- Plan of Location of the Wind Turbines, signed by competent professional.



sincerely.

Yours

Inga.Agustina Peralta
Director
ENERGÉTICA ARGENTINA S.A.





República Argentina - Poder Ejecutivo Nacional
2018 - Año del Centenario de la Reforma Universitaria

Note:

Number: N0-2018-04518441-APN-DDYME#MEM

BUENOS AIRES CITY
26th January, 2018.

Reference: Notification RESOL-2018-18-APN-SECEE#MEM - EXP-S0 1:0239839/2016 - Admission of the company ENERGÉTICA ARGENTINA SOCIEDAD ANÓNIMA as AGENT GENERATOR of the MEM for its Wind Energy Park Energética I

A: ENERGÉTICA ARGENTINA SOCIEDAD ANÓNIMA (ESMERALDA 1394 Piso:4 Dpto:B - CABA),

With Copy A:

Dear Sirs:

By this means, I am notified about Resolution N° 18 (RESOL-2018-18-APN-SECEE#MEM) signed by the Electric Energy Secretary of the National Electric Energy Office Engineer Mr. Alejandro Valerio SRUOGA at 25 days of the month of January, 2018.

Yours, sincerely.

Digitally signed by GESTION DOCUMENTAL ELECTRONICA - GOE
DN:cn=GESTION DOCUMENTAL ELECTRONICA *GDE,c=AR, o=MINISTERIO DEMODERNIZACION,
ou=SECRETARIA DE MODERNIZACION ADMINISTRATIVA, serialNumber=CUIT 30715117564
Date: 2018.01.26 09:53:04 -03'00'

German Dario Oberti
Director
Dirección de Despacho y Mesa de Entradas
Ministerio de Energía y Minería


Ministerio de Energía y Minería
Dirección de Despacho y
Mesa de Entrada
Dr. German Oberti
Director



República Argentina - Poder Ejecutivo Nacional
2018 - Año del Centenario de la Reforma Universitaria

Resolution

Number: RESOL-2018-18-APN-SECEE#MEM

BUENOS AIRES CITY
25th January, 2018

Reference: EXP-S01:0239839/2016 - Admission of the company ENERGETICA ARGENTINA SOCIEDAD ANÓNIMA as AGENT GENERATOR
OR of the MEM for its Wind Energy Park Energética 1

WHEREAS Proceeding N° SOI :0239839/2016 of the Registry of the MINISTRY OF ENERGY AND MINING,
and

RESULTING:

That the company ENERGETICA ARGENTINA SOCIEDAD ANÓNIMA petitioned its authorization as AGENT GENERATOR in the MERCADO ELÉCTRICO MAYORISTA (MEM) for its Wind Energy Station Energética I of ONE HUNDRED MEGAWATS (100 MW) of nominal power, installed in the District of Tomquist, BUENOS AIRES PROVINCE, connecting to the ARGENTINE SYSTEM OF INTERCONNECTION (SADI) in bars of THIRTY THREE KILOVOLTS (33 kV) of the new Transformer Station 132/33 kV, bonding to the High Tension Line of ONE HUNDRED THIRTY TWO KILOVOLTS (132 kV) Bahía Blanca -Tornquist, jurisdiction of the EMPRESA DE TRANSPORTE DE ENERGÍA ELÉCTRICA POR DISTRIBUCIÓN TRONCAL DE LA PROVINCIA DE BUENOS AIRES SOCIEDAD ANÓNIMA (TRANSBA S.A.).

That by means of Note B-108130 - 1 of date 21st July, 2016 the COMPAÑÍA ADMINISTRADORA DEL MERCADO MAYORISTA ELÉCTRICO SOCIEDAD ANÓNIMA (CAMESA) informed that the company ENERGETICA ARGENTINA SOCIEDAD ANÓNIMA meets the requirements demanded under Points 5.1 and 5.2 of the Annex 17 of the Procedures for its admission and administration of the MERCADO ELÉCTRICO MAYORISTA (MEM).

That by means of the Resolution N° 2.351 with date 2nd August, 2016, the Provincial Organism for the Sustainable Development of the Buenos Aires Province determined to declare the Project Work called Wind Energy Park Energética I environmentally suitable.

That the company ENERGETICA ARGENTINA SOCIEDAD ANÓNIMA has fulfilled the requirements of current legislation with respect to the presentation of documents about the association and commercial ends.

That the petition of admittance into the MERCADO ELÉCTRICO MAYORISTA (MEM) of the Wind Energy Park Energética I was published in the Official Bulletin of the Argentine Republic N° 33.486 with date 20th October, 2016 without having received any objections that may disqualify the rendering of this resolution .



That the NATIONAL ADMINISTRATION OF THE WHOLESALE ELECTRIC MARKET REGULATION of the SUBSECRETARÍA DE ENERGÍA TÉRMICA, TRANSPORTE Y DISTRIBUCIÓN DE ENERGÍA ELÉCTRICA of the SECRETARÍA DE ENERGÍA ELÉCTRICA of the MINISTRY OF ENERGY AND MINING has taken note of its competence.

That Article 11 of the Resolution N° 6 with date 25th January, 2016 of the MINISTRY OF ENERGY AND MINING, outsourced in the SECRETARY OF ELECTRIC ENERGY the faculties assigned to the ex-SECRETARY OF ENERGY of the ex-MINISTERIO DE PLANIFICACIÓN FEDERAL, INVERSIÓN PÚBLICA Y SERVICIOS, according Articles 35, 36 y 37 of Law N° 24.065.

That the DIRECCIÓN GENERAL DE ASUNTOS JURÍDICOS of the MINISTRY OF ENERGY AND MINING has taken note of its competence.

That the faculties for the rendering of this resolution arise from that specified by Articles 35 and 36 of Law N° 24.065 and by the Resolution N° 25 with date 16th March, 2016 of the MINISTRY OF ENERGY AND MINING.

For that,

THE SECRETARY OF ELECTRIC ENERGY


RESOLVES:

ARTICLE 1°.- Authorize the admission of the company ENERGÉTICA ARGENTINA SOCIEDAD ANÓNIMA as AGENT GENERATOR of the MERCADO ELÉCTRICO MAYORISTA (MEM) for its Wind Energy Park Energética I of ONE HUNDRED MEGAWATS (100 MW) of nominal power, installed in the District of Tomquist, BUENOS AIRES PROVINCE, connecting to the ARGENTINE SYSTEM OF INTERCONNECTION (SADI) in bars of THIRTY THREE KILOVOLTS (33 kV) of the new Transformer Station 132/33 kV, vinculated to the High Tension Line of ONE HUNDRED THIRTY TWO KILOVOLTS (132 kV) Bahía Blanca -Tomquist, jurisdiction of the EMPRESA DE TRANSPORTE DE ENERGÍA ELÉCTRICA POR DISTRIBUCIÓN TRONCAL DE LA PROVINCIA DE BUENOS AIRES SOCIEDAD ANÓNIMA (TRANSBA S.A.).

ARTICLE 2°.- Inform the COMPAÑÍA ADMINISTRADORA DEL MERCADO MAYORISTA ELÉCTRICO SOCIEDAD ANÓNIMA (CAMMESA) for the purpose of cost overrun that might be generated to the other agents of the MERCADO ELÉCTRICO MAYORISTA (MEM) and the penalties that may be paid by lenders of the FUNCIÓN TÉCNICA DEL TRANSPORTE (FIT) derived from eventual unavailability on the occasion of the admission this act authorizes, will be charged on the company ENERGÉTICA ARGENTINA SOCIEDAD ANÓNIMA, title holder of the Wind Energy Station Energética I, in its bond with the SISTEMA ARGENTINO DE INTECONEXIÓN (SADI) in bars of THIRTY THREE KILOVOLTS (33kV) of the new Transformer Station 132/33 kV. To this effect the COMPAÑÍA ADMINISTRADORA DEL MERCADO MAYORISTA ELÉCTRICO SOCIEDAD ANÓNIMA (CAMMESA) is enabled to effect the corresponding charges within the Seasonal Period in which such overrun or penalties are produced..

ARTICLE 3°.- Notify the company ENERGÉTICA ARGENTINA SOCIEDAD ANÓNIMA, the COMPAÑÍA ADMINISTRADORA DEL MERCADO MAYORISTA ELÉCTRICO SOCIEDAD ANÓNIMA (CAMMESA), the EMPRESA DE TRANSPORTE DE ENERGÍA ELÉCTRICA POR DISTRIBUCIÓN TRONCAL DE LA PROVINCIA DE BUENOS AIRES SOCIEDAD ANÓNIMA (TRANSBA S.A.) and the ENTE NACIONAL REGULADOR DE LA ELECTRICIDAD (ENRE), decentralized organism acting in the MINISTRY OF ENERGY AND MINING.

ARTICLE 4°.- For communication and publication, deliver to the Dirección Nacional del Registro Oficial and file it.


SECRETARIA
Ministerio de Energía y Minería
Dirección de Despacho
y Mesa de Entrada
Dr. Garbín Oberl
DIRECTOR


gt% d2 y1: ejand.ro Valerio
Location Autonomous City of Buenos Aires

Alejandro Valerio
Sruoga Secretario
Secretaria de Energía Eléctrica
Ministerio de Energía y
Minería

HEREBY I, Iván Diego Durontó, ID N° 23.471.261 and in my capacity of title holder of the company ENERGÉTICA ARGENTINA S.A., with legal address in 1023 Carlos Pellegrini Floor 9, of the Autonomous City of Buenos Aires, declare under oath that the equipment affected for the construction and subsequent operation of wind energy park do not and will not contain biphenyl polychlorides (PCBs) and that such products will not be stored in the site.



IVÁN DIEGO DURONTÓ
APODERADO





SAFETY DATA SHEET

HDS. Nro. 41.29

Date: 24/04/01

Company Sika Argentina S.A.I.C.
5250 Juan B. Albert - Caseros - Bs. A

Telephone (011) 4734-3500

Product: ASPHALTIC MEMBRANE 35Kg c/ aluminum Page 1/3

Emergency telephones in case of ingestion: (01) 4658-7777 / (01) 4654-6648 Hospital Posadas

1.1 Chemical composition: Formula based on tarmac, mineral charges, additives, with intermediate films of polystyrene and external coating of aluminum.

1.2 State: Solid 1.3 Color: Black 1.4 Odor: -

2. PHYSICAL AND SAFETY DATA

2.1 Change of state:

2.2 Density:

N.A.

2.3 Vapor pressure

N.A.

2.4 Viscosity

N.A.

2.5 Solubility in water:

Insoluble

2.6 pH:

N.A.

2.7 Flash point:

> 200 °C

2.8 Ignition temperature:

N.A.

2.9 Explosion limit:

Inferior: -

Superior: -

2.10 Thermal decomposition:

N.A.

2.11 Dangerous decomposing products -

2.12 Dangerous reactions:

None is handled correctly

2.13 Additional Information: -

6. MEASURES IN CASE OF FIRE OR ACCIDENT

6.1 After leakage or spills: Remove mechanically and discard according to 5.5
Clean small quantities with turpentine

6.2 Extinction agents; Adequate: Foam, CO2, dry powder,
water Do not use: -

6.3 FIRST AIDS Take contaminated clothes off immediately. Wash contaminated skin with plenty of water and soap.
In case of eye contact, wash immediately under water jet for 15 minutes. See eye specialist
In case of ingestion or vapor inhalation, take to fresh air and search for medical help

6.4 Additional Information:

7. TOXICITY INFORMATION

No health damage with normal handling.

8. EGOGCER EGORORICAR INFORMATION

The product is slightly harmful for the acuatic environment. Do not discard on water streams of earth.

9. ADDITIONAL INFORMATION

This information corresponds only to this product and does not include caution measures that must be considered to apply the product, specially considering handling of welding torches or heaters needed for the application.

The information in this Safety Sheet corresponds to our knowledge in the moment of publication. All guarantee is excluded. Our current General Conditions of Sale and Supply will be applied. Please check the last updated version of the Technical Sheet of the Products

before any use.

Sika Argentina S.A.I.C.

HDS Nro. 41.29

MATERIAL SAFETY DATA SHEET

Sika®-1

SECTION 1. IDENTIFICATION OF THE DANGEROUS CHEMICAL SUBSTANCE OR MIXTURE AND ITS SUPPLIER OR MANUFACTURER.

Product Name Sika®-1

Product Code: 100000014484

Type of product : liquid

Recommended use of the chemical product and use restrictions

Product use : Only for professional use.

Information about the manufacturer or provider

Sika Ar^gentina S.A.I.C.

5250 Juan Bautista Alberdi
1678 Caseros/Buenos Aires
Argentina

Telephone 011-4734-3500

Fax : 011-4734-3555

Email failache.nestor@ar.sika.com tronico

Emergency Telephone: Posadas Hospital 98-82+54, 1146587777

SECTION 2. HAZARD IDENTIFICATION

SGA Classification

Skin irritation : Category 3

Skin sensitization: Category 1

Elements of GHS tag

Pictograms of danger

Caution

Danger Indications: H316 Skin rash

H
Attention
3

17 Can provoke skin rash



MATERIAL SAFETY DATA SHEET

Safety Advice: **Prevention:**

P261 Avoid breathing powders/smokes/ gases/ mists/ vapors/ air sprays

SikaM

Verstón 1.0

Number of HDS: 100000014484

Revision date: 2016.09.22

Vapor pressure : 23 hPa (23 hPa)

Relative vapor density No data Density : approx.

1.05 g/cm³

Solubility

Hydrosolubility : No data Solubility in other
solvents : No data

Partition coefficient : (n-
octanol/water) : No data

Temperature of auto
inflammation : No data

Temperature of
decomposition : No data

Viscosity

Viscosity, dynamics: No data Viscosity,
cinematics : > 20,5 mm²/s

Explosive properties : No data Molecular

Weight : No data

SECTION 10. Stability and reactivity

Reactivity No dangerous reaction known under normal use.

Chemical stability: The product is chemically stable.

Possible dangerous
reactions: : Stable under recommended storage conditions.

Conditions to avoid: No data

Incompatible materials: No data It does not decompose
if stored and applied as indicated

MATERIAL SAFETY DATA SHEET

SECTION 11. TOXICOLOGIC INFORMATION

Acute toxicity No data

Corrosion/ skin irritation It
causes skin rash.

Sika®-1
MATERIAL SAFETY DATA SHEET

Verstón 1.0

Number of HDS: 100000014484

Revision date: 2016.0922



duos.

Polluted containers: Empty the content left. Discard as product not used. Do not reuse empty containers.

SECTION 14. INFORMATION RELATED TO TRANSPORT.

International Regulations IATA-DGR

Goods with no danger Code- IMDG Goods with no danger

Bulk transport with arrangement to Annex II of the Convenio Marpool 73/78 and the IBC Code.

No applicable for the product as it is provided.

NCh 2190/382 Goods with no danger

SECTION 15. REGULATION INFORMATION

Environmental , safety and health specific regulation for the substance or mixture.

International convention on Chemical Weapons : 2,2',2"-nítrotriethanol

(CWC) Programs about Toxic Chemical Products

and precursors (Louisiana Administrative Code of , Title 33 Part V Section 10101, et seq)

Precursors and chemical essence substances : No applicable for the elaboration of narcotic substances.

SECTION 16. OTHER INFORMATION INCLUDED THAT FOR THE PREPARATION AND UPDATE OF SAFETY DATA SHEETS

The information contained in this safety data sheet corresponds to our level of knowledge at the publication date. All guarantees excluded. Our current general conditions for purchase are applied. Please, check the Product Data Sheet before the use and processing.

jf

MATERIAL SAFETY DATA SHEET

MIRA 313

**M Uçut~y GOOD NOT DANGEROUS FOR ITS
TRANSPORTATION**

Issuer: W.R. GRACE ARGENTINA S.A. Risk number: Not dangerous
570 Primera Junta ONU N° : Not dangerous (B1878IPL) Quilmes, Buenos Aires, Argentina
Class and Division: Not

Physical State: Brown liquid. Incompatible with strong oxidant agents (class 5.1) acids and bases (class 8).

EPP: Use breathing, eye, and thermal protection and butyl gloves.

RISKS

- NOT FLAMMABLE , it does not autoignite, but it may be decomposed when heated and produce fire corrosive and/or toxic vapors

Health • IRRITANT; may cause irritation if ingested, inhaled or under skin contact.

Medium • All handling must consider local regulations and laws.

Ab. t • The material is stable. Nevertheless, avoid open fires and high temperatures.

3

IN CASE OF ACCIDENT

- Use appropriate personal protection elements
- Stop the leakage, if it is possible to do it without risks. Do not touch or tread over the spilled material.

Spills * Collect the product using sand, vermiculite, earth or inert absorbent material and clean or wash the contaminated area completely.

- Do not pour water directly over the spill or identify source of leak. Avoid water fluids entering in contact.

- Use dry chemical powder , foam, sand or CO2 Use the product according to the materials in the surroundings. DO NOT USE water jet directly.

FIRE * Move the containers in the area of fire if it can be done without risks.

- Make an overflow basin for the water that controls the fire . for disposal afterwards. no

Contamination * This material may be a dangerous waste.

Environmental * Comply with the legal recommendations established for its disposal.

- Call emergency medical service
- Take the victim to fresh air. Apply artificial breathing assistance if the victim does not breathe.
- Take off and insulate clothes or shoes that may be contaminated.

First ** Keep the victim under rest and with normal temperature.

Aids * In case of contact with the substance, wash skin and eyes immediately with water and soap at least for 20 minutes.

Information for * If there is lose of consciousness, apply oxygen.

the physician * Take the patient to a non-contaminated environment, keep the patient sheltered and calm.

This Emergency Intervention File is destined to Emergency Services .
Information or risks and safety for the characteristics in case of accidents that is consigned for each product are elaborated in base of the generic classification of each one. (risk number and ONU N°). So, the typical values of the physical properties included in this information are consigned with the sole purpose of emergency management and they must not be interpreted as technical specifications, of quality, or absolute limits of parameters for the different consignments of products.

EMERGENCY TELEPHONES

FIREFIGHTERS: 100

POLICE: 101/911

CIVIL DEFENSE: 103

MEDICAL EMERGENCY 107

MATERIAL SAFETY TECHNICAL SHEET



Verstón 1.0

Number of HDS: 100000015754

Revision date: 2017.0314

SECTION 1. IDENTIFICATION OF THE PRODUCT AND COMPANY

Product Name Wood

Product Code: 100000015754

Type of product : liquid

Recommended use of the chemical product and use restrictions

Product use : Reserved exclusively to professional users.

Information about the manufacturer or provider Sika

Argentina S.A.I.C.

5250 Juan Bautista Alberdu
1678, Buenos Aires,
Argentina.

Telephone 011-4734-5000

Telefax : 011-4734-5555

email failache.nestor@ar.sika.com Teléfono de emergencia :

Posadas Hospital 98-82011, 1146587777

SECTION 2. HAZARD IDENTIFICATION

SGA Classification

Not dangerous substance or mixture

Elements tagged GHS Not dangerous
substance or mixture

Other dangers not classified None known.

SECTION 3. COMPOSITION/INFORMATION OF COMPONENTS

Substance /Mixture Mixture

MATERIAL SAFETY TECHNICAL SHEET

Dangerous Components

Does not contain dangerous ingredients

SECTION 4. FIRST AIDS

General Recommendation: No danger that may require special measures of first aids

If inhaled: Take to fresh air

In case of skin contact. Take off contaminated clothes and shoes

MATERIAL SAFETY TECHNICAL SHEET

Verstón 1.0

Number of HDS: 100000015754

Revision date: 2017.03.14

piel

Discard washing with water and soap

In case of eye contact.

: Wash eyes with plenty of water as a caution measure.

Take away lenses.

Keep eyes wide open while washing.

By ingestion Wash mouth with water and after that drink plenty of water.

Do not offer milk or alcoholic drinks.

Never give anything to an unconscious individual.

Main symptoms and acute or retarded effects.

: No significant effects or risks are detected.

See Section 11 for detailed health and symptoms information

Notes for the physician: Treat by symptoms.

SECTION 5. FIREFIGHTING SAFETY MEASURES

Proper firefighting means

: Use extinguishing measures that are appropriate to the place and its surroundings.

Dangerous decomposing products

: No dangerous combustion products are identified.

MATERIAL SAFETY TECHNICAL SHEET

Specific extinguishing methods : Standard Procedures for chemical fires.

Special protection equipment: In case of fire, protect yourself with an autonomous breathing equipment for firefighters against protection.

SECTION 6. MEASURES IN CASE OF ACCIDENTAL SPILLAGE

Warning related to the environment : No special environmental requirements are needed

Methods and material of contention and of cleaning : Clean with absorbent material (for example, a piece of cloth).
Keep the containers appropriately closed for their disposal.

SECTION 7. MANIPULATION AND STORAGE

Indications for fire and explosion protection : Normal dispositions of fire preventive protection

Safe manipulation advice : Individual protection equipment, see section 8.
No special manipulation is advised.
When handling chemical products, follow standard measures of hygiene.


Storage conditions : Keep the containers hermetically closed in a place

Material Safety Technical Sheet.

Separol® Madera

Verstón 1.0

Number of HDS: 100000015754



safe

dry and well ventilated.

Store according to regulations Fióenclohadacle. revision: 2017.03.14

Materials that must be avoided : No special restrictions for storage with
with other products.

SECTION 8. EXPOSURE CONTROL/INDIVIDUAL PROTECTION

Environmental Limit Value Components of professional exposure.

It does not contain substances with limit values of professional exposure.

Personal Protection : Use breathing protection unless there exists exit ventilation

Breathing Protection adequate or at least the exposure evaluation shows the
exposure is within recommended parameters.

The filter class for the breathing apparatus must be adequate for the
maximum concentration anticipated for the contaminant.

(gas/vapor/spray/particles) that may be
present when handling the material. If exceeds this concentration,
there must be

Hand Protection Chemical - resistant and non-permeable gloves that meet
approved standards must be used when there is handling of chemical
products and the risk evaluation indicates that it is
necessary

Eye protection : Eye protection that meets standard requirements
approved must be used when risk evaluation indicates it
necessary.

Skin and body protection : Select the body protection according the characteristics,
concentration and quantity of dangerous substances, and the
specific work place.

Hygiene Measures: Do not eat or drink during its use.

Do not smoke during its use.

SECTION 9. PHYSICAL AND CHEMICAL PROPERTIES.

Aspect :liquid

Color. No data


Odor : characteristic

Odor threshold: No data

pH: No data

Material Safety Technical Sheet.
Separol® Madera

Fusion Point / Freezing Point : No data



—

Material Safety Technical Sheet Separol® Madera

Separo® Madera

Revision date: 2017.03.14

Verstón 1.0

Number of HDS: 100000015754

Revision date: 2017.03.14

Boiling Point/ interval No data

Flash point: > 150 °C (>302 °F)

Method: Closed Cup (System)

Evaporation ratio: No data

Flammability : No data

Superior limit of explosion : No data

Highest limit of explosion : No data

Vapor pressure No data Relative vapor density :

No data

Density : approx.. 0,87 g/cm³ (20 °C (68 °F) ())

Solubility

Solubility in water: No data Solubility in dis
solvents : No data

Coefficient of distribution : No data

octhanol/water Auto-
flammation temperature : No data

Temperature of
decomposition : No data

Viscosity

Viscosity, dynamics: No data Viscosity,

cinematics : > 20,5 mm²/s (40 °C)

Explosive properties : No data Molecular

Weight : No data

SECTION 10. Stability and reactivity

Reactivity : No dangerous reaction known under normal use. Chemical stability: The product is

chemically stable.

Material Safety Technical Sheet

Possible reactions:
Dangerous

: No especial danger

Revision date: 2017.03.14

MATERIAL SAFETY TECHNICAL

Separol® Madera

Revision date: 2017.03.14

Version 1.0

Number of SDS: 100000015754

Conditions that must be avoided: No data

Incompatible materials: No data. It does not decompose if stored and applied as indicated.

SECCION 11, TOXICOLOGIC INFORMATION

Acute toxicity

No data

Corrosion or skin irritation Product:

Not classified in base of information available.

Sever lesions or eye irritation

Not classified in base of information available.

Breathing or skin sensibility

Skin sensibility: Not classified in base of information available.

. Breathing sensibility: Not classified in base of information available.

Mutagenicity in germinal cells :

Not classified in base of information available.

Carcinogenicity :

Not classified in base of information available.

Toxicity for reproduction

Not classified in base of information available.

Specific toxicity in determined organs (stot)- unique exposure

Not classified in base of information available.

Specific toxicity in certain organs (stot) - repeated exposure

Not

classified in base of information available.

Aspiration toxicity

MATERIAL SAFETY TECHNICAL

Not classified in base of information available.

~~Separol® Madera~~

SECTION 12. ECOLOGIC INFORMATION

Revision date: 2017.03.14

Ecotoxicity d

No data Persistency and degradability d No data

Potential of biocummulation No data Mobility in the soil No data Other adverse effects.

Product:

MATERIAL SAFETY TECHNICAL

Separol® Madera

Revision



Version 1.0
100000015754

Number of SDS:

Complement ecologic information No data

SECTION 13. CONSIDERATIONS RELATED TO THE ELIMINATION

Elimination Methods.

Polluted containers: Empty containers must be taken to a site of appropriate handling for waste or disposal.

SECTION 14. INFORMATION RELATED TO TRANSPORT.

International Regulations

IATA-DGR

Not dangerous

Code -IMDG

Not dangerous

Bulk ransport with arrangement to Annex II of the Convenio Marpool 73/78 and the IBC Code.

Not applicable to the product

NCh 2190/382

Not dangerous

SECTION 15. REGULATION INFORMATION

Regulation and legislation in relation to safety, health and environment specific for the substance or mixture

Registry of Carcinogenic Substances and Agents : not applicable

International convention on Chemical Weapons : Not applicable (CWC)

Programs about Toxic Chemical Products

and Precursors (Louisiana Administrative Code, Title 33, Part V Section 10101 et. seq.)

Precursors and chemical essence substances : No applicable for the elaboration of narcotic substances.

MATERIAL SAFETY TECHNICAL

SECTION 16. OTHER INFORMATION

The information contained in this safety data sheet corresponds to our knowledge of level : 2017.03.14 knowledge in the moment of its publication All guarantees excluded. will be applied

Our current general conditions for purchase are applied. Please, check the Product Data Sheet before the use and processing.

REGULAR PETROL

AXIOK SAFETY DATA SHEET

pnernv

Version: 1st March, 2018

IDENTIFICATION OF THE PRODUCT AND COMPANY

Product Name **Regular Petrol.**

Internal Code: .

Predicted Use: Fuel: _

PAN AMERICAN ENERGY LLC, Sucursal Argentina

Av. Leandro N. Alem 0182 (C1221AAT) Ciudad Autónoma de Buenos Aires,

Argentina Teléfonos para consultas técnicas: LUBRICANTS 2822-888-8288

- FUELS 2822-555-3776, 2822-666-3776

Emergency Telephone (24 hours): 0-800-222-2933 (in Argentina)

+541151991409 (out of Argentina)

SECCIÓN II - HAZARD IDENTIFICATION

CLASSIFICATION (according to the Globally Harmonized System)

PICTOGRAM



Flammable liquids (Category 2)

Skin Rush (Category 2)- Eye irritation (Category 2A)

Mutagenicity (Category 1B) - Carcinogenicity (Category 1B)

Reproductive Toxicity (Category 2).

Specific Toxicity in certain organs - sole exposure (Category 3) Danger by inhalation (Category 1)

Danger for aquatic environment - acute danger(Category 2) Danger for aquatic environment - danger in the long term (Category 2)

CAUTION**PELIGRO**

DANGER INDICATIONS:	H225 - Flammable liquids and vapors. H324- Can be lethal in case of ingestion and penetration through respiratory tracks. H315 - Skin rash H319 - Causes severe eye irritation H336 - May cause sleepiness or vértigo. H342 - May cause genetic defects. <u>H35Ü - May cause cancer.</u>
SAFETY ADVICE:	

P212 Avoid heat, sparkles, open fires and other sources of ignition. No smoking.

P273 - Do not spread in the environment.

P282 - Use gloves, clothes and eye/face protection

P321 + P31p + P331 - IN CASE OF INGESTION : Call immediately an INTOXICATION CENTER / physician. Do not induce vomiting.

Version: 1
Replaces : -
Elaborated by :

Emission date:
March

2018

CIQUIME Revised by:

PAN AMERICAN ENERGY LLC,
Argentinian
SUSbsidiary

P303 + P361 + P353 - IN CASE OF SKIN CONTACT (or hair): Take contaminated clothes off immediately.

Wash skin with water or take a shower

P304 + P340 - IN CASE OF INHALATION: Take the person to fresh air and maintain him in a position that may improve his breathing.

P305 + P351 + P338 - IN CASE OF EYE CONTACT: Wash with water for several minutes. Remove lenses when present and can be done easily. Continue with washing.

P370+ P378 IN CASE OF fire: Use water mist, foam, chemical powder or carbon dioxide (CO2) for extinction

P403 + P235 - Store in a well-ventilated place Keep Fresh.

P501 - Discard content/ container according to current national /international regulations.

ADDITIONAL INFORMATION

None

SECTION III - COMPOSITION / INFORMATION OF THE COMPONENTS

SUBSTANCE

Does not apply

MIXTURE

MIXTURE COMPONENTS

N° CAS % WEIGHT CLASSIFICATION

Gasoline	86090 -81-5	Flam. Liquid 1; Skin Irrit. 2; Care. 1B; Muta. 1B. Repr. 2; STOT Single Eqp. 3; Asp. Tox. 1; Aquatic Acute 2; Aquatic
Chronic 2		
Benzene	Flam. Liq. 2; Care. 1A; Muta. 1B; STOT < 2,571-43-2	RE 1; Asp. Tox. 1; Eye Irrit. 2; Skin Irrit. 2; Aquatic Acute 2

SECTION V- FIRST AIDS

GENERAL MEASURES:	Avoid exposure to the product, taking the adequate requirements: See the physician, taking the safety sheet.
EYE CONTACT:	Rinse eyes immediately with water at least for 15 minutes and keep eyes open to guarantee the correct cleaning. and eyelid tissue. Washing the eyes in seconds is essential to reach extreme efficacy. If he/she wears lenses, remove them, after the first 5 minutes and then, continue. Wash immediately with water and soap after contact and
SKIN CONTACT:	during 15 minutes at least.. Take off contaminated clothes or shoes.
INHALATION:	Take the victim to fresh air. Keep calm. If he/she does not breathe, give artificial breathing assistance. Call physician. Do not induce vomiting. Wash mouth with water. Never give
INGESTION :	nothing orally to a non-conscious individual. Call physician. If the vomit is spontaneous, turn the victim on his/her side to reduce
SYMPTOMS :	inhalation: irritation in the nose, throat and lungs. May cause depression to the central nervous system. SKIN CONTACT: Skin rash. Injection at high pressure under the skin may cause severe damage. <u>EYE CONTACT: May be irritant for the eyes.</u>

Notes for the physician: If ingested, the material may be aspirated by the lungs and cause chemical pneumonia. Treat properly. Give symptomatic treatment. For more information, see a physician. Prolonged and repeated exposure to benzene may cause severe lesions to the blood-forming organs and is associated to anemia and the subsequent development of acute myeloid leukemia.

SECTION V- FIREFIGHTING SAFETY MEASURES

PROPER
FIREFIGHTING MEDIA.

Use dry chemical powder , foam, sand or CO2 Use the product according to the materials in the surroundings. DO NOT USE water jet directly.

SPECIFIC DANGERS.

The container exposed to heat may explode unexpectedly and project dangerous fragments.

Vapors are heavier than the air and can be spread on the ground In case of fire it may release smokes and irritant and/or toxic gases, as carbon oxide and other substances derived from incomplete combustion.

SPECIAL
FIREFIGHTING
EQUIPMENT

Use autonomous breathing equipment. Clothes for structural protection for

firefighters provide limited protection in case of fire. Only can it be effective in spill situations. In important spills, use clothes with protection against chemical products, which is specifically recommended by the manufacturer. This may offer little or no thermal protection at all.

Spray containers with water to keep them cold. Cool containers with water jet far after the fire. Fight the fire from a maximum distance or use fixed support for hoses or regulators.

Prevent the water used for fire control or its dilution

SPECIAL MEASURES OF to let into the water inlets , drainages or streams.

FIREFIGHTING SAFETY MEASURES Shuffle away if there is an increasing sound from the safety mechanisms of

ventilation, or if the tank starts to lose color. ALWAYS keep yourself far from tanks involved in fire.

The hot product may cause violent explosions when entering in contact with the water, and the hot material projected may be projected and cause severe burns.

SECTION VI - MEASURES IN CASE OF ACCIDENTAL SPILLAGE

Discard all sources of ignition (do not smoke, do not use flare bombs, sparkles or flames in the area of danger) Stop the leak if it is possible to do it without risks. All the equipments used to handle the product must be earthed, Do not touch or tread over the material spilled. Foam may be used to reduce the emission of vapors. Do not permit reusing the product spilled.

CAUTION OF THE MEDIA ENVIRONMENT: Restrain the liquid with a dam or barrier. Prevent its entrance into navigable trenches, basements or confined spaces not contaminated.

CONTENTION AND CLEANING: Collect the product using sand, vermiculite, earth or inert absorbent material and clean or wash the contaminated area completely. Dispose the water and waste collected into specially signaled containers for its

SECTION VII - HANDLING AND STORAGE.

CAUTION FOR SAFETY HANDLING: elimination as chemical waste.

Eating, drinking or smoking during its manipulation. is forbidden Avoid skin, eye and clothes contact. Wash you arms, hands, and nails after handling this product. Ease the access to safety showers and

emergency eye rinse.

Use equipment and clothes that avoid the accumulation of charge. Store in a clean, dry and well-ventilated area. Protect from the sun. Do not smoke, weld or any work in any task that may produce flames or sparkles.

SAFETY STORAGE CONDITIONS: in the storage area. Keep yourself far from strong oxidants

Keep far from strong oxidant agents, acids and bases, halogens. Package material appropriated: that provided by the manufacturer.

Code NFPA: 1 3 0

CONTROL PARAMETERS:

CMP (Res. MTESS 295/03):	300 ppm; Gasoline 0,5 ppm; Benzene
CMP (Res. MTESS 295/03):	500 ppm; Gasoline
CMP-C (Res. MTESS 295/03):	N/D
REL-TWA:	0,1 ppm, Benzene
REL-STEL:	1 ppm, Benzene
TLV-TWA (ACGIH):	300 ppm; Gasoline 0,5 ppm; Benzene

PROTECTION MEASURES: Keep the working space ventilated. Normal ventilation for habitual operations of manufactures is generally adequate, local extractors must be used during operations that may produce or release big quantities of the product. In low or confined spaces mechanic ventilation must be provided.

BREATHING PROTECTION: In the necessary cases, use breathing protection for organic vapors (A). Pay special attention to oxygen levels present in the air.

If there are high releases, use autonomous breathing equipment

THERMAL PROTECTION:	To handle this product protective nitrile non-permeable gloves must be used (they must respect IRAM3607--36083609 and EN 374 norms), safety work clothes and shoes resistant to products.
---------------------	---

EYE PROTECTION:	Splash- proof goggles must be worn products (that meet EN 166 requirements).
-----------------	--

FORM AND SHAPE:	Clear liquid.
-----------------	---------------

OLOR:	Aromatic.
-------	-----------

Threshold odor:	N/D
-----------------	-----

COLOR:	Lightly yellowish
--------	-------------------

PH:	N/D
-----	-----

FUSION POINT:	N/D
---------------	-----

BOILING POINT:	25°C a 215°C (77°F a 419°F)
----------------	-----------------------------

FLASH POINT:	-40°C (-40°F) [ASTM D56]
--------------	--------------------------

EVAPORATION RATIO:	> 10 (butyl acetate n- = 1)
--------------------	-----------------------------

TEMP. OF AUTOIGNITION:	440°C (824°F)
------------------------	---------------

TEMP. OF DECOMPOSING	N/D
----------------------	-----

FLAMMABILITY:	The product is fammable.
---------------	--------------------------

EXPLOSIVE INTERVAL:	1,0 % - 7,0%
---------------------	--------------

VAPOR PRESSURE (38°C):	455 mmHg (60,5 kPa)
VAPOR DENSITY (AIR:1)	3
DENSITY(15°C):	0,72 g/cm ³
SOLUBILITY IN WATER:	: Insignificant in water.
CONSTANT OF HENRY (20°C)	¿ N/D
COEF. of distribution (logKo/w):	N/D
VISCOSITY (cSt a 20°C):	0.9
Log Koc:	N/D
EXPLOSIVE PROPERTIES	Not explosive According to column 2 of the Annex VII del REACH, this study is not necessary because: there are no molecular groups associated to explosive properties
COMBUSTIBLE PROPERTIES	According to column 2 of the Annex VII del REACH, the study is not necessary since : the substance , by it own chemical structure cannot react in an exothermic form with materials.
OTHER DATA:	None

SECTION X - STABILITY AND REACTIVITY

REACTIVITY	Not expected to produce reactions or decompositions of the product under normal conditions of storage. Does not contain organic peroxides. Not corrosive for metals. Does not react with water.
Chemical stability:	The product is chemically stable and does not require stabilizers.
DANGEROUS REACTIONS:	Dangerous Polymerization is not expected .
CONDITIONS TO AVOID:	Static discharges, heat and pressure Avoid contact with surfaces surfaces (over 80°C)
DANGEROUS PRODUCTS OF DECOMPOSING MATERIALS	In case of overheating it may release irritant and toxic vapors. In case of fire, see Section 5
INCOMPATIBLES:	Keep far from strong oxidant agents, acids and bases, halogens.

SECCION 11, TOXICOLOGIC INFORMATION

EXPOSURE ROUTES:

by inhaling, skin or eye contract.

Severe effects

inhalation: irritation in the nose, throat and lungs. May cause depression

Central Nervous System

SKIN CONTACT: Skin rash. High pressure Injection under

-

~~skin may cause severe damage.~~

	EYE CONTACT: May be irritant for the eyes. Ingestion: If ingested, may be aspired causing lung damage.
CARCINOGENICITY, MUTAGENICITY AND OTHER EFFECTS: Carcinogenic investigation).	Some components of this product are identified as higher or equal than 0.1% that present characteristics of probable human carcinogenic, possible or confirmed by IARC (International Agency for
DATA IN ANIMALS:	ETA-DL50 oral (rat, calc.): > 5000 mg/kg ETA-DL50 der (rabbit, calc.): 2051 mg/kg ETA-CL50 inh. (rat, 4hs., calc.): > 5 mg/l Skin rash (rabbit, estimated): irritant Eye irritation (rabbit, estimated): irritant Skin sensibility (guinea pig, estimates): not observed Breathing sensibility (guinea pig): not observed.

SECCION 11, TOXICOLOGIC INFORMATION

ECO TOXICITY	ETA-CE50 (O. mykiss, calc., 48 h): 8,1 mg/l ETA-CE50 (D. magna, calc., 48 h): 4,6 mg/l ETA-CE50 (D. magna, calc., 48 h): 3,2 mg/l ETA-CE50 (D. magna, calc., 48 h): 15.3 mg/l.
PERSISTENCE AND DEGRADABILITY :	ETA-CSEO (D. rerio, calc., 14 d): 0,2 mg/l ETA-BIODEGRADABILITY (estimated): 75% in 28 days - easily biodegradable. PNEC (water): N/D PNEC (mar): N/D PNEC (mar): N/D This substance/mixture does not fulfill the criteria PBT in the Annex XIII of the REACH regulation.

SECCIÓN XIII - WASTE CONSIDERATION

BIOACCUMULATION:	Log Ko/w: N/D BIOACCUMULATION IN FISH - BCF (OCDE 305): 10 TO 2500. It has potential for bioaccumulate, nevertheless, the metabolism over physical properties may reduce bioconcentration or limit
MOVILITY:	LogKoc: N/D CONSTANT OF HENRY (20°C) N/D
AOX, CONTENT OF METALS:	Does not contain halogens or metals.

The product left as well as empty containers must be eliminated according current legislation of Environmental protection laws and in particular of Dangerous Waste (National Law N°

24.051 and its regulations). The waste must be identified and disposed by an authorized company.

Warning of Empty Containers (where applicable): Empty containers may contain waste and thus be dangerous. Do not try to fill or clean containers without having the appropriate instructions. Empty drums must be purged, completely drained and stored until they are reconditioned or are eliminated permanently. Empty containers must be recycled, reused or eliminated through contractors duly qualified or authorized in concordance with official regulations. DO NOT PRESURE, CUT, WELD WITH HARD METALS OR SOFT ONES , OR WITH STRONG WELDING; AND DO NOT PUT ANY BARRIER, RECTIFY OR EXPOSE THOSE CONTAINERS TO FLAME, SPARKLES , STATIC ELECTRICITY OR ANY OTHER SOURCE OF IGNITION . SINCE THEY MAY EXPLODE AND CAUSE DAMAGE OR DEATH.

SECCIÓN XIV- TRANSPORTATION INFORMATION

TERRESTRIAL TRANSPORT.

TRANSPORT NAME:	GASOLINE	
N° UN/ID:		
DANGER INDICATIONS:	3	
Packing group:	II	
Risk code:	3	
Limited and excepted quantity:	ADR 1L/E2	R. 195/97: 333 Kg

AIR TRANSPORT (ICAO/IATA)

Appropriate Name for shipping	GASOLINE	
N° UN/ID:	1203	At
DANGER INDICATIONS:	3	
Packing group:	II	
Instructions for passenger planes and cargo:	Y341, 1L/353, 5L	
Instructions for passenger planes and cargo:	364, 60L	
CRE:	3H	

TRANSPORTE MARÍTIMO (IMO)

Transport packages according Code IMDG

Appropriate Name for shipping	GASOLINE	
N° UN/ITS:	1203	At
DANGER INDICATIONS:		
Packing group:	II	'ly'
EMS:	F-E; S-E	
Stowage and handling:	Category E	
Segregation:	-	
Marine Pollutant:	YES (naphtha)	

Transport name: UN 12203; GASOLINE; Class 3; PG II; MARINE
POLLUTANT; Flash point -40°C (-40°F) c.c.

SECTION XV - USE REGULATION

Regulation and legislation in relation to safety, health and environment specific for the substance or mixture
No harm to the ozone layer(1005/2009/CE).

Volatile organic contents of the compositions (COV) (1999/13/EC) N/D

Safety Data Sheet according Resolution 801/2015 of the Superintendencia de Riesgos del Trabajo MTESS and the IRAM Law N° 41400 2013 - Safety Data File Format according to SGA. Resolution 295/2003 Ministerio de Trabajo, Empleo y Seguridad Social, República Argentina - Controls of environmental exposition.

Resolución 310/2003 Superintendencia de Riesgos del Trabajo, Ministerio de Trabajo, Empleo y Seguridad Social, República Argentina - Carcinogenic agents.

National Law N° 24.051 and its regulations, República Argentina - Dangerous waste Law Resolution195/97 Secretaría de Obras Públicas y Transporte, República Argentina General Regulation for the Transport of Dangerous Goods by roads.

European Agreement about International Transport of Dangerous Goods by roads. (ADR 2015) Regulation about International Transport of Dangerous Goods by railroads. (RID 2015)

International Maritime Code of Dangerous Goods (Amendment 38-16) IMO Code
IBC/MARPOL, IMO, Resolution MEPC 64/23/Add.1.

Regulations of the International Air Transport Association (IATA 56 ed. 2015) related to transport

of dangerous goods by air.

Sistema Globalmente Armonizado de Clasificación y Etiquetado de Productos Químicos, quinta edición revisada, 2015 (SGA 2015).

International Agency for Research on Cancer (IARC), clasificación de carcinógenos.

SECCIÓN XVI – OTRA INFORMACIÓN

N/A: not applicable

N/D: no data.

CAS Chemical Summary Services IARC:
Agencia Internacional para la Investigación del
Cáncer

ACGIH: American Conference of Governmental
Industrial Hygienists.

TLV: Threshold limit value

TWA Time Weighted Average

STEL Short time Exposure Limit

REL: Recommended Exposure Limit PEL:
Permitted Exposure Limit

INSHT: Institute of National Safety and Hygiene in
Work

ETA: estimation of Acute toxicity. DL50.

Average Lethal Dose

CL50. Average Lethal Concentration

CE50. Average Effective

Concentration CI50. Average

inhibitory Concentration

): Changes respective the previous version

MATERIAL SAFETY DATA SHEET

The classification has been done in base of the chemical analogous and the information of the product.

SECTION 2: classification by analogy with other products, and in base of product data

VSEESCIO1N09: Product Number of HDS: 100000014484

data

Flammability according trial data SECTIONS 11

and 12 analogy with other products.

Revision date: 2016.09.22

Acute toxicity: estimation method of acute toxicity.

This information refers only to the product mentioned in the Section 1 and it will not be valid for other product(s) or any other process. This safety sheet provides safety and health information. The information corresponds to our knowledge , understanding , correct and complete and it is provided bona fide , but with no guarantee at all. The product must be used in applications consistent with our bibliography of the product. The individuals who handle this product, must be informed of the safety cautions recommended and must have access to this information. For any other use, the exposition must be assessed in such a way that it may be applied appropriate practices of handling and training programs to secure safety measures in the working site. In all cases it will be the user's responsibility that this information be appropriate and complete for the especial use of this product.

Version: 1 1 Emission 1st March, 2018

Replaces :

Elaborated by : CIQUIME Revised by: PAN AMERICAN ENERGY LLC,
Argentinian SUSbsidiary